

VERIFICATION OF COMPLIANCE

No.: GPSD GZES2207014001PV01

Applicant: Shenzhen SOFARSOLAR Co., Ltd.

11/F., Gaoxingi Technology Building, No. 67 Area, Xingdong Community,

Xin'an Sub-district, Bao'an District, Shenzhen, Guangdong, China.

Manufacturer: Shenzhen SOFARSOLAR Co., Ltd.

11/F., Gaoxingi Technology Building, No. 67 Area, Xingdong Community,

Xin'an Sub-district, Bao'an District, Shenzhen, Guangdong, China.

Product Name: Hybrid Inverter (Three Phase)

Model No.: HYD 5KTL-3PH, HYD 6KTL-3PH, HYD 8KTL-3PH;

HYD 10KTL-3PH, HYD 15KTL-3PH, HYD 20KTL-3PH;

Trade Mark:

SØFAR

Rating: Refer to page 2 and 3.

Protection against Electric Shock: Class I
Degree of Protection: IP 65

Additional Information (if Firmware version: V2.00

any):

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: VDE 0126-1-1:2013

(include the requirement of Enedis-PRO-RES_10E:26/06/2020,

VFR:2013, VFR:2014 and VFR:2019.)

as shown in the GZES220701400101

Test Report Number(s):

This Verification of GPSD Compliance has been granted to the applicant based on the results of tests performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the General

Product Safety Directive 2001/95/EC

David Guo

Senior Technical Manager

2022-08-02

SGS-CSTC

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services which can be accessible at https://www.sgs.com/en/terms-and-conditions

Member of SGS Group (Société Générale de Surveillance)



No.: GPSD GZES2207014001PV01

Other information added:

Rating:

Model	HYD	HYD	HYD	HYD	HYD	HYD					
	5KTL-3PH	6KTL-3PH	8KTL-3PH	10KTL-3PH	15KTL-3PH	20KTL-3PH					
	PV String Input Data										
Max. DC voltage	1000V										
MPPT voltage range	180V~960V										
Full power MPPT	050)/ 050)/	320V~850V	360V~850V	220V~850V	350V~850V	450V~850V					
voltage range	250V~850V										
Max. input current	12.5A/12.5A	12.5A/12.5A	12.5A/12.5A	25A/25A	25A/25A	25A/25A					
Max. short current	15A/15A	15A/15A	15A/15A	30A/30A	30A/30A	30A/30A					
Battery Input Data											
Battery voltage	190\/ 900\/										
range	180V~800V										
Battery voltage	200V~800V	240\/ 900\/	320V~800V	200V~800V	300V~800V	400V~800V					
range for full load	200 V ~ 600 V	240V~800V	320V~600V	2007~6007	300 7 ~ 600 7	400 V ~000 V					
No. of battery input	1			2							
Nominal											
charging/discharging	5000W	6000W	8000W	10000W	15000W	20000W					
power											
Rated charging/	054	054	054	50A	50A	50A					
discharging current	25A	25A	25A	(25A/25A)	(25A/25A)	(25A/25A)					
Max.				FOA	FOA	FOA					
charging/discharging	25A	25A	25A	50A	50A	50A					
current	RVICES CO., LID			(25A/25A)	(25A/25A)	(25A/25A)					

David Guo

Senior Technical Manager

SGS-CSTC

2022-08-02

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services which can be accessible at https://www.sgs.com/en/terms-and-conditions Member of SGS Group (Société Générale de Surveillance)



No.: GPSD GZES2207014001PV01

Other information added:

Rating:

AC Output Data (On-grid)										
Nominal AC power	5000W	6000W	W0008	10000W	15000W	20000W				
Max. AC power output to utility grid	5500VA	6600VA	8800VA	11000VA	16500VA	22000VA				
Max. AC power from utility grid	10000VA	12000VA	16000VA	20000VA	30000VA	40000VA				
Max. AC current output to utility grid	8A	10A	13A	16A	24A	32A				
Rated AC current output to utility grid	7.2A	8.7A	11.6A	14.5A	21.7A	29A				
Max. AC Current from utility grid	15A	17A	24A	29A	44A	58A				
Nominal output voltage	3/N/PE, 230Vac									
Nominal output freqency	50Hz									
Output power factor	~1(0.8 leading to 0.8 lagging)									
AC Output Data (Back-up)										
Nominal output power	5000W	6000W	W0008	10000W	15000W	20000W				
Max. output power	5500VA	6600VA	8800VA	11000VA	16500VA	22000VA				
Rated. output current	7.2A	8.7A	11.6A	14.5A	21.7A	29A				
Max. output current	8A	10A	13A	16A	24A	32A				
Nominal output voltage	3/N/PE, 230Vac									
Nominal output freqency	50Hz									
Output power factor	~1(0.8 leading to 0.8 lagging)									
Operating temperature range	-30°C ~60°C									
Ingress protection	IP65									
Protective class	Class I									
Cooling methods RNICES CO. LID	Heat sink	Heat sinl	K Heat si	nk Fa	n Fan	Fan				

David Guo

Senior Technical Manager

SGS-CSTC

2022-08-02

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services which can be accessible at https://www.sgs.com/en/terms-and-conditions

Member of SGS Group (Société Générale de Surveillance)