



**TEST REPORT**  
**IEC 61727**  
**Photovoltaic (PV) systems –**  
**Characteristics of the utility interface**

**Report Number** ..... : GZES200601936101

**Date of issue** ..... : 23/06/2020

**Total number of pages** ..... : 26

**Name of Testing Laboratory preparing the Report** ..... : SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch

**Applicant's name**..... : Shenzhen SOFAR SOLAR Co., Ltd.

**Address** ..... : 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen City, Guangdong Province, P.R. China

**Test specification:**

**Standard**..... : IEC 61727:2004 (Second Edition)

**Test procedure**..... : Characteristic Examination

**Non-standard test method**..... : N/A

**Test Report Form No.**..... : IEC61727A

**Test Report Form(s) Originator**.... : TÜV SÜD Product Service GmbH

**Master TRF**..... : Dated 2014-11



**Copyright © 2014 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.**

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.


If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

**This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.**

**General disclaimer:**

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

<b>Test item description</b> .....	Hybrid Inverter (Three Phase)
<b>Trade Mark</b> .....	
<b>Manufacturer</b> .....	Shenzhen SOFAR SOLAR Co., Ltd.
<b>Address</b> .....	401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen City, Guangdong Province, P.R. China
<b>Model/Type reference</b> .....	HYD 5KTL-3PH, HYD 6KTL-3PH, HYD 8KTL-3PH; HYD 10KTL-3PH, HYD 15KTL-3PH, HYD 20KTL-3PH;
<b>Ratings</b> .....	See model list in Page 7 to Page 8. <b>Serial Number:</b> SP1ES020H71002 <b>Firmware version:</b> V2.00

<b>Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):</b>		
<input type="checkbox"/>	<b>GB-Testing Laboratory:</b>	
Testing location/ address .....		
<input type="checkbox"/>	<b>Associated GB-Testing Laboratory:</b>	
Testing location/ address .....		
Tested by (name, function, signature).....:		
Approved by (name, function, signature)....:		
<input checked="" type="checkbox"/>	<b>Testing procedure: TMP/CTF Stage 1:</b>	Shenzhen SOFAR SOLAR Co., Ltd.
Testing location/ address .....		401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen City, Guangdong Province, P.R. China
Tested by (name, function, signature).....:		Hugo Zhang (Project Engineer) 
Approved by (name, function, signature).....:		Roger Hu (Technical Reviewer) 
<input type="checkbox"/>	<b>Testing procedure: WMT/CTF Stage 2:</b>	
Testing location/ address .....		
Tested by (name, function, signature).....:		
Witnessed by (name, function, signature) ..:		
Approved by (name, function, signature)....:		
<input type="checkbox"/>	<b>Testing procedure: SMT/CTF Stage 3 or 4:</b>	
Testing location/ address .....		
Tested by (name, function, signature).....:		
Witnessed by (name, function, signature) ..:		
Approved by (name, function, signature)....:		
Supervised by (name, function, signature) :		

**List of Attachments (including a total number of pages in each attachment):**

50 Hz		
Attachment #	Description	Pages
Attachment I	Pictures of the EUT and Electrical Schemes	10 pages
Attachment II	Testing Information	5 pages
Attachment III	Graphs and Screenshots of Test Results	28 pages

**Summary of testing:**

**Tests performed (name of test and test clause):**

The equipment has been tested according to the standard:  
IEC 61727:2004. Testing has been carried out at 50 Hz

All applicable tests according to the above specified standard have been carried out.

From the result of inspection and tests on the submitted sample, we conclude that it complies with the requirements of the standard.

**Testing location:**


Shenzhen SOFAR SOLAR Co., Ltd.  
401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen City, Guangdong Province, P.R. China

(All clauses)

**Summary of compliance with National Differences:**

No National Differences are addressed to this test report

**Copy of marking plate(representative):**

<b>SOFAR SOLAR</b>	
Hybrid Inverter	
Model No:	<b>HYD 20KTL-3PH</b>
Max.DC Voltage	1000V
MPPT Voltage Range	180~960V
Max. Input Current	25/25A
Max. PV Isc	30/30A
Battery Type	Li-Ion
Battery Voltage Range	180~800V
Battery Max. Charging Current	25/25A
Battery Max. Discharging Current	25/25A
Nominal Grid/Back-up Voltage	3/N/PE, 380/400V
Nominal Grid/Back-up Frequency	50/60Hz
Max. Current Output to Grid	32A
Max. Power Output to Grid	22000VA
Max. Current from Grid	58A
Max. Power from Grid	40000VA
Back-up Max. Output Current	32A
Back-up Max. Output Power	22000VA
Power Factor	1 (adjustable+/-0.8)
Operating Temperature Range	-30~+60°C
Ingress Protection	IP65
Protective Class	Class I
Inverter Topology	Non-isolated
Flicker Impedance	$Z = 0.4 + j0.25 \Omega$
Overvoltage Category	AC III, DC II
Manufacturer : Shenzhen SOFAR SOLAR Co.,Ltd.	
Address : 401, Building 4, AnTongDa Industrial Park,	
District 68, XingDong Community,XinAn Street,	
BaoAn District, Shenzhen, China	
SAA	VDE0126-1-1,VDE-AR-N4105
G98,G99,EN50438,AS4777,UTE C15-712-1	
	

**Note:**

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation
3. Labels of other models are as the same with HYD 20KTL-3PH's except the parameters of rating.

<b>Test item particulars</b> ..... : Hybrid Inverter (Three Phase)	
<b>Classification of installation and use</b> ..... : Fixed (permanent connection)	
<b>Supply Connection</b> ..... : DC; PV ..... : AC; Grid connection	
<b>Possible test case verdicts:</b> - test case does not apply to the test object ..... : N/A - test object does meet the requirement ..... : P (Pass) - test object does not meet the requirement ..... : F (Fail)	
<b>Testing</b> ..... : CTF Stage 1 procedure	
<b>Date of receipt of test item</b> ..... : N/A	
<b>Date (s) of performance of tests</b> ..... : From 29/05/2020 to 19/06/2020	
<b>General remarks:</b>	
<p>"(See Enclosure #)" refers to additional information appended to the report.          "(See appended table)" refers to a table appended to the report.</p> <p>This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <a href="http://www.sgs.com/terms_and_conditions.htm">www.sgs.com/terms_and_conditions.htm</a> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <a href="http://www.sgs.com/terms_e-document.htm">www.sgs.com/terms_e-document.htm</a>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.</p> <p><b>Throughout this report a <input type="checkbox"/> comma / <input checked="" type="checkbox"/> point is used as the decimal separator.</b></p>	
<b>Manufacturer's Declaration per sub-clause 4.2.5 of IEC 62109-2:</b>	
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided ..... :	<input type="checkbox"/> <b>Yes</b> <input checked="" type="checkbox"/> <b>Not applicable</b>
<b>When differences exist; they shall be identified in the General product information section.</b>	
<b>Name and address of factory (ies)</b> ..... : Dongguan SOFAR SOLAR Co.,Ltd. 1F - 6F, Building E, No. 1 JinQi Road, Bihu Industrial Park, Wulian Village, Fenggang Town, Dongguan City, Guangdong Province, P.R. China.	
<b>General product information:</b>	
Product covered by this report is grid-connected PV inverter for indoor or outdoor installation. The connection to the DC input and AC output are through connectors.  The Solar inverter converts DC voltage into AC voltage. The input and output are protected by varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high power switching bridge and a two relays. This assures that	

the opening of the output circuit can operate in case of one error.

**Equipment Under Testing:**

- HYD 20KTL-3PH;

**Variant models:**

- HYD 5KTL-3PH;
- HYD 6KTL-3PH;
- HYD 8KTL-3PH;
- HYD 10KTL-3PH;
- HYD 15KTL-3PH;

Model	HYD 5KTL-3PH	HYD 6KTL-3PH	HYD 8KTL-3PH	HYD 10KTL-3PH	HYD 15KTL-3PH	HYD 20KTL-3PH
<b>PV String Input Data</b>						
Recommended- Max.PV power	7500Wp (6000Wp/6000Wp)	9000Wp (6600Wp/6600Wp)	12000Wp (6600Wp/6600Wp)	15000Wp (7500Wp/7500Wp)	22500Wp (11250Wp/11250Wp)	30000Wp (15000Wp/15000Wp)
Max. DC voltage	1000V					
Start-up operating voltage	200V					
MPPT voltage range	180V~960V					
Nominal DC voltage	600V					
Full power MPPT voltage range	250V~850V	320V~850V	360V~850V	220V~850V	350V~850V	450V~850V
Max. input current	12.5A/12.5A	12.5A/12.5A	12.5A/12.5A	25A/25A	25A/25A	25A/25A
Max. short current	15A/15A	15A/15A	15A/15A	30A/30A	30A/30A	30A/30A
<b>Battery Input Data</b>						
Battery voltage range	180V~800V					
Battery voltage range for full load	200V~800V	240V~800V	320V~800V	200V~800V	300V~800V	400V~800V
No. of battery input	1			2		
Nominal charging/dis-charging power	5000W	6000W	8000W	10000W	15000W	20000W
Max. charging/dis-charging current	25A	25A	25A	50A (25A/25A)	50A (25A/25A)	50A (25A/25A)
Peak charging/dis-charging current, Duration	40A, 60s	40A, 60s	40A, 60s	70A (35A/35A), 60s	70A (35A/35A), 60s	70A (35A/35A), 60s
<b>AC Output Data (On-grid)</b>						
Nominal AC power	5000W	6000W	8000W	10000W	15000W	20000W

Max. AC power output to utility grid	5500VA	6600VA	8800VA	11000VA	16500VA	22000VA
Max. AC power from utility grid	10000VA	12000VA	16000VA	20000VA	30000VA	40000VA
Max. AC current output to utility grid	8A	10A	13A	16A	24A	32A
Max. AC Current from utility grid	15A	17A	24A	29A	44A	58A
AC Output Data (Back-up)						
Nominal output power	5000W	6000W	8000W	10000W	15000W	20000W
Max. output power	5500VA	6600VA	8800VA	11000VA	16500VA	22000VA
Peak output power, Duration	10000VA, 60s	12000VA, 60s	16000VA, 60s	20000VA, 60s	22000VA, 60s	22000VA, 60s
Max. output current	8A	10A	13A	16A	24A	32A
Peak output current, Duration	15A, 60s	18A, 60s	24A, 60s	30A, 60s	32A, 60s	32A, 60s
Nominal output voltage	3/N/PE, 220/380Vac, 230/400Vac					
Nominal output frequency	50/60Hz					
Output power factor	~1(0.8 leading to 0.8 lagging)					
Operating temperature range	-30°C ~60°C					
Ingress protection	IP65					
Protective class	Class I					
Cooling method	heat sink	heat sink	heat sink	fan	fan	fan

The variants models have been included in this test report without tests because the following features don't change regarding to the tested model:

- Same connection system and hardware topology
- Same control algorithm.
- Same Firmware Version



IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict
<b>4</b>	<b>UTILITY COMPATIBILITY</b>		<b>P</b>
	The quality of power provided by the PV system for the on-site AC loads and for power delivered to the utility is governed by practices and standards on voltage, flicker, frequency, harmonics and power factor.		P
	Deviation from these standards represents out-of-bounds conditions and may require the PV system to sense the deviation and properly disconnect from the utility system.		P
<b>4.1</b>	<b>Voltage, current and frequency</b>		<b>P</b>
	The PV system AC voltage, current and frequency are compatible with the utility system.		P
<b>4.2</b>	<b>Normal voltage operating range</b>		<b>P</b>
	Utility-interconnected PV systems do not normally regulate voltage, they inject current into the utility. Therefore, the voltage operating range for PV inverters is selected as a protection function that responds to abnormal utility conditions, not as a voltage regulation function.		P
<b>4.3</b>	<b>Flicker</b>		<b>P</b>
	The operation of the PV system is not cause voltage flicker in excess of limits stated in the relevant sections of IEC 61000-3-3 for systems less than 16 A or IEC 61000-3-5 for systems with current of 16 A and above.	<b>(see appended table)</b>	P
<b>4.4</b>	<b>DC injection</b>		<b>P</b>
	The PV system is not inject DC current greater than 1 % of the rated inverter output current, into the utility AC interface under any operating condition.	<b>(see appended table)</b>	P
<b>4.5</b>	<b>Normal frequency operating range</b>		<b>P</b>
	The PV system operates in synchronism with the utility system, and within the frequency trip limits defined in 5.2.2.		P
<b>4.6</b>	<b>Harmonics and waveform distortion</b>		<b>P</b>
	Total harmonic current distortion is less than 5 % at rated inverter output. Each individual harmonic is limited to the percentages listed in Table 1.	<b>(see appended table)</b>	P
	Even harmonics in these ranges is less than 25 % of the lower odd harmonic limits listed.		P

IEC 61727																			
Clause	Requirement + Test	Result - Remark	Verdict																
	<p align="center"><b>Table 1 – Current distortion limits</b></p> <table border="1"> <thead> <tr> <th>Odd harmonics</th> <th>Distortion limit</th> </tr> </thead> <tbody> <tr> <td>3<sup>rd</sup> through 9<sup>th</sup></td> <td>Less than 4,0 %</td> </tr> <tr> <td>11<sup>th</sup> through 15<sup>th</sup></td> <td>Less than 2,0 %</td> </tr> <tr> <td>17<sup>th</sup> through 21<sup>st</sup></td> <td>Less than 1,5 %</td> </tr> <tr> <td>23<sup>rd</sup> through 33<sup>rd</sup></td> <td>Less than 0,6 %</td> </tr> <tr> <th>Even harmonics</th> <th>Distortion limit</th> </tr> <tr> <td>2<sup>rd</sup> through 8<sup>th</sup></td> <td>Less than 1,0 %</td> </tr> <tr> <td>10<sup>th</sup> through 32<sup>nd</sup></td> <td>Less than 0,5 %</td> </tr> </tbody> </table>	Odd harmonics	Distortion limit	3 <sup>rd</sup> through 9 <sup>th</sup>	Less than 4,0 %	11 <sup>th</sup> through 15 <sup>th</sup>	Less than 2,0 %	17 <sup>th</sup> through 21 <sup>st</sup>	Less than 1,5 %	23 <sup>rd</sup> through 33 <sup>rd</sup>	Less than 0,6 %	Even harmonics	Distortion limit	2 <sup>rd</sup> through 8 <sup>th</sup>	Less than 1,0 %	10 <sup>th</sup> through 32 <sup>nd</sup>	Less than 0,5 %		P
Odd harmonics	Distortion limit																		
3 <sup>rd</sup> through 9 <sup>th</sup>	Less than 4,0 %																		
11 <sup>th</sup> through 15 <sup>th</sup>	Less than 2,0 %																		
17 <sup>th</sup> through 21 <sup>st</sup>	Less than 1,5 %																		
23 <sup>rd</sup> through 33 <sup>rd</sup>	Less than 0,6 %																		
Even harmonics	Distortion limit																		
2 <sup>rd</sup> through 8 <sup>th</sup>	Less than 1,0 %																		
10 <sup>th</sup> through 32 <sup>nd</sup>	Less than 0,5 %																		
4.7	The PV system has a lagging power factor greater than 0,9 when the output is greater than 50 % of the rated inverter output power.	(see appended table)	P																
5	<b>PERSONNEL SAFETY AND EQUIPMENT PROTECTION</b>		P																
	This Clause provides information and considerations for the safe and proper operation of the utility-connected PV systems.		P																
5.1	<b>Loss of utility voltage</b>		P																
	To prevent islanding, a utility connected PV system ceases to energize the utility system from a de-energized distribution line irrespective of connected loads or other generators within specified time limits.		P																
	A utility distribution line can become de-energized for several reasons. For example, a substation breaker opening due to fault conditions or the distribution line switched out during maintenance.		P																
5.2	<b>Over/under voltage and frequency</b>		P																
	The abnormal utility conditions of concern are voltage and frequency excursions above or below the values stated in this Clause, and the complete disconnection of the utility, presenting the potential for a distributed resource island.	(see appended table)	P																
5.2.1	<b>Over/under voltage</b>		P																
	When the interface voltage deviates outside the conditions specified in Table 2, the photovoltaic system ceases to energize the utility distribution system. This applies to any phase of a multiphase system.	(see appended table)	P																
	<p align="center"><b>Table 2 – Response to abnormal voltages</b></p> <table border="1"> <thead> <tr> <th>Voltage (at point of utility connection)</th> <th>Maximum trip time*</th> </tr> </thead> <tbody> <tr> <td><math>V &lt; 0,5 \times V_{nominal}</math></td> <td>0,1 s</td> </tr> <tr> <td><math>50 \% \leq V &lt; 85 \%</math></td> <td>2,0 s</td> </tr> <tr> <td><math>85 \% \leq V \leq 110 \%</math></td> <td>Continuous operation</td> </tr> <tr> <td><math>110 \% &lt; V &lt; 135 \%</math></td> <td>2,0 s</td> </tr> <tr> <td><math>135 \% \leq V</math></td> <td>0,05 s</td> </tr> </tbody> </table> <p>* Trip time refers to the time between the abnormal condition occurring and the inverter ceasing to energize the utility line. The PV system control circuits shall actually remain connected to the utility to allow sensing of utility electrical conditions for use by the "reconnect" feature.</p>	Voltage (at point of utility connection)	Maximum trip time*	$V < 0,5 \times V_{nominal}$	0,1 s	$50 \% \leq V < 85 \%$	2,0 s	$85 \% \leq V \leq 110 \%$	Continuous operation	$110 \% < V < 135 \%$	2,0 s	$135 \% \leq V$	0,05 s		P				
Voltage (at point of utility connection)	Maximum trip time*																		
$V < 0,5 \times V_{nominal}$	0,1 s																		
$50 \% \leq V < 85 \%$	2,0 s																		
$85 \% \leq V \leq 110 \%$	Continuous operation																		
$110 \% < V < 135 \%$	2,0 s																		
$135 \% \leq V$	0,05 s																		
5.2.2	<b>Over/under frequency</b>		P																

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict
	When the utility frequency deviates outside the specified conditions the photovoltaic system ceases to energize the utility line. The unit does not have to cease to energize if the frequency returns to the normal utility continuous operation condition within the specified trip time.	(see appended table)	P
	When the utility frequency is outside the range of $\pm 1$ Hz, the system ceases to energize the utility line within 0,2 s. The purpose of the allowed range and time delay is to allow continued operation for short-term disturbances and to avoid excessive nuisance tripping in weak-utility system conditions.		P
<b>5.3</b>	<b>Islanding protection</b>		<b>P</b>
	The PV system must cease to energize the utility line within 2 s of loss of utility.	Test according IEC 62116: 2014 Refer to Test Report No: GZES200601936102	P
<b>5.4</b>	<b>Response to utility recovery</b>		<b>P</b>
	Following an out-of-range utility condition that has caused the photovoltaic system to cease energizing, the photovoltaic system is not energize the utility line for 20 s to 5 min after the utility service voltage and frequency have recovered to within the specified ranges.	(see appended table)	P
<b>5.5</b>	<b>Earthing</b>		<b>P</b>
	The utility interface equipment is earthed/grounded in accordance with IEC 60364-7-712.		P
<b>5.6</b>	<b>Short circuit protection</b>		<b>P</b>
	The photovoltaic system has short-circuit protection in accordance with IEC 60364-7-712.		P
<b>5.7</b>	<b>Isolation and switching</b>		<b>P</b>
	A method of isolation and switching is provided in accordance with IEC 60364-7-712.		P

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.3	TABLE: Flicker				P
	Starting	Stopping	Running		
Limit	4%	4%	Pst = 1.0	Plt = 0.65	
Sample model	HYD 20KTL-3PH				
<b>33%Pn for 50Hz</b>					
Test value (Phase A)	0.176	0.154	0.061	0.053	
Test value (Phase B)	0.113	0.115	0.142	0.140	
Test value (Phase C)	0.000	0.000	0.053	0.050	
<b>66%Pn for 50Hz</b>					
Test value (Phase A)	0.284	0.353	0.044	0.032	
Test value (Phase B)	0.113	0.101	0.139	0.137	
Test value (Phase C)	0.100	0.112	0.048	0.046	
<b>100%Pn for 50Hz</b>					
Test value (Phase A)	0.155	0.173	0.058	0.053	
Test value (Phase B)	0.108	0.122	0.135	0.135	
Test value (Phase C)	0.000	0.105	0.043	0.041	
<p>Supplementary information:                      The measurements of voltage fluctuations have been measured at 33 %, 66% and 100 % of the nominal power value of the inverter.                      As it can be seen in screenshots in Attachment III, this test has two steps and 10min for each step:                      1.Starting operation                      2.Stopping operation                      The values took of Pst and Plt are the most unfavorable of the two steps.                      As it can be seen in the screenshots in Attachment III. The values took of Pst and Plt are the most unfavorable of the twelve steps and 10min for each step for running operation</p>					

4.4	TABLE: Direct current injection							P	
Rated output current (A)	Ratio of rated output power (VA)	Measured DC output current between terminals (A)						Isolated transformer? (Yes/No)	Limit (A)
		L1-L2	L1-L3	L2-L3	L1-N	L2-N	L3-N		
29.0	33%	--	--	--	0.014	-0.002	-0.013	No	0.290
29.0	66%	--	--	--	0.013	-0.001	-0.014	No	0.290
29.0	100%	--	--	--	0.012	-0.002	-0.014	No	0.290
<p>Supplementary information: N/A</p>									

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(a)	Table: harmonics and waveform distortion (at 33%Pn Phase A, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.111	1	03	0.680	4	
04	0.175	1	05	2.521	4	
06	0.274	1	07	1.354	4	
08	0.188	1	09	0.483	4	
10	0.301	0.5	11	1.661	2	
12	0.077	0.5	13	1.177	2	
14	0.101	0.5	15	0.145	2	
16	0.073	0.5	17	0.478	1.5	
18	0.049	0.5	19	0.852	1.5	
20	0.040	0.5	21	0.102	1.5	
22	0.047	0.5	23	0.191	0.6	
24	0.026	0.5	25	0.535	0.6	
26	0.044	0.5	27	0.035	0.6	
28	0.039	0.5	29	0.227	0.6	
30	0.023	0.5	31	0.369	0.6	
32	0.025	0.5	33	0.034	0.6	
THD	3.847	5	--	--	--	

Supplementary information:

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(b)	Table: harmonics and waveform distortion (at 33%Pn Phase B, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.288	1	03	0.358	4	
04	0.306	1	05	2.108	4	
06	0.469	1	07	0.577	4	
08	0.120	1	09	0.440	4	
10	0.280	0.5	11	1.384	2	
12	0.057	0.5	13	1.015	2	
14	0.056	0.5	15	0.185	2	
16	0.073	0.5	17	0.501	1.5	
18	0.049	0.5	19	0.764	1.5	
20	0.050	0.5	21	0.049	1.5	
22	0.027	0.5	23	0.229	0.6	
24	0.028	0.5	25	0.530	0.6	
26	0.036	0.5	27	0.027	0.6	
28	0.032	0.5	29	0.189	0.6	
30	0.023	0.5	31	0.365	0.6	
32	0.019	0.5	33	0.023	0.6	
THD	3.151	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(c)	Table: harmonics and waveform distortion (at 33%Pn Phase C, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.230	1	03	0.907	4	
04	0.246	1	05	1.555	4	
06	0.284	1	07	1.054	4	
08	0.147	1	09	0.805	4	
10	0.177	0.5	11	1.103	2	
12	0.052	0.5	13	1.124	2	
14	0.129	0.5	15	0.337	2	
16	0.037	0.5	17	0.324	1.5	
18	0.030	0.5	19	0.808	1.5	
20	0.054	0.5	21	0.139	1.5	
22	0.039	0.5	23	0.246	0.6	
24	0.024	0.5	25	0.523	0.6	
26	0.019	0.5	27	0.036	0.6	
28	0.034	0.5	29	0.190	0.6	
30	0.018	0.5	31	0.363	0.6	
32	0.023	0.5	33	0.048	0.6	
THD	3.025	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(d)	Table: harmonics and waveform distortion (at 66%Pn Phase A, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.127	1	03	0.130	4	
04	0.080	1	05	0.971	4	
06	0.085	1	07	0.634	4	
08	0.115	1	09	0.193	4	
10	0.123	0.5	11	0.867	2	
12	0.053	0.5	13	0.675	2	
14	0.046	0.5	15	0.118	2	
16	0.054	0.5	17	0.322	1.5	
18	0.021	0.5	19	0.408	1.5	
20	0.018	0.5	21	0.050	1.5	
22	0.023	0.5	23	0.122	0.6	
24	0.019	0.5	25	0.209	0.6	
26	0.029	0.5	27	0.025	0.6	
28	0.021	0.5	29	0.080	0.6	
30	0.014	0.5	31	0.090	0.6	
32	0.024	0.5	33	0.022	0.6	
THD	1.742	5	--	--	--	
Supplementary information:						



IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(e)	Table: harmonics and waveform distortion (at 66%Pn Phase B, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.048	1	03	0.466	4	
04	0.080	1	05	0.833	4	
06	0.177	1	07	0.322	4	
08	0.114	1	09	0.209	4	
10	0.136	0.5	11	0.620	2	
12	0.059	0.5	13	0.587	2	
14	0.049	0.5	15	0.103	2	
16	0.051	0.5	17	0.253	1.5	
18	0.036	0.5	19	0.347	1.5	
20	0.018	0.5	21	0.061	1.5	
22	0.014	0.5	23	0.142	0.6	
24	0.019	0.5	25	0.195	0.6	
26	0.025	0.5	27	0.021	0.6	
28	0.018	0.5	29	0.087	0.6	
30	0.014	0.5	31	0.088	0.6	
32	0.017	0.5	33	0.019	0.6	
THD	1.465	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(f)	Table: harmonics and waveform distortion (at 66%Pn Phase C, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.116	1	03	0.573	4	
04	0.094	1	05	0.651	4	
06	0.161	1	07	0.599	4	
08	0.050	1	09	0.356	4	
10	0.113	0.5	11	0.504	2	
12	0.042	0.5	13	0.577	2	
14	0.073	0.5	15	0.200	2	
16	0.028	0.5	17	0.198	1.5	
18	0.025	0.5	19	0.367	1.5	
20	0.024	0.5	21	0.110	1.5	
22	0.020	0.5	23	0.084	0.6	
24	0.011	0.5	25	0.209	0.6	
26	0.014	0.5	27	0.044	0.6	
28	0.019	0.5	29	0.092	0.6	
30	0.010	0.5	31	0.092	0.6	
32	0.013	0.5	33	0.020	0.6	
THD	1.482	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(g)	Table: harmonics and waveform distortion (at 100%Pn Phase A, 50Hz)				P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)
02	0.107	1	03	0.248	4
04	0.070	1	05	0.868	4
06	0.070	1	07	0.543	4
08	0.122	1	09	0.176	4
10	0.097	0.5	11	0.696	2
12	0.028	0.5	13	0.514	2
14	0.040	0.5	15	0.114	2
16	0.029	0.5	17	0.245	1.5
18	0.024	0.5	19	0.274	1.5
20	0.022	0.5	21	0.050	1.5
22	0.013	0.5	23	0.099	0.6
24	0.017	0.5	25	0.146	0.6
26	0.020	0.5	27	0.021	0.6
28	0.015	0.5	29	0.025	0.6
30	0.010	0.5	31	0.080	0.6
32	0.015	0.5	33	0.018	0.6
THD	1.459	5	--	--	--
Supplementary information:					

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(h)	Table: harmonics and waveform distortion (at 100%Pn Phase B, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.062	1	03	0.268	4	
04	0.052	1	05	0.506	4	
06	0.111	1	07	0.317	4	
08	0.092	1	09	0.187	4	
10	0.086	0.5	11	0.398	2	
12	0.034	0.5	13	0.441	2	
14	0.030	0.5	15	0.063	2	
16	0.041	0.5	17	0.142	1.5	
18	0.027	0.5	19	0.247	1.5	
20	0.015	0.5	21	0.025	1.5	
22	0.013	0.5	23	0.078	0.6	
24	0.012	0.5	25	0.148	0.6	
26	0.015	0.5	27	0.017	0.6	
28	0.015	0.5	29	0.033	0.6	
30	0.010	0.5	31	0.086	0.6	
32	0.012	0.5	33	0.022	0.6	
THD	0.990	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(i)	Table: harmonics and waveform distortion (at 100%Pn Phase C, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.071	1	03	0.504	4	
04	0.071	1	05	0.585	4	
06	0.106	1	07	0.577	4	
08	0.050	1	09	0.347	4	
10	0.066	0.5	11	0.483	2	
12	0.031	0.5	13	0.529	2	
14	0.053	0.5	15	0.169	2	
16	0.030	0.5	17	0.181	1.5	
18	0.019	0.5	19	0.282	1.5	
20	0.029	0.5	21	0.089	1.5	
22	0.015	0.5	23	0.053	0.6	
24	0.014	0.5	25	0.153	0.6	
26	0.013	0.5	27	0.025	0.6	
28	0.017	0.5	29	0.033	0.6	
30	0.010	0.5	31	0.084	0.6	
32	0.009	0.5	33	0.021	0.6	
THD	1.335	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.7	TABLE: Power factor							P
No	Input			Output				Rated output (V.A)
	Voltage (V d.c.)	Current (A d.c.)	Power (W)	Voltage (V a.c.)	Current (A a.c.)	Power (W)	Power factor	
1	618.2	6.6	4101.5	230.2	5.8	3984.5	0.995 (a) 0.996 (b) N/A (c)	(20±5)%
2	618.0	10.0	6162.4	230.3	8.7	6009.4	0.999 (a) 0.999 (b) N/A (c)	(30±5)%
3	618.3	13.3	8223.8	230.4	11.6	8030.7	0.999 (a) 0.999 (b) N/A (c)	(40±5)%
4	617.9	16.6	10282.5	230.5	14.5	10044.3	0.999 (a) 1.000 (b) N/A (c)	(50±5)%
5	618.5	20.0	12340.3	230.6	17.4	12052.9	1.000 (a) 1.000 (b) N/A (c)	(60±5)%
6	618.6	23.3	14395.2	230.7	20.3	14054.5	1.000 (a) 1.000 (b) N/A (c)	(70±5)%
7	618.7	26.6	16450.6	230.8	23.2	16052.5	1.000 (a) 1.000 (b) N/A (c)	(80±5)%
8	618.9	29.9	18503.7	230.9	26.1	18044.2	0.999 (a) 1.000 (b) N/A (c)	(90±5)%
9	619.0	33.2	20556.7	231.0	28.9	20031.7	1.000 (a) 1.000 (b) N/A (c)	(100±5)%

Supplementary information:  
 Power factor with "+" indicating leading and "-" indicating lagging

Each power stage has been maintained during 60 seconds for measurements with a sampling rate of 0.2 s.

Values offered correspond with the 60s average measured with each corresponding stage.

Except for power factor measurements, where:  
 The value a) indicates the average of measured absolute PF values during each 60s stage of measurement.  
 The value b) indicates the maximum leading PF value measured during each 60s stage of measurement.  
 The value c) indicates the maximum lagging PF value measured during each 60s stage of measurement.

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

5.2.1 & 5.4		TABLE: Under-and over-voltage trip settings and reconnection test						P
<b>(1) Under voltage disconnection procedure</b>								
Rated output voltage (V)	Output power (VA)	Required min. voltage (V)	Value of PCE trip settings (V)	Ratio of decreased (V / s)	Interval time (ms)	Measured tripped voltage (V)	Measured disconnection time (ms)	
50 % Vn ≤ V < 85 % Vn Phase ABC								
230	20000	195	195	--	2000	194.4	1633	
230	20000	155	155	--	2000	154.3	1645	
230	20000	117	117	--	2000	115.5	1645	
V < 50%Vn Phase ABC								
230	20000	114	114	--	100	112.8	72	
<b>(2) Under voltage reconnection procedure</b>								
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)		Reconnection time (s)			
--			197.6		63.6			
<b>(3) Over voltage disconnection procedure</b>								
Rated output voltage (V)	Output power (VA)	Required max. voltage (V)	Value of PCE trip settings (V)	Ratio of increased (V / s)	Interval time (ms)	Measured tripped voltage (V)	Measured disconnection time (ms)	
110 % Vn < V < 135 % Vn Phase ABC								
230	20000	255	255	--	2000	252.9	1624	
230	20000	282	282	--	2000	281.2	35	
230	20000	309	309	--	2000	285.5(*)	6	
(*) Due to the hardware problem of the machine, the voltage has not reached the expected value of trip protection 309V.								
135 % Vn ≤ V Phase ABC								
230	20000	312	312	--	50	290.5(*)	6.0	
(*) Due to the hardware problem of the machine, the voltage has not reached the expected value of trip protection 312V.								
<b>(4) Over voltage reconnection procedure</b>								
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)		Reconnection time (s)			
--			251.2		63.2			
Supplementary information:								
N/A								

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

5.2.2 & 5.4		TABLE: Over/under frequency trip settings and reconnection test						Pass
<b>(1) Under frequency disconnection procedure</b>								
Rated output frequency (Hz)	Output power (VA)	Required min. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of decreased (Hz / s)	Interval time (ms)	Measured tripped frequency (Hz)	Measured disconnection time (ms)	
50	20000	49	49	--	200	49.0	163	
<b>(2) Under frequency reconnection procedure</b>								
Ratio of voltage rapidly decreased (Hz / s)			Reconnection frequency (Hz)		Reconnection time (s)			
--			49.1		63.4			
<b>(3) Over frequency disconnection procedure</b>								
Rated output frequency (Hz)	Output power (VA)	Required max. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of increased (Hz / s)	Interval time (ms)	Measured tripped frequency (Hz)	Measured disconnection time (ms)	
50	20000	51	51	--	200	51.0	188	
<b>(4) Over frequency reconnection procedure</b>								
Ratio of voltage rapidly decreased (Hz / s)			Reconnection frequency (Hz)		Reconnection time (s)			
--			50.9		64.0			
Supplementary information: N/A								



IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

5.3 Table: tested condition and run-on time									P
No.	P <sub>EUT</sub> (% of EUT rating)	Reac-tive load (% of normal)	P <sub>AC</sub>	Q <sub>AC</sub>	Run-on time(ms )	P <sub>EUT</sub> (KW)	Actual Q <sub>f</sub>	V <sub>DC</sub> (d.c.V)	Which load is selected to be adjusted (R or L)
Test condtion A									
1	100	100	0	0	544	20.1	1.01	808.2	--
2	100	100	-5	-5	404	20.2	1.05	808.6	R/L
3	100	100	-5	0	436	20.1	1.05	808.7	R
4	100	100	-5	+5	410	20.2	1.03	808.2	R/L
5	100	100	0	-5	482	20.1	1.02	808.8	L
6	100	100	0	+5	510	20.1	1.05	808.6	L
7	100	100	+5	-5	412	20.1	0.98	809.1	R/L
8	100	100	+5	0	442	20.2	0.96	808.3	R
9	100	100	+5	+5	414	20.1	0.96	808.5	R/L
10	100	100	-10	+10	--	--	--	--	R/L
11	100	100	-5	+10	--	--	--	--	R/L
12	100	100	0	+10	--	--	--	--	L
13	100	100	+10	+10	--	--	--	--	R/L
14	100	100	+10	+5	--	--	--	--	R/L
15	100	100	+10	0	--	--	--	--	R
16	100	100	+10	-5	--	--	--	--	R/L
17	100	100	+10	-10	--	--	--	--	R/L
18	100	100	+5	-10	--	--	--	--	R/L
19	100	100	+5	10	--	--	--	--	R/L
20	100	100	0	-10	--	--	--	--	L
21	100	100	-5	-10	--	--	--	--	R/L
22	100	100	-10	-10	--	--	--	--	R/L
23	100	100	-10	-5	--	--	--	--	R/L
24	100	100	-10	0	--	--	--	--	R/L
25	100	100	-10	+5	--	--	--	--	R/L
Test condtion B									

IEC 61727									
Clause	Requirement + Test				Result - Remark				Verdict
10	66	66	0	0	496	13.2	1.00	571.2	--
11	66	66	0	-5	418	13.2	1.02	571.8	L
12	66	66	0	-4	430	13.2	1.02	571.7	L
13	66	66	0	-3	444	13.2	1.02	571.4	L
14	66	66	0	-2	446	13.2	1.01	572.0	L
15	66	66	0	-1	462	13.2	1.00	571.6	L
16	66	66	0	1	490	13.2	1.00	571.8	L
17	66	66	0	2	468	13.2	0.99	572.1	L
18	66	66	0	3	458	13.2	0.98	571.8	L
19	66	66	0	4	452	13.2	0.98	571.9	L
20	66	66	0	5	404	13.2	0.97	571.3	L
21	66	66	0	6	--	--	--	--	L
Test condition C									
22	33	33	0	0	518	6.6	1.00	328.3	--
23	33	33	0	-5	380	6.6	1.03	328.4	L
24	33	33	0	-4	442	6.6	1.02	328.9	L
25	33	33	0	-3	448	6.6	1.02	329.0	L
26	33	33	0	-2	466	6.6	1.01	328.5	L
27	33	33	0	-1	482	6.6	1.01	328.3	L
28	33	33	0	1	508	6.6	1.00	328.2	L
29	33	33	0	2	444	6.6	0.99	329.1	L
30	33	33	0	3	424	6.6	0.99	328.8	L
31	33	33	0	4	422	6.6	0.98	328.6	L
32	33	33	0	5	396	6.6	0.97	328.4	L
33	33	33	0	6	--	--	--	--	L
<p>Remark:</p> <p>For test condition A:            If any of the recorded run-on times are longer than the one recorded for the rated balance condition, then the non-shaded parameter combinations also require testing.</p> <p>For test condition B and C:            If run-on times are still increasing at the 95 % or 105 % points, additional 1 % increments is taken until run-on times begin decreasing.</p> <p>The compliances with these requirements are stated in the following test report:            IEC 62116: test report n° GZES200601936102</p>									

--- End of test report---

# **Attachment I**

**(Pictures of the EUT and Electrical Schemes)**

1 PICTURES

Front view



Back view




**Internal View 1**




**Internal View 2**




**Front side of Power board**




**Back side of Power board**




Front side of Display board




Back side of Display board



**Front side of Control board**




**Back side of Control board**






**Front side of Output board front**



**Back side of Output board front**



Grounding




Connection interface



## Serial Number and Software Version

Inverter Info(1)  
Product SN: SP1ES020H71002  
ARM Software Version: V2.00  
Main DSP Software Version: D010136  
Slave DSP Software Version: D010134


2 ELECTRICAL SCHEMES



## **Attachment II**

**(Testing information)**

## 1 TESTING CIRCUIT



Current and voltage clamps have been connected to the inverter input/output for all the tests.

All the tests and checks have been performed in accordance with the reference standard under testing.

**2 TESTING EQUIPMENT**

From	No.	Equipment Name	Model No.	Equipment No.	Calibration Date	Equipment calibration due date
Sofar Solar	1	Digital oscilloscope	MD03024	MY58491772	2020/04/24	2021/04/23
	2	Voltage probe	SI-9110	111152	2020/1/14	2021/1/13
	3	Voltage probe	SI-9110	152627	2020/01/14	2021/01/13
	4	Voltage probe	SI-9110	111134	2020/01/14	2021/01/13
	5	Power analyzer	PA5000H	C8202909082002 110001	2020/03/02	2021/03/01
	6	Current probe	CP1000A	C181000922	2020/01/14	2021/01/13
	7	Current probe	CP1000A	C181000925	2020/01/14	2021/01/13
	8	Current probe	CP1000A	C181000929	2020/01/14	2021/01/13
	9	Temperature & Humidity meter	TH101B	ZB-WSDJ-001	2020/01/14	2021/01/13
SGS	10	True RMS Multimeter	Fluke / 187	GZE012-8	2019/12/05	2020/12/04

**IEC 61727:2004**

Items	Specifications
1) PV array simulator	
a) Voltage range	0 – 1000Vdc ( 0.01V step)
b) Current range	0 – 40A ( 0.01A step)
2) AC power source	
a) Output wiring	Three phase
b) Output capacity	30KVA
c) Output voltage	10-300Vrms
d) Output frequency	45-65Hz
e) Voltage stability	± 100ppm/°C
f) Output voltage distortion	0.05% max.
3) Digital meter	
a) Voltage range	0 – 1000Vdc, 0 – 600Vrms
b) Current range	0 – 30A
c) Frequency range ( accuracy)	0.2%
d) Measurement items	Voltage (V)    Current (A)    Active power (W) Reactive power (Var) Volt-ampere (VA) Power factor (PF) Frequency (Hz) Electric energy (Wh)
4) Waveform recorder	
a) Sampling speed	1M/s
b) Recording device	Memory record and USB reading
c) Time accuracy	± 500ppm
5) AC load	
a) Resistive load	Maximum voltage: 300Vrms Current range: 0 – 100A Capacity: 30KW
b) Inductive load	Maximum voltage: 300Vrms Current range: 0 – 100A Capacity: 30KVA
c) Capacitive load	Maximum voltage: 300Vrms Current range: 0 – 100A Capacity: 30KVA



**3 MEASUREMENT UNCERTAINTY**

<b>Magnitude</b>	<b>Uncertainty</b>
Voltage measurement	±1.5 %
Current measurement	±2.0 %
Frequency measurement	±0.2 %
Time measurement	±0.2 %
Power measurement	±2.5 %
Phase Angle	±1°
Temperature	±3° C
<p>Note1: Measurements uncertainties showed in this table are maximum allowable uncertainties. The measurement uncertainties associated with other parameters measured during the tests are in the laboratory at disposal of the petitioner.</p> <p>Note2: Where the standard requires lower uncertainties that those in this table. Most restrictive uncertainty has been considered.</p>	

## **Attachment III**

**(GRAPHS AND SCREENSHORTS OF TEST RESULTS)**

**Flickers**

The measurements of voltage fluctuations have been measured at 33 %, 66% and 100 % of the nominal power value of the inverter.

As it can be seen in the next screenshots, this test has two steps:

- 1.Starting operation
- 2.Stopping operation

The values took of Dmax of the two steps.

**Starting operation and Stopping operation for 50Hz**  
**33% Pn (Phase A)**

No.	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:2
1	0.129 Pass	0.176 Pass	0.0 Pass	0.055 Pass	
2	0.102 Pass	0.154 Pass	0.0 Pass	0.054 Pass	
<b>Result</b>	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>	<b>0.054 Pass</b>

**33% Pn (Phase B)**

No.	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:2
1	0.031 Pass	0.113 Pass	0.0 Pass	0.136 Pass	
2	0.036 Pass	0.115 Pass	0.0 Pass	0.136 Pass	
<b>Result</b>	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>	<b>0.136 Pass</b>

**IEC 61727:2004**

### 33% Pn (Phase C)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7  
I1 I2 I3 I4 I5 I6 I7

SCL  Line Filter

AVG  Freq Filter

PA\_00018.tif

CH: 1 2 3  
4 5 6 7

Count █ 2/2 Complete

Interval █ 00:00s/10:00s

Element 3

Volt Range 300 V/50Hz Element3 Judgement Pass

Un (U3) 230.364V Total Judgement Pass

Freq (U3) 50.000Hz (Element1,2,3)

Dmin 0.10%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:2
No. 1	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.042 <span style="color: green;">Pass</span>	
2	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.043 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.042 <span style="color: green;">Pass</span>

Update: 642

Runtime: 5:32:19

38% 10% 2020-06-06 14:14:06

Σ A(3P4W)

U1 300 V  
I1 50 A  
Sync Src: U1  
Integral: Reset

U2 300 V  
I2 50 A  
Sync Src: U1  
Integral: Reset

U3 300 V  
I3 50 A  
Sync Src: U1  
Integral: Reset

Element 4

U4 1000 V  
I4 50 A  
Sync Src: U1  
Integral: Reset

Element 5

U5 1000 V  
I5 5 A  
Sync Src: U1  
Integral: Reset

### 66% Pn (Phase A)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7  
I1 I2 I3 I4 I5 I6 I7

SCL  Line Filter

AVG  Freq Filter

CH: 1 2 3  
4 5 6 7

Count █ 2/2 Complete

Interval █ 00:00s/10:00s

Element 1

Volt Range 300 V/50Hz Element1 Judgement Pass

Un (U1) 230.468V Total Judgement Pass

Freq (U1) 50.000Hz (Element1,2,3)

Dmin 0.10%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:2
No. 1	0.094 <span style="color: green;">Pass</span>	0.284 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.058 <span style="color: green;">Pass</span>	
2	0.108 <span style="color: green;">Pass</span>	0.353 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.059 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.059 <span style="color: green;">Pass</span>

Update: 633

Runtime: 5:08:58

38% 10% 2020-06-06 13:50:45

Σ A(3P4W)

U1 300 V  
I1 50 A  
Sync Src: U1  
Integral: Reset

U2 300 V  
I2 50 A  
Sync Src: U1  
Integral: Reset

U3 300 V  
I3 50 A  
Sync Src: U1  
Integral: Reset

Element 4

U4 1000 V  
I4 50 A  
Sync Src: U1  
Integral: Reset

Element 5

U5 1000 V  
I5 5 A  
Sync Src: U1  
Integral: Reset

### 66% Pn (Phase B)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7  
I1 I2 I3 I4 I5 I6 I7

SCL  Line Filter

AVG  Freq Filter

PA\_00013.tif

CH: 1 2 3  
4 5 6 7

Count 2/2 Complete

Interval 00:00s/10:00s

Element 2

Volt Range 300 V/50Hz Element2 Judgement Pass

Un (U2) 230.528V Total Judgement Pass

Freq (U2) 50.000Hz (Element1,2,3)

Dmin 0.10%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:2
No. 1	0.034 <span style="color: green;">Pass</span>	0.113 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.135 <span style="color: green;">Pass</span>	
2	0.001 <span style="color: green;">Pass</span>	0.101 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.135 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.135 <span style="color: green;">Pass</span>

Update: 637

Runtime: 5:09:06

38% 10% 2020-06-06 13:50:53

Σ A(3P4W)

U1 300 V  
I1 50 A  
Sync Src: U1  
Integral: Reset

U2 300 V  
I2 50 A  
Sync Src: U1  
Integral: Reset

U3 300 V  
I3 50 A  
Sync Src: U1  
Integral: Reset

Element 4

U4 1000 V  
I4 50 A  
Sync Src: U1  
Integral: Reset

Element 5

U5 1000 V  
I5 5 A  
Sync Src: U1  
Integral: Reset

### 66% Pn (Phase C)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7  
I1 I2 I3 I4 I5 I6 I7

SCL  Line Filter

AVG  Freq Filter

PA\_00014.tif

CH: 1 2 3  
4 5 6 7

Count 2/2 Complete

Interval 00:00s/10:00s

Element 3

Volt Range 300 V/50Hz Element3 Judgement Pass

Un (U3) 230.635V Total Judgement Pass

Freq (U3) 50.000Hz (Element1,2,3)

Dmin 0.10%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:2
No. 1	0.019 <span style="color: green;">Pass</span>	0.100 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.042 <span style="color: green;">Pass</span>	
2	0.008 <span style="color: green;">Pass</span>	0.112 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.043 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.043 <span style="color: green;">Pass</span>

Update: 640

Runtime: 5:09:13

38% 10% 2020-06-06 13:51:00

Σ A(3P4W)

U1 300 V  
I1 50 A  
Sync Src: U1  
Integral: Reset

U2 300 V  
I2 50 A  
Sync Src: U1  
Integral: Reset

U3 300 V  
I3 50 A  
Sync Src: U1  
Integral: Reset

Element 4

U4 1000 V  
I4 50 A  
Sync Src: U1  
Integral: Reset

Element 5

U5 1000 V  
I5 5 A  
Sync Src: U1  
Integral: Reset

**IEC 61727:2004**

### 100% Pn (Phase A)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7  
I1 I2 I3 I4 I5 I6 I7

SCL  Line Filter

AVG  Freq Filter

CH: 1 2 3  
4 5 6 7

Count █ 2/2 Complete

Interval █ 00:00s/10:00s

Element 1

Volt Range 300 V/50Hz

Un (U1) 230.901V

Freq (U1) 50.000Hz

Dmin 0.10%

Element1 Judgement Pass

Total Judgement Pass

(Element1,2,3)

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
No. 1	0.105 <span style="color: green;">Pass</span>	0.155 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.061 <span style="color: green;">Pass</span>	N:2
2	0.101 <span style="color: green;">Pass</span>	0.173 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.054 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.058 <span style="color: green;">Pass</span>

Update: 727

Runtime: 2:33:03

38% 10% 2020-06-06 11:14:49

Σ(A3P4W)

U1 300 V  
I1 50 A  
Sync Src: U1  
Integral: Reset

U2 300 V  
I2 50 A  
Sync Src: U1  
Integral: Reset

U3 300 V  
I3 50 A  
Sync Src: U1  
Integral: Reset

Element 4

U4 1000 V  
I4 50 A  
Sync Src: U1  
Integral: Reset

Element 5

U5 1000 V  
I5 5 A  
Sync Src: U1  
Integral: Reset

### 100% Pn (Phase B)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7  
I1 I2 I3 I4 I5 I6 I7

SCL  Line Filter

AVG  Freq Filter

PA\_00010.tif

CH: 1 2 3  
4 5 6 7

Count █ 2/2 Complete

Interval █ 00:00s/10:00s

Element 2

Volt Range 300 V/50Hz

Un (U2) 230.892V

Freq (U2) 50.000Hz

Dmin 0.10%

Element2 Judgement Pass

Total Judgement Pass

(Element1,2,3)

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
No. 1	0.010 <span style="color: green;">Pass</span>	0.108 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.139 <span style="color: green;">Pass</span>	N:2
2	0.012 <span style="color: green;">Pass</span>	0.122 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.139 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.139 <span style="color: green;">Pass</span>

Update: 732

Runtime: 2:33:12

38% 10% 2020-06-06 11:14:59

Σ(A3P4W)

U1 300 V  
I1 50 A  
Sync Src: U1  
Integral: Reset

U2 300 V  
I2 50 A  
Sync Src: U1  
Integral: Reset

U3 300 V  
I3 50 A  
Sync Src: U1  
Integral: Reset

Element 4

U4 1000 V  
I4 50 A  
Sync Src: U1  
Integral: Reset

Element 5

U5 1000 V  
I5 5 A  
Sync Src: U1  
Integral: Reset

### 100% Pn (Phase C)

Flicker Mode  
Flicker

Range Over

U1	U2	U3	U4	U5	U6	U7
I1	I2	I3	I4	I5	I6	I7

SCL  Line Filter

AVG  Freq Filter

PA\_00011.tif

CH:

1	2	3	
4	5	6	7

Count █ 2/2 Complete

Interval 00:00s/10:00s

Element 3

Volt Range 300 V/50Hz

Un (U3) 231.048V

Freq (U3) 50.000Hz

Dmin 0.10%

Element3

Total (Element1,2,3)

Judgement Pass

Judgement Pass

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:2
No. 1	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.049 <span style="color: green;">Pass</span>	
2	0.004 <span style="color: green;">Pass</span>	0.105 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.049 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.049 <span style="color: green;">Pass</span>

Update: 735

Runtime: 2:33:19

38%  
10%

2020-06-06  
11:15:06

Σ A(3P4W)

U1 300 V

I1 50 A

Sync Src: U1

Integral: Reset

U2 300 V

I2 50 A

Sync Src: U1

Integral: Reset

U3 300 V

I3 50 A

Sync Src: U1

Integral: Reset

Element 4

U4 1000 V

I4 50 A

Sync Src: U1

Integral: Reset

Element 5

U5 1000 V

I5 5 A

Sync Src: U1

Integral: Reset

As it can be seen in the next screenshots is running operation. The values took of Pst and Plt are the most unfavorable of the twelve steps.

### Running operation for 50Hz

#### 33% Pn (Phase A)

No.	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12
1	0.087 Pass	0.188 Pass	0.0 Pass	0.041 Pass	
2	0.085 Pass	0.159 Pass	0.0 Pass	0.039 Pass	
3	0.110 Pass	0.159 Pass	0.0 Pass	0.048 Pass	
4	0.113 Pass	0.161 Pass	0.0 Pass	0.054 Pass	
5	0.113 Pass	0.153 Pass	0.0 Pass	0.053 Pass	
6	0.115 Pass	0.136 Pass	0.0 Pass	0.058 Pass	
7	0.106 Pass	0.162 Pass	0.0 Pass	0.061 Pass	
8	0.103 Pass	0.137 Pass	0.0 Pass	0.057 Pass	
9	0.104 Pass	0.156 Pass	0.0 Pass	0.056 Pass	
10	0.097 Pass	0.134 Pass	0.0 Pass	0.054 Pass	
11	0.103 Pass	0.162 Pass	0.0 Pass	0.054 Pass	
12	0.099 Pass	0.154 Pass	0.0 Pass	0.057 Pass	
Result	Pass	Pass	Pass	Pass	0.053 Pass

### 33% Pn (Phase B)

No.	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12
1	0.004 Pass	0.111 Pass	0.0 Pass	0.142 Pass	
2	0.003 Pass	0.119 Pass	0.0 Pass	0.141 Pass	
3	0.011 Pass	0.101 Pass	0.0 Pass	0.140 Pass	
4	0.012 Pass	0.111 Pass	0.0 Pass	0.140 Pass	
5	0.000 Pass	0.000 Pass	0.0 Pass	0.140 Pass	
6	0.000 Pass	0.000 Pass	0.0 Pass	0.140 Pass	
7	0.000 Pass	0.000 Pass	0.0 Pass	0.139 Pass	
8	0.018 Pass	0.158 Pass	0.0 Pass	0.140 Pass	
9	0.014 Pass	0.123 Pass	0.0 Pass	0.139 Pass	
10	0.009 Pass	0.107 Pass	0.0 Pass	0.140 Pass	
11	0.006 Pass	0.102 Pass	0.0 Pass	0.139 Pass	
12	0.009 Pass	0.117 Pass	0.0 Pass	0.140 Pass	
Result	Pass	Pass	Pass	Pass	0.140 Pass



**IEC 61727:2004**

### 33% Pn (Phase C)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7  
I1 I2 I3 I4 I5 I6 I7

SCL  Line Filter

AVG  Freq Filter

PA\_00002.tif

CH: 1 2 3  
4 5 6 7

Count: 12/12 Complete

Interval: 00:00s/10:00s

Element: 3

Volt Range: 600 V/50Hz

Un (U3): 230.213V

Freq (U3): 50.000Hz

Dmin: 0.10%

Element3: (Element1,2,3)

Judgement: Pass

Total Judgement: Pass

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.053 <span style="color: green;">Pass</span>	
2	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.051 <span style="color: green;">Pass</span>	
3	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.049 <span style="color: green;">Pass</span>	
4	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.050 <span style="color: green;">Pass</span>	
5	0.017 <span style="color: green;">Pass</span>	0.108 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.050 <span style="color: green;">Pass</span>	
6	0.020 <span style="color: green;">Pass</span>	0.106 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.049 <span style="color: green;">Pass</span>	
7	0.014 <span style="color: green;">Pass</span>	0.104 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.050 <span style="color: green;">Pass</span>	
8	0.057 <span style="color: green;">Pass</span>	0.109 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.050 <span style="color: green;">Pass</span>	
9	0.049 <span style="color: green;">Pass</span>	0.108 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.049 <span style="color: green;">Pass</span>	
10	0.002 <span style="color: green;">Pass</span>	0.106 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.048 <span style="color: green;">Pass</span>	
11	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.049 <span style="color: green;">Pass</span>	
12	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.049 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.050 <span style="color: green;">Pass</span>

Update: 3655

Runtime: 5:05:00

50% 10% x1 2020-06-03 13:31:12

### 66% Pn (Phase A)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7  
I1 I2 I3 I4 I5 I6 I7

SCL  Line Filter

AVG  Freq Filter

PA\_00000.tif

CH: 1 2 3  
4 5 6 7

Count: 12/12 Complete

Interval: 00:00s/10:00s

Element: 1

Volt Range: 600 V/50Hz

Un (U1): 230.272V

Freq (U1): 50.000Hz

Dmin: 0.10%

Element1: (Element1,2,3)

Judgement: Pass

Total Judgement: Pass

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	0.114 <span style="color: green;">Pass</span>	0.159 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.044 <span style="color: green;">Pass</span>	
2	0.068 <span style="color: green;">Pass</span>	0.109 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.037 <span style="color: green;">Pass</span>	
3	0.092 <span style="color: green;">Pass</span>	0.132 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.027 <span style="color: green;">Pass</span>	
4	0.017 <span style="color: green;">Pass</span>	0.165 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.033 <span style="color: green;">Pass</span>	
5	0.098 <span style="color: green;">Pass</span>	0.213 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.025 <span style="color: green;">Pass</span>	
6	0.071 <span style="color: green;">Pass</span>	0.133 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.025 <span style="color: green;">Pass</span>	
7	0.078 <span style="color: green;">Pass</span>	0.171 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.026 <span style="color: green;">Pass</span>	
8	0.104 <span style="color: green;">Pass</span>	0.199 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.032 <span style="color: green;">Pass</span>	
9	0.036 <span style="color: green;">Pass</span>	0.151 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.027 <span style="color: green;">Pass</span>	
10	0.095 <span style="color: green;">Pass</span>	0.152 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.028 <span style="color: green;">Pass</span>	
11	0.081 <span style="color: green;">Pass</span>	0.146 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.030 <span style="color: green;">Pass</span>	
12	0.090 <span style="color: green;">Pass</span>	0.144 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.033 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.032 <span style="color: green;">Pass</span>

Update: 3716

Runtime: 7:39:47

51% 10% x1 2020-06-03 16:06:00

**IEC 61727:2004**

### 66% Pn (Phase B)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7  
U11 U12 U13 U14 U15 U16 U17

SCL  Line Filter

AVG  Freq Filter

PA\_00004.tif

CH: 1 2 3  
4 5 6 7

Count: 12/12 Complete

Interval: 00:00s/10:00s

Element: 2

Volt Range: 600 V/50Hz

Un (U2): 230.157V

Freq (U2): 50.000Hz

Dmin: 0.10%

Element2: Total (Element1,2,3)

Judgement: Pass

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	0.010 <span style="color: green;">Pass</span>	0.119 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.139 <span style="color: green;">Pass</span>	
2	0.007 <span style="color: green;">Pass</span>	0.111 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.138 <span style="color: green;">Pass</span>	
3	0.006 <span style="color: green;">Pass</span>	0.114 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.137 <span style="color: green;">Pass</span>	
4	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.136 <span style="color: green;">Pass</span>	
5	0.007 <span style="color: green;">Pass</span>	0.104 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.136 <span style="color: green;">Pass</span>	
6	0.009 <span style="color: green;">Pass</span>	0.103 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.137 <span style="color: green;">Pass</span>	
7	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.136 <span style="color: green;">Pass</span>	
8	0.006 <span style="color: green;">Pass</span>	0.105 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.137 <span style="color: green;">Pass</span>	
9	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.137 <span style="color: green;">Pass</span>	
10	0.011 <span style="color: green;">Pass</span>	0.104 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.136 <span style="color: green;">Pass</span>	
11	0.010 <span style="color: green;">Pass</span>	0.119 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.137 <span style="color: green;">Pass</span>	
12	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.137 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.137 <span style="color: green;">Pass</span>

Update: 3722

Runtime: 7:40:00

51% 10% 2020-06-03 16:06:13

ΣA(3P4W)

U1 600 V  
I1 50 A  
Sync Src: U1  
Integral: Reset

U2 600 V  
I2 50 A  
Sync Src: U1  
Integral: Reset

U3 600 V  
I3 50 A  
Sync Src: U1  
Integral: Reset

Element 4

U4 1000 V  
I4 50 A  
Sync Src: U1  
Integral: Reset

Element 5

U5 1000 V  
I5 5 A  
Sync Src: U1  
Integral: Reset

### 66% Pn (Phase C)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7  
U11 U12 U13 U14 U15 U16 U17

SCL  Line Filter

AVG  Freq Filter

PA\_00005.tif

CH: 1 2 3  
4 5 6 7

Count: 12/12 Complete

Interval: 00:00s/10:00s

Element: 3

Volt Range: 600 V/50Hz

Un (U3): 230.253V

Freq (U3): 50.000Hz

Dmin: 0.10%

Element3: Total (Element1,2,3)

Judgement: Pass

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.048 <span style="color: green;">Pass</span>	
2	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.047 <span style="color: green;">Pass</span>	
3	0.013 <span style="color: green;">Pass</span>	0.101 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.046 <span style="color: green;">Pass</span>	
4	0.009 <span style="color: green;">Pass</span>	0.101 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.045 <span style="color: green;">Pass</span>	
5	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.046 <span style="color: green;">Pass</span>	
6	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.046 <span style="color: green;">Pass</span>	
7	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.046 <span style="color: green;">Pass</span>	
8	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.046 <span style="color: green;">Pass</span>	
9	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.046 <span style="color: green;">Pass</span>	
10	0.020 <span style="color: green;">Pass</span>	0.108 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.046 <span style="color: green;">Pass</span>	
11	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.047 <span style="color: green;">Pass</span>	
12	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.047 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.046 <span style="color: green;">Pass</span>

Update: 3726

Runtime: 7:40:07

51% 10% 2020-06-03 16:06:20

ΣA(3P4W)

U1 600 V  
I1 50 A  
Sync Src: U1  
Integral: Reset

U2 600 V  
I2 50 A  
Sync Src: U1  
Integral: Reset

U3 600 V  
I3 50 A  
Sync Src: U1  
Integral: Reset

Element 4

U4 1000 V  
I4 50 A  
Sync Src: U1  
Integral: Reset

Element 5

U5 1000 V  
I5 5 A  
Sync Src: U1  
Integral: Reset

**IEC 61727:2004**

**100% Pn (Phase A)**

Flicker Mode: Flicker

Range Over

U1	U2	U3	U4	U5	U6	U7
I1	I2	I3	I4	I5	I6	I7

SCL  Line Filter

AVG  Freq Filter

CH: 1 2 3

Count  12/12 Complete

Interval  00:00s/10:00s

Element 1

Volt Range 300 V/50Hz      Element1      Judgement Pass

Un (U1) 230.339V      Total      Judgement Pass

Freq (U1) 50.000Hz      (Element1,2,3)

Dmin 0.10%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	0.103 <span style="color: green;">Pass</span>	0.139 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.058 <span style="color: green;">Pass</span>	
2	0.100 <span style="color: green;">Pass</span>	0.140 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.056 <span style="color: green;">Pass</span>	
3	0.112 <span style="color: green;">Pass</span>	0.141 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.055 <span style="color: green;">Pass</span>	
4	0.103 <span style="color: green;">Pass</span>	0.132 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.054 <span style="color: green;">Pass</span>	
5	0.091 <span style="color: green;">Pass</span>	0.144 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.054 <span style="color: green;">Pass</span>	
6	0.100 <span style="color: green;">Pass</span>	0.168 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.053 <span style="color: green;">Pass</span>	
7	0.096 <span style="color: green;">Pass</span>	0.139 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.052 <span style="color: green;">Pass</span>	
8	0.107 <span style="color: green;">Pass</span>	0.180 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.053 <span style="color: green;">Pass</span>	
9	0.107 <span style="color: green;">Pass</span>	0.173 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.052 <span style="color: green;">Pass</span>	
10	0.127 <span style="color: green;">Pass</span>	0.173 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.052 <span style="color: green;">Pass</span>	
11	0.112 <span style="color: green;">Pass</span>	0.137 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.052 <span style="color: green;">Pass</span>	
12	0.102 <span style="color: green;">Pass</span>	0.155 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.052 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.053 <span style="color: green;">Pass</span>

Update: 3757

Runtime: 4:42:50

38% 10% 2020-06-06 13:24:37

ΣA(3P4W)

U1 300 V  
I1 50 A  
Sync Src: U1  
Integral: Reset

U2 300 V  
I2 50 A  
Sync Src: U1  
Integral: Reset

U3 300 V  
I3 50 A  
Sync Src: U1  
Integral: Reset

Element 4

U4 1000 V  
I4 50 A  
Sync Src: U1  
Integral: Reset

Element 5

U5 1000 V  
I5 5 A  
Sync Src: U1  
Integral: Reset

**100% Pn (Phase B)**

Flicker Mode: Flicker

Range Over

U1	U2	U3	U4	U5	U6	U7
I1	I2	I3	I4	I5	I6	I7

SCL  Line Filter

AVG  Freq Filter

CH: 1 2 3

Count  12/12 Complete

Interval  00:00s/10:00s

Element 2

Volt Range 300 V/50Hz      Element2      Judgement Pass

Un (U2) 230.370V      Total      Judgement Pass

Freq (U2) 50.000Hz      (Element1,2,3)

Dmin 0.10%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	0.014 <span style="color: green;">Pass</span>	0.106 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.135 <span style="color: green;">Pass</span>	
2	0.008 <span style="color: green;">Pass</span>	0.105 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.135 <span style="color: green;">Pass</span>	
3	0.010 <span style="color: green;">Pass</span>	0.110 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.134 <span style="color: green;">Pass</span>	
4	0.005 <span style="color: green;">Pass</span>	0.120 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.135 <span style="color: green;">Pass</span>	
5	0.032 <span style="color: green;">Pass</span>	0.112 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.135 <span style="color: green;">Pass</span>	
6	0.051 <span style="color: green;">Pass</span>	0.152 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.135 <span style="color: green;">Pass</span>	
7	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.134 <span style="color: green;">Pass</span>	
8	0.007 <span style="color: green;">Pass</span>	0.101 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.134 <span style="color: green;">Pass</span>	
9	0.003 <span style="color: green;">Pass</span>	0.109 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.134 <span style="color: green;">Pass</span>	
10	0.008 <span style="color: green;">Pass</span>	0.112 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.135 <span style="color: green;">Pass</span>	
11	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.134 <span style="color: green;">Pass</span>	
12	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.134 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.135 <span style="color: green;">Pass</span>

Update: 3761

Runtime: 4:42:58

38% 10% 2020-06-06 13:24:45

ΣA(3P4W)

U1 300 V  
I1 50 A  
Sync Src: U1  
Integral: Reset

U2 300 V  
I2 50 A  
Sync Src: U1  
Integral: Reset

U3 300 V  
I3 50 A  
Sync Src: U1  
Integral: Reset

Element 4

U4 1000 V  
I4 50 A  
Sync Src: U1  
Integral: Reset

Element 5

U5 1000 V  
I5 5 A  
Sync Src: U1  
Integral: Reset

**IEC 61727:2004**

### 100% Pn (Phase C)

Flicker Mode  
Flicker

Range Over

U1	U2	U3	U4	U5	U6	U7
I1	I2	I3	I4	I5	I6	I7

SCL  Line Filter

AVG  Freq Filter

PA\_00011.tif

CH: 1 2 3

4 5 6 7

Count 12/12 Complete

Interval 00:00s/10:00s

Element 3

Volt Range 300 V/50Hz

Un (U3) 230.422V

Freq (U3) 50.000Hz

Dmin 0.10%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12
No. 1	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.043 <span style="color: green;">Pass</span>	
2	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.042 <span style="color: green;">Pass</span>	
3	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.042 <span style="color: green;">Pass</span>	
4	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.042 <span style="color: green;">Pass</span>	
5	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.041 <span style="color: green;">Pass</span>	
6	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.041 <span style="color: green;">Pass</span>	
7	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.041 <span style="color: green;">Pass</span>	
8	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.042 <span style="color: green;">Pass</span>	
9	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.041 <span style="color: green;">Pass</span>	
10	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.039 <span style="color: green;">Pass</span>	
11	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.040 <span style="color: green;">Pass</span>	
12	0.000 <span style="color: green;">Pass</span>	0.000 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.041 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.041 <span style="color: green;">Pass</span>

Update: 3766

Runtime: 4:43:07

38%  
10%  
2020-06-06  
13:24:54

Σ I<sup>2</sup>(3P4W)

U1 300 V

I1 50 A

Sync Src: U1

Integral: Reset

U2 300 V

I2 50 A

Sync Src: U1

Integral: Reset

U3 300 V

I3 50 A

Sync Src: U1

Integral: Reset

Element 4

U4 1000 V

I4 50 A

Sync Src: U1

Integral: Reset

Element 5


U5 1000 V

I5 5 A



Sync Src: U1

Integral: Reset


**Direct current injection**



**Harmonics and waveform distortion**




**Power factor**




**Under-and over-voltage trip settings and reconnection test**

**50 %Vn ≤ V < 85 %Vn (setting at 195V)**

**Trip Value**




**Disconnection Time**






**50 % ≤ V < 85 % (setting at 155V)**

**Trip Value**




**Disconnection Time**




**50 %Vn ≤ V < 85 %Vn (setting at 117V)**

**Trip Value**




**Disconnection Time**




**$V < 50\%V_n$**


**Trip Value**



**Disconnection Time**




***Under voltage Reconnection***




**110 %Vn < V < 135 %Vn(setting at 255V)**

**Trip value**




**Disconnection Time**




**110 %Vn < V < 135 %Vn(setting at 282V)**

**Trip value**




**Disconnection Time**




**110 %Vn < V < 135 %Vn(setting at 309V)**

**Trip value**




**Disconnection Time**




**135%Vn ≤ V(setting at 312V)**

**Trip value**




**Disconnection Time**







**Over voltage reconnection**




**Over/under frequency trip settings and reconnection test**



**Disconnection time**




***Under frequency reconnection***




IEC 61727:2004

Over frequency

Trip value



Disconnection time



**Over frequency reconnection**

