



**BUREAU  
VERITAS**

# TEST REPORT C10/11

**Specific technical grid-connection guideline for decentralised  
generators with parallel coupling to the public grid**

<b>Report reference number</b> .....	<b>PVBE140508N005</b>
<b>Date of issue</b> .....	2014-07-23
<b>Total number of pages</b> .....	123
<b>Testing laboratory name</b> .....	<b>Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch</b>
<b>Address</b> .....	No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China
	
<b>Applicant's name</b> .....	<b>Shenzhen SOFARSOLAR Co., Ltd.</b>
<b>Address</b> .....	3A-1, Huake Building, East Technology Park, Qiaoxiang Road, Nanshan District, Shenzhen, China.
<b>Test specification</b>	
<b>Standard</b> .....	C10/11 – 2012 DIN VDE0126-1-1:2006-02 DIN VDE V 0124-100:2012-07
<b>Certificate</b> .....	<b>Certificate of compliance</b>
<b>Test report form number</b> .....	C10/11
<b>Master TRF</b> .....	Bureau Veritas Consumer Products Services Germany GmbH
<b>Test item description</b> .....	<b>Grid connected photovoltaic inverter</b>
<b>Trademark</b> .....	
<b>Model / Type</b> .....	SOFAR 1100TL, SOFAR 1600TL, SOFAR 2200TL, SOFAR 2700TL, SOFAR 3000TL

Ratings .....	SOFAR 1100TL	SOFAR 1600TL	SOFAR 2200TL	SOFAR 2700TL	SOFAR 3000TL
MPP DC voltage range [V] .....	110-380	165-380	170-450	210-450	230-450
Input DC voltage range [V] .....	90-400, max.450		100-480, max.500		
Input DC current [A] .....	max.10		max.13		
Output AC voltage [V] .....	230, 50Hz				
Output AC current [A] .....	max.4,5	max.7,0	max.9,5	max.11,5	Max.13,0
Output power [W] .....	1000	1500	2000	2500	2800

**Testing Location** ..... : **Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch**  
**Address** ..... : No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China

**Tested by**  
 (name and signature)..... : James Huang   
**Approved by**  
 (name and signature)..... : Corney Zhang 

**Manufacturer's name**..... : **Shenzhen SOFARSOLAR Co., Ltd.**  
**Factory address** ..... : No. 8, Fulong road, Qingxi town, Dongguan city, Guangdong, China.

Document History			
Date	Internal reference	Modification / Change / Status	Revision
2014-07-23	James Huang	Initial report was written	0
Supplementary information:			

<b>Test items particulars</b>	
Equipment mobility.....	: Permanent connection
Operating condition.....	: Continuous
Class of equipment.....	: Class I
Protection against ingress of water..	: IP65 according to EN 60529
Mass of equipment [kg].....	: SOFAR 1100TL, SOFAR 1600TL, SOFAR 2200TL: 11kg SOFAR 2700TL, SOFAR 3000TL: 12kg
<b>Test case verdicts</b>	
Test case does not apply to the test object.....	: N/A
Test item does meet the requirement.....	: P(ass)
Test item does not meet the requirement.....	: F(ail)
<b>Testing</b>	
Date of receipt of test item.....	: 2014-05-08
Date(s) of performance of test.....	: 2014-05-08 to 2014-07-15
<b>General remarks:</b>	
<p>The test result presented in this report relate only to the object(s) tested.          This report must not be reproduced in part or in full without the written approval of the issuing testing laboratory.</p> <p>"(see Annex #)" refers to additional information appended to the report.          "(see appended table)" refers to a table appended to the report.</p> <p>Throughout this report a comma is used as the decimal separator.</p>	
<b>This Test Report consists of the following documents:</b>	
<ol style="list-style-type: none"> <li>1. Test Report</li> <li>2. Annex No. 1 – EMC Test Report</li> <li>3. Annex No. 2 – Pictures of the unit</li> <li>4. Annex No. 3 – Test equipment list</li> </ol>	

Copy of marking plate


**SOFAR SOLAR**

PV Grid Inverter **SOFAR 1100TL**

Maximum DC input voltage	450V
DC voltage range	90-400V
Maximum DC input current	10A
Maximum PV Isc	12A
Nominal Grid voltage	L/N/PE 230V~
Maximum AC output current	4.5A
Nominal Grid frequency	50Hz
Maximum AC output power	1000W
Power factor	1
Ingress protection	IP65
Operating temperature range	-25-+60°C
Protective class	Class I

Manufacturer: Shenzhen SOFARSOLAR Co., Ltd.  
Made in China

VDE0126-1-1, VDE-AR-N 4105, G83/2, EN50438, C10/11, AS4777, RD1699, UTE C15-712-1




**SOFAR SOLAR**

PV Grid Inverter **SOFAR 1600TL**

Maximum DC input voltage	450V
DC voltage range	90-400V
Maximum DC input current	10A
Maximum PV Isc	12A
Nominal Grid voltage	L/N/PE 230V~
Maximum AC output current	7A
Nominal Grid frequency	50Hz
Maximum AC output power	1500W
Power factor	1
Ingress protection	IP65
Operating temperature range	-25-+60°C
Protective class	Class I

Manufacturer: Shenzhen SOFARSOLAR Co., Ltd.  
Made in China

VDE0126-1-1, VDE-AR-N 4105, G83/2, EN50438, C10/11, AS4777, RD1699, UTE C15-712-1




**SOFAR SOLAR**

PV Grid Inverter **SOFAR 2200TL**

Maximum DC input voltage	500V
DC voltage range	100-480V
Maximum DC input current	13A
Maximum PV Isc	15A
Nominal Grid voltage	L/N/PE 230V~
Maximum AC output current	9.5A
Nominal Grid frequency	50Hz
Maximum AC output power	2000W
Power factor	1
Ingress protection	IP65
Operating temperature range	-25-+60°C
Protective class	Class I

Manufacturer: Shenzhen SOFARSOLAR Co., Ltd.  
Made in China

VDE0126-1-1, VDE-AR-N 4105, G83/2, EN50438, C10/11, AS4777, RD1699, UTE C15-712-1




**SOFAR SOLAR**

PV Grid Inverter **SOFAR 2700TL**

Maximum DC input voltage	500V
DC voltage range	100-480V
Maximum DC input current	13A
Maximum PV Isc	15A
Nominal Grid voltage	L/N/PE 230V~
Maximum AC output current	11.5A
Nominal Grid frequency	50Hz
Maximum AC output power	2500W
Power factor	1
Ingress protection	IP65
Operating temperature range	-25-+60°C
Protective class	Class I

Manufacturer: Shenzhen SOFARSOLAR Co., Ltd.  
Made in China

VDE0126-1-1, VDE-AR-N 4105, G83/2, EN50438, C10/11, AS4777, RD1699, UTE C15-712-1




**SOFAR SOLAR**

PV Grid Inverter **SOFAR 3000TL**

Maximum DC input voltage	500V
DC voltage range	100-480V
Maximum DC input current	13A
Maximum PV Isc	15A
Nominal Grid voltage	L/N/PE 230V~
Maximum AC output current	13A
Nominal Grid frequency	50Hz
Maximum AC output power	2800W
Power factor	1
Ingress protection	IP65
Operating temperature range	-25-+60°C
Protective class	Class I

Manufacturer: Shenzhen SOFARSOLAR Co., Ltd.  
Made in China


VDE0126-1-1, VDE-AR-N 4105, G83/2, EN50438, C10/11, AS4777, RD1699, UTE C15-712-1



### General product information:

The Solar Inverter converts DC voltage into AC voltage.

The input and output are protected by varistors to Earth. The unit is providing EMC filtering at the PV input and output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundantly by the high power switching bridge and two relays. This assures that the opening of the output circuit will also operate in case of a single error.



The internal control is redundant built. It consists of Microcontroller Master DSP (UC34) and Slave DSP (UC35).

The Master DSP control the relays (RYP2-RYP5) by switching signals; measures the PV voltage, PV current, Bus voltage, grid voltage, frequency, AC current with injected DC and the array insulation resistance to ground. In addition it tests the current sensors and the RCMU circuit before each start up.

The Slave DSP (UC35) is measures the grid voltage, AC current, grid frequency and residual current, also can switch off the relays (RYP2-RYP5) independently, and communicate with Master DSP (UC34) each other.

The current is measured by a current sensor. The AC current signal and the injected DC current signal are sent to the Master DSP. The Master DSP tests and calibrates before each start up all current sensors.

The unit provides two relays in series in all output conductors. When single fault applied to one relay, alarm an error code in display panel, another redundant relay provides basic insulation maintained between the PV array and the mains. All the relays are tested before each start up.

The product was tested on:

Hardware version: V1.00

Software version: V1.00

**Description of the differences of the models within a series:**

The models SOFAR 1100TL, SOFAR 1600TL, SOFAR 2200TL, SOFAR 2700TL and SOFAR 3000TL are same as in hardware except the components are in the difference table. Identical in software the output power just adjusted by software.

<b>Difference table</b>					
	SOFAR 1100TL	SOFAR 1600TL	SOFAR 2500TL	SOFAR 2700TL	SOFAR 3000TL
Boost inductor	2,6mH	2,6mH	1,9mH	1,9mH	1,9mH
Resistor (RP105, RP108 /RP189,RP109)	220ohm / 10Kohm	220ohm / 10Kohm	200ohm / 7,5Kohm	200ohm / 7,5Kohm	200ohm / 7,5Kohm
BUS capacitor (ECP1, ECP2, ECP3, ECP4)	2 pcs	2 pcs	3 pcs	3 pcs	3 or 4 pcs
Inverter inductor	3,4mH	2,3mH	2,1mH	1,5mH	1,3mH
Resistor (RP118, RP119, RC18 /RP120, RP121,RC22)	499 Ω, 200 Ω, 200 Ω	1 KΩ, 200 Ω, 100 Ω	1 KΩ, 330 Ω, 330 Ω	2 KΩ, 100 Ω, 100 Ω	2 KΩ, 100 Ω, 100 Ω
DC switch and Wi-Fi module are optional.					

C10/11 – 2012			
Clause/§	Requirement:	Remark:	Verdict
1	<p><b>Scope</b></p> <p>This technical guideline is valid for electrical generators up to a power of 25MVA, connected to the public low-voltage or medium-voltage grid.</p>	1) Noticed, inverter to be connected to the public low-voltage grid	<b>P</b>
2	<b>Grid connection</b>		-
2.1	<p><b>Agreement of the network operator</b></p> <p>Connection to the public grid is allowed in agreement with the network operator. Small generators are out of the official agreement process if:</p> <ul style="list-style-type: none"> <li>- single-phase units <math>\leq 5\text{kVA}_{\text{max}}</math></li> <li>- three-phase units <math>\leq 10\text{kVA}_{\text{max}}</math> and the phase unbalance is limited to 20A</li> <li>- the generator has an integrated automatic disconnection device in accordance with 3.2</li> </ul>		-
2.2	<p><b>General</b></p> <p>The network operator decides about the parallel coupling to the public grid.</p>		-
2.3	<p><b>Power transit</b></p> <p>The maximum acceptable transit power in a connection point is defined by the network operator</p>		-
2.4	<p><b>Type of connection</b></p> <ul style="list-style-type: none"> <li>- <math>&gt; 5\text{kVA}_{\text{max}}</math> must be installed as a multi-phase system and the phase unbalance is limited to 20A</li> <li>- <math>\leq 5\text{kVA}_{\text{max}}</math> can be connected in single- or multi-phase</li> <li>- A grounding of the neutral in the generator is not allowed</li> </ul>	1) Max. single-phase inverter with 2.8kW. N and PE are not bonded.	<b>P</b>
2.4.1	<p><b>Connection to the public low-voltage grid</b></p> <p>The voltage level shall be 230V/400V with or without neutral connection</p>	The inverter is connected to a 230V network, neutral is provided	<b>P</b>
2.4.2	<p><b>Connection to the public medium-voltage grid</b></p> <p>Relevant if a connection without transformer is planned.</p>	Connection to the low-voltage grid	<b>N/A</b>
2.5	<p><b>(n-1)-Situations (only at medium-voltage appliances)</b></p> <p>The power of the de-centralized LV generators shall not exceed the power of the LV/MV transformer</p>	Connection to the low-voltage grid	<b>N/A</b>
2.6	<p><b>Contribution to the short-circuit power</b></p> <p>The short-circuit power of the final installation must be within certain limits</p>	Must be considered at the final installation	<b>N/A</b>
2.7	<p><b>Transformer (only at medium-voltage appliances)</b></p>	Must be considered at the final installation	<b>N/A</b>



<b>2.8</b>	<b>Voltage-level, voltage-control and reactive power</b> - generators $\leq 1\text{MVA}$ : power factor $>0,95$ - generators $>1\text{MVA}$ : generator must be capable of providing a reactive power of $-0,1P_{\text{nom}}$ and $0,33P_{\text{nom}}$ as defined by the network operator	See table below for measurement of power factor	<b>P</b>
<b>2.9</b>	<b>Power fluctuations</b> Abrupt power fluctuations shall not change the voltage-level by more than 3%	Must be considered in the final installation	<b>N/A</b>
<b>2.10</b>	<b>Frequency control</b> In order not to increase frequency instability that might lead to a blackout, the decentralized production plant must be able to change his power injection as a function of mains frequency. In case of frequency higher than the nominal, the decentralized production plant shall adapt its active power injection according to the principles described § 2.13.2.1 and § 2.13.2.2.	See appended test table	<b>P</b>
<b>2.11</b>	<b>Islanding</b> Islanding within an installation is not allowed. Clause 3. of the standard must be considered	Clause 3 considered	<b>P</b>
<b>2.12</b>	<b>Reconnection to the grid</b> Reconnection after islanding is only allowed after a synchro-check, see 3.3.5	Considered	<b>P</b>
<b>2.13</b>	<b>Grid faults</b>		<b>-</b>
<b>2.13.1</b>	<b>Grid voltage</b> The generator shall technically be able to run at a grid tolerance of $\pm 10\%$ of $V_{\text{nom}}$	Considered	<b>P</b>
<b>2.13.2</b>	<b>Grid frequency</b> The generators shall technically be able to run at a grid frequency between 49,0Hz – 51,0Hz and at least for 30 minutes at the frequency bands of 47,5Hz – 49,0Hz and 51,0Hz and 51,5Hz.	See appended test table	<b>P</b>
<b>2.13.2.1</b>	<b>Active power feed-in for overfrequency</b> For a frequency between 50,02Hz – 51,5Hz must the decentralized production plant be able to adapt the active power with a gradient of 40% of the power $P_M$ ( $P_M$ momentary power when the frequency exceeds 50,2Hz).	See appended test table	<b>P</b>
<b>2.13.2.1</b>	<b>Reconnection condition after overfrequency disconnection</b> The reconnection is allowed in band of 47,5Hz - 50,05Hz after at least 60s with a limited rise of maximum 10% active power $P_{a_{\text{max}}}$ of the decentralized production plant per minute.	See appended test table	<b>P</b>

<b>2.13.3</b>	<b>Low voltage ride through</b> Generators >1MVA shall technically be able to ride through low voltages as follows: 85% of $V_{nom}$ for 1,5s 70% of $V_{nom}$ for 0,2s Voltages below 70% shall cause a disconnection	Inverter <1MVA	<b>N/A</b>
<b>2.13.4</b>	<b>Short interruptions on voltage</b> Short interruptions can be caused by automatic switching operations in the grid. Requirements for the generators are defined in item 3. of this standard	Noticed	<b>P</b>
<b>2.14</b>	<b>Flicker</b> Relevant for wind generators	The inverter does not generate flicker	<b>P</b>
<b>2.15</b>	<b>Harmonics</b> Harmonics shall not cause disturbances in the grid	Noticed	<b>P</b>
<b>2.16</b>	<b>Un-symmetric grid load</b> The generator shall not load the grid in an un-symmetric load condition	Considered	<b>P</b>
<b>2.17</b>	<b>Capacitor bench</b> The network operator can require a capacitor bench in the installation	Must be considered in the final installation	<b>N/A</b>
<b>2.18</b>	<b>Remote controlling</b> Remote controlling of the units can be possible via power line communication	Must be considered by the network operator in the final installation	<b>N/A</b>
<b>2.19</b>	<b>Combination of different generators</b> On a multi-phase installation the unbalance shall be not more than 20A. If required by the network operator, mult-generator applications shall have different reconnection times	Must be considered in the final installation	<b>N/A</b>
<b>2.20</b>	<b>Communication</b> Generators >1MVA shall provide a communication interface according to IEC 61850	Inverter <1MVA	<b>N/A</b>
<b>2.21</b>	<b>Energy Metering</b> Not part of this technical guideline		<b>N/A</b>
<b>3</b>	<b>Disconnection and monitoring devices</b>		<b>-</b>
<b>3.1</b>	<b>Block diagram</b>		<b>-</b>
<b>3.2</b>	<b>Disconnection system</b> A disconnection device with insulating function which the distribution network operator can access at any time must be installed. Generators ≤10kVA can have an integrated automatic disconnection device according to Annex 4 of this standard. The requirement of an accessible disconnection device can be waived in this case.	Inverter ≤10kVA with an integrated automatic disconnection device	<b>P</b>
<b>3.3</b>	<b>Grid protection</b>		<b>-</b>

<b>3.3.1</b>	<b>General</b> Disconnection devices, other than defined in clause 3.2, must be tested according to clause 3.3 of this standard. In this context an immediate disconnection shall not exceed 120ms.	Noticed	<b>P</b>
<b>3.3.2</b>	<b>General protection for internal faults</b> Generators must disconnect from the grid in case of internal faults	Noticed	<b>P</b>
<b>3.3.3</b>	<b>Disconnection device</b> The disconnection system shall be fail-safe. A loss of control in the generator shall cause an immediate disconnection. The functionality is tested according to clause 4.2.3 of this standard	Considered	<b>P</b>
<b>3.3.3.1</b>	<b>Connection to the medium-voltage grid</b> General requirements to the disconnection device - frequency relay with immediately disconnection if the frequency range exceeds $47,5\text{Hz} < f < 51,5\text{Hz}$ ; the DNO could ask adjustments in the specific frequency (between 47,5Hz and 51,5Hz), if justified for security reasons - 3phase maximum voltage relay with immediately disconnection if the voltage exceeds a defined value. This value is $< 110\%$ of $V_{nom}$ and is provided by the network operator - 3phase minimum voltage relay with disconnection within 1,5s if the voltage is in the range of 50-85% of $V_{nom}$ - 3phase minimum voltage relay with immediately disconnection if the voltage is in the range of 25-50% of $V_{nom}$ - detection of islanding by implementation of one of the following: vector jump of more than $7^\circ$ or $df/dt$ by 1Hz/s	Inverter for low-voltage connection	<b>N/A</b>
<b>3.3.3.2</b>	<b>Connection to the low-voltage grid</b>		<b>-</b>
<b>3.3.3.2.1</b>	<b>General case</b> - frequency relay with immediately disconnection if the frequency range exceeds $47,5\text{Hz} < f < 51,5\text{Hz}$ ; the DNO could ask adjustments in the specific frequency (between 47,5Hz and 51,5Hz), if justified for security reasons - 1 or 3phase maximum voltage relay with immediately disconnection if the voltage exceeds a defined value. This value is $< 110\%$ of $V_{nom}$ and is provided by the network operator - 3phase minimum voltage relay with disconnection within 1,5s if the voltage is in the range of 50-85% of $V_{nom}$ - 3phase minimum voltage relay with immediately disconnection if the voltage is in the range of 25-50% of $V_{nom}$ - detection of islanding by implementation of one of the following: vector jump of more than $7^\circ$ or $df/dt$ by 1Hz/s	See table below	<b>P</b>
<b>3.3.3.2.2</b>	<b>Generator power <math>\leq 10\text{kVA}</math> and not able to run in islanding-mode</b> Monitoring of maximum and minimum voltage	Only applicable to asynchronous generators without reactive power compensation	<b>N/A</b>
<b>3.3.4</b>	<b>Overview</b>		<b>-</b>


<b>3.3.5</b>	<b>Synchro-check</b> Grid parallel operation is only allowed if a synchronization device is installed. At generators $\leq 10\text{kVA}$ this can be waived	Inverter $< 10\text{kVA}$ with an integrated automatic synchronisation to the grid	<b>P</b>
<b>3.3.6</b>	<b>Voltage detector</b> Used in medium-voltage appliances to avoid a possible asynchronous connection to the grid	Low-voltage appliance	<b>N/A</b>
<b>3.3.7</b>	<b>DC-injection</b> The generator shall not inject more than 1% of its nominal ac-current as a dc-component permanently to the grid. As an alternative a dc-injection monitoring can be implemented which detects the 1% within 200ms and causes a disconnection	See table below	<b>P</b>
<b>3.3.8</b>	<b>Direction-sensitive protection</b>		<b>N/A</b>
<b>3.3.9</b>	<b>Additional protection on the medium-voltage side</b> Can be required by the network operator	Low-voltage appliance	<b>N/A</b>
<b>3.3.10</b>	<b>Other protections</b> The aforementioned protections are the technical minimum requirements. In any case the network operator can request special features	Noticed	<b>P</b>
<b>4</b>	<b>Procedure for the industrial commissioning</b> <i>Not scope of this investigation</i>		-
<b>5</b>	<b>Operation</b> <i>Not scope of this investigation</i>		-
<b>Annex 1</b>	<b>EMC relevant standards</b> EN/IEC 61000-series is applicable	Considered, see Annex No. 1 for EMC reports	<b>P</b>
<b>Annex 2</b>	<b>Voltage plan</b>		<b>N/A</b>
<b>Annex 3</b>	<b>Example wind turbine</b>		<b>N/A</b>
<b>Annex 4</b>	<b>Automatic disconnection facility</b>		<b>P</b>

## Test Results


Power factor			P
<b>SOFAR 1100TL</b>			
Test conditions:	U <sub>DC</sub> =450V U <sub>AC</sub> =230V		
Output power [kW]	~20% 0,56kW	~50% 1,4kW	~100% 2,8kW
Power Factor	0,991	0,998	0,999
<b>SOFAR 3000TL</b>			
Test conditions:	U <sub>DC</sub> =450V U <sub>AC</sub> =230V		
Output power [kW]	~20% 0,56kW	~50% 1,4kW	~100% 2,8kW
Power Factor	0,994	0,999	0,999
<b>Note:</b> The tests had been performed on the SOFAR 1100TL and SOFAR 3000TL are valid for the SOFAR 1600TL, SOFAR 2200TL and SOFAR 2700TL, since it is same as in hardware and just power derated by software.			

Voltage monitoring					P	
Setting values:	Setting U> [V]:		264,5 V			
	Setting T <sub>disconnection</sub> [ms]		40 ms			
	Setting U<[V]:		184,0 V			
	Setting T <sub>disconnection</sub> [ms]		40 ms			
Operating time of the monitoring device:						
	Undervoltage			Overvoltage		
L to N:						
Step [V to V]	230,0 V to 177,1 V			230,0 V to 271,4 V		
Limit [V]:	184,0 V			264,5 V		
Measurement [V]	184,0 V	183,9 V	183,9 V	264,2 V	264,2 V	264,2 V
Limit [ms]:	100 ms			100 ms		
Disconnection time [ms]	56 ms	52 ms	70 ms	60 ms	72 ms	63 ms
<b>Test:</b> The P-N-voltages should be measured for each phase separately.						
<b>Assessment criterion:</b> The permitted tolerance between setting value and trip value of the voltage may not exceed $\pm 1\%$ of $U_n$ .						
<b>Note:</b> The tests had been performed on the SOFAR 3000TL is valid for the SOFAR 1100TL, SOFAR 1600TL, SOFAR 2200TL and SOFAR 2700TL, since it is same as in hardware and just power derated by software.						

### Undervoltage:



### Overvoltage:




<b>Overvoltage protection according to DIN EN 50160:2000-03, 2.3</b>		<b>P</b>
Limit:	From 253V to 264,5V	within 10min
Trip value	257V	8,3min
<p>Note: The tests had been performed on the SOFAR 3000TL is valid for the SOFAR 1100TL, SOFAR 1600TL, SOFAR 2200TL and SOFAR 2700TL, since it is same as in hardware and just power derated by software.</p>		





Frequency monitoring					P	
Setting values:	Setting $f <$ [Hz]:		47,50 Hz			
	Setting $f >$ [Hz]:		51,50 Hz			
	Setting $T_{\text{disconnection}}$ [ms]		40 ms			
Operating time of the monitoring device						
	Under frequency			Over frequency		
Ramp [Hz to Hz]:	48,00 Hz -> 47,00 Hz			51,00 Hz -> 52,00 Hz		
Limit [Hz]:	47,50 Hz			51,50 Hz		
Measurement [Hz]:	47,50 Hz	47,50 Hz	47,50 Hz	51,50 Hz	51,50 Hz	51,50 Hz
Limit [ms]:	100 ms			100 ms		
Disconnection time [ms]:	60 ms	58 ms	58 ms	80 ms	77 ms	74 ms
<b>Test:</b> The measuring is performed at a continuous change of frequency of 1 Hz/s. The trip value was determined manually by reducing the frequency in 10 mHz steps. When the trip value is known (e.g. 47,51 Hz), the grid simulator is programmed to run from e.g. 48,00 Hz to 47,00 Hz with 1 Hz/s. The disconnection time is calculated by the measured time minus the 490 ms from 48,00 Hz to 47,50 Hz.						
<b>Assessment criterion:</b> The setting value and the trip value of the frequency may not vary by more than $\pm 0.1 \% f_n$ .  For frequencies of between 47,5 Hz and 51,5 Hz ( $\pm 0,1 \% f_n$ ) automatic disconnection from the network as a result of a deviation in frequency is not permitted.  <u>Limit values:</u> Frequency decrease protection $f < 47,5 \text{ Hz}$ 100 ms Frequency increase protection $f < 51,5 \text{ Hz}$ 100 ms						
<b>Note:</b> The tests had been performed on the SOFAR 3000TL is valid for the SOFAR 1100TL, SOFAR 1600TL, SOFAR 2200TL and SOFAR 2700TL, since it is same as in hardware and just power derated by software.						

### Underfrequency:




### Overfrequency:




Active power feed-in for overfrequency							
Test cycle for adjustable/conditionally adjustable PGUs							P
<b>Test:</b>							
1-min mean value	a) 50,00 Hz	b) 50,25 Hz	c) 50,70 Hz	d) 51,15 Hz	e) 50,70 Hz	f) 50,25 Hz	g) 50,00 Hz
1. Measurement a) to g): Active power output > 80% P <sub>E<sub>max</sub></sub>							
Frequency [Hz]:	50,00	50,25	50,70	51,15	50,70	50,25	50,00
P <sub>setpoint</sub> [kW]:	N/A	2,747	2,243	1,738	2,243	2,747	N/A
P <sub>E60</sub> [kW]:	2,803	2,761	2,262	1,761	2,262	2,762	2,790
ΔP <sub>E60</sub> /P <sub>Setpoint</sub> [%]:	N/A	0,50	0,68	0,80	0,69	0,51	N/A
2. Measurement a) to g): Active power output 40% and 60% after freezing > 80% P <sub>E<sub>max</sub></sub>							
Frequency [Hz]:	50,00	50,25	50,70	51,15	50,70	50,25	N/A
P <sub>setpoint</sub> [kW]:	N/A	1,393	1,137	0,881	1,137	1,393	N/A
P <sub>E60</sub> [kW]:	1,421	1,415	1,158	0,903	1,157	1,411	N/A
ΔP <sub>E60</sub> /P <sub>Setpoint</sub> [%]:	N/A	0,81	0,73	0,78	0,73	0,65	N/A
Limit ΔP <sub>E60</sub> /P <sub>Setpoint</sub> :	+ 10 % of P <sub>E<sub>max</sub></sub>						
<b>Graph of Measurement 1.: Active power output &gt; 80% P<sub>E<sub>max</sub></sub></b>							
							

**Graph of Measurement 2.:Active power output 40% and 60% after freezing > 80% P<sub>E</sub>max**



**Graph of power gradient:**



**Test:**

The test is conducted for two powers. First, the test must start at a power  $> 80\% P_{E_{max}}$  ("Measurement 1"), and in a second test, for a power between  $40\%$  to  $60\% P_{E_{max}}$  ("Measurement 2"). In the second test, after freezing of the PM, the available active power output must be increased to a value  $> 80\% P_{E_{max}}$ , and after the network frequency of  $50,2$  Hz is fallen below, the rise of the active power gradient must be recorded.

Point g) must be held until the PGU is again feeding in with the active power output available.

**Assessment criterion:**

For  $f=50,2$  Hz, the value of the PM active power currently being generated is "frozen".

a) For adjustable PGUs when:

- 1) in case of decreasing frequency the active power is reduced (or raised for a later frequency decrease) with a gradient of  $40\%$  PM per Hz between measuring points b) and f), as seen in the graphs above
- 2) the maximum active power gradient occurring in point g) is lower than  $10\%$  of maximum active power  $P_{E_{max}}$  every minute, and
- 3) the reaction value of the setpoint determined by the gradient characteristic curve does not differ from  $P_{E_{max}}$  by more than  $\pm 10\%$ .

b) For conditionally adjustable PGUs

- 1) when they behave as in a) within their adjustment range, and
- 2) when, outside the adjustable range, the power fed in on leaving the adjustment range remains constant until shutdown. Shutdown must occur before  $51,5$  Hz are reached.


The PGU has to disconnect from the network before  $100$  ms after frequency h) is reached.

**Note:**


The tests had been performed on the SOFAR 3000TL is valid for the SOFAR 1100TL, SOFAR 1600TL, SOFAR 2200TL and SOFAR 2700TL, since it is same as in hardware and just power derated by software.


Reconnection condition after disconnection			P
Setting values:	Setting $T_{\text{reconnection } 60\text{s}}$ [s]:	60 s	
	Setting $f <$ [Hz]:	47,5 Hz	
	Setting $f >$ [Hz]:	51,5 Hz	
<b>Test:</b>			
	$f_{\text{ist}}$	Reset time:	Limit:
<b>Connecting conditions for frequencies:</b>			
a)	47,45 Hz	No reconnection	No resetting allowed
	Switch to:		
b)	$\geq 47,55$ Hz	74 s	$\geq 60$ s
c)	50,06 Hz	No reconnection	No resetting allowed
	Switch to:		
d)	$\geq 50,0$ Hz	74 s	$\geq 60$ s
<b>Test:</b> see points a) to h) for the test process. The measurement was carried out with a programmable AC source. e.g. connecting conditions for frequencies: Point a) and b). The AC source was programmed in such a way that the first step of 230 V / 50 Hz to 200 V / 47,0 Hz resulted in a faulty disconnection. Thereafter the voltage and frequency for 100 s is set to 215 V / 47,45 Hz. Switching on again is not permitted. After a lapse of 100 s the voltage is set to 230 V / 47,55 Hz. Setting again after 60 s is permitted.			
<b>Assessment criterion:</b> After the NS protection has tripped the system shall only reconnect after 60s within the tolerance bands of voltage ( $(80\% U_n \leq U \leq 110\% U_n)$ ) and frequency ( $47,5 \text{ Hz} \leq f \leq 50,05\text{Hz}$ ) have been exceeded.			
<b>Note:</b> The tests had been performed on the SOFAR 3000TL is valid for the SOFAR 1100TL, SOFAR 1600TL, SOFAR 2200TL and SOFAR 2700TL, since it is same as in hardware and just power derated by software.			

**a) 47,50 Hz to b)  $\geq 47,55$  Hz:**



**c) 50,10 Hz to d)  $\leq 50,00$  Hz:**











Diagram for permanent DC-Injection:



**Note:**

Testing must be performed according to WI 10.4.-03.doc rev D. The internal temperature of the EUT must be stabilized. No temperature drift of more than 2K within 1 hour is allowed. The tests had been performed on the SOFAR 3000TL is valid for the SOFAR 1100TL, SOFAR 1600TL, SOFAR 2200TL and SOFAR 2700TL, since it is same as in hardware and just power derated by software.

Detection of Anti-Islanding		P	
<b>Test conditions:</b>	Frequency: 50+/-0,2Hz $U_N=230\pm 3V_{ac}$ RLC consumes inverter real power within +/- 3% Distortion factor of chokes < 3%		
Disconnection limit:	5s		
Output power:	25%	50%	100%
Osc. Parameter			
- 5%	0,158	0,204	0,180
- 4%	0,146	0,128	0,071
- 3%	0,202	0,108	0,104
- 2%	0,235	0,384	0,391
- 1%	0,420	0,394	0,452
0 %	0,489	0,378	0,468
+1 %	0,422	0,431	0,485
+2 %	0,130	0,115	0,109
+3 %	0,190	0,202	0,111
+4 %	0,167	0,203	0,140
+5 %	0,170	0,048	0,100
Parameter at 0%	L=120,02 mH R=76,12 $\Omega$ C=84,66 $\mu F$	L=59,48 mH R=37,84 $\Omega$ C=169,75 $\mu F$	L=29,87 mH R=18,93 $\Omega$ C=338,59 $\mu F$
<b>Note:</b> In accordance with DIN V VDE V 0126-1-1:2006-02  The tests had been performed on the SOFAR 3000TL is valid for the SOFAR 1100TL, SOFAR 1600TL, SOFAR 2200TL and SOFAR 2700TL, since it is same as in hardware and just power derated by software.			


### 25% Power



### 50% Power



### 100% Power



# Annex 1

## EMC Test Report



## ATTESTATION of conformity with European Directives

Attestation Number: 1488AB0508N005R1001  
Product: PV Grid Inverter  
Brand Name:   
Model: SOFAR 3000TL, SOFAR 1100TL, SOFAR 2200TL  
Additional Model: SOFAR 1600TL, SOFAR 2700TL  
Applicant: Shenzhen SOFARSOLAR Co., Ltd.  
Address: 3A-1, Huake Building, East Technology Park, Qiaoxiang Road, Nanshan District, Shenzhen, China.  
Technical Characteristics: DC Input: DC 110 - 380V Max. 10A For SOFAR 1100TL;  
DC Input: DC 165 - 380V Max. 10A For SOFAR 1600TL ;  
DC Input: DC 170 - 450V Max. 13A For SOFAR 2200TL;  
DC Input: DC 210 - 450V Max. 13A For SOFAR 2700TL;  
DC Input: DC 230 - 450V Max. 13A For SOFAR 3000TL  
Output: AC 230V, 50/60Hz, Power: 1000W / 1500W / 2000W / 2500W / 2800W  
Output Voltage/Current: SOFAR 1100TL:230V/4.5A; SOFAR 1600TL:230V/7.0A;  
SOFAR 2200TL:230V/9.5A; SOFAR 2700TL:230V/11.5A; SOFAR 3000TL:230V/13.0A

The submitted sample of the above equipment has been tested for CE marking according to following European Directive and standards:

- Electromagnetic Compatibility Directive 2004/108/EC


Standards	Report Number	Report date
EN 61000-6-3:2007 + A1:2011 EN 61000-3-2:2006 + A1 :2009 + A2:2009 EN 61000-3-3:2013 EN 61000-6-2:2005	CE140508N005R1	Jul. 21, 2014

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive.

This verification does not imply assessment of the production of the product. The CE marking may be affixed if all relevant and effective European Directives with CE are applicable.



Supervisor  
EMC Department



Name: Madison Luo  
Date: Jul. 21, 2014

This document shall not be reproduced, except in full, without the written approval of  
Bureau Veritas Shenzhen Co., Ltd.

Information given in this document is related to the tested specimen of the described electrical sample.

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd.,  
Houjie Town, Dongguan City,  
Guangdong 523942, China

Tel.: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

## TEST REPORT

Applicant	Shenzhen SOFARSOLAR Co., Ltd.	
Address	3A-1, Huake Building, East Technology Park, Qiaoxiang Road, Nanshan District, Shenzhen, China.	
Manufacturer or Supplier	Shenzhen SOFARSOLAR Co., Ltd.	
Address	3A-1, Huake Building, East Technology Park, Qiaoxiang Road, Nanshan District, Shenzhen, China.	
Product	PV grid-interactive inverter	
Brand Name		
Model	SOFAR 3000TL, SOFAR 1100TL, SOFAR 2200TL	
Additional Model & Model Difference	SOFAR 1600TL, SOFAR 2700TL See item 2.1	
Date of tests	May 08, 2014 ~ Jun. 30, 2014	
<p>The submitted sample of the above equipment has been tested for according to following European Directive - Electromagnetic directive 2004/108/EC and the tests have been carried out according to the requirements of the following standards:</p>		
<input checked="" type="checkbox"/> EN 61000-6-3:2007 + A1:2011 <input checked="" type="checkbox"/> EN 61000-3-2:2006 + A1:2009 + A2:2009 <input checked="" type="checkbox"/> EN 61000-3-3:2013 <input checked="" type="checkbox"/> EN 61000-6-2:2005		
<p><b>CONCLUSION: The submitted sample was found to <u>COMPLY</u> with the test requirement</b></p>		
<p>Tested by Breeze Jiang Project Engineer / EMC Department</p>		<p>Approved by Madison Luo Manager / EMC Department</p>
		
<p>Date: Jul. 21, 2014</p>		
<p><small>This report is for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. The results set forth in this report are not indicative or representative of the quality or characteristics of the lot from which a test sample was taken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. You have 60 days from date of issuance of this report to notify us of any material error or omission caused by our negligence, provided, however, that such notice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise such issue within the prescribed time shall constitute your unqualified acceptance of the completeness of this report, the tests conducted and the correctness of the report contents. Unless specific mention, the uncertainty of measurement has been explicitly taken into account to declare the compliance or non-compliance to the specification</small></p>		

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China

Tel: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

## Table of Contents

RELEASE CONTROL RECORD .....	5
1 SUMMARY OF TEST RESULTS .....	6
1.1 MEASUREMENT UNCERTAINTY .....	8
2 GENERAL INFORMATION .....	9
2.1 GENERAL DESCRIPTION OF EUT .....	9
2.2 DESCRIPTION OF TEST MODES .....	11
2.3 GENERAL DESCRIPTION OF APPLIED STANDARDS .....	12
2.4 DESCRIPTION OF SUPPORT UNITS .....	12
3 EMISSION TEST .....	13
3.1 CONDUCTED EMISSION MEASUREMENT .....	13
3.1.1 LIMITS OF CONDUCTED EMISSION MEASUREMENT .....	13
3.1.2 TEST INSTRUMENTS .....	13
3.1.3 TEST PROCEDURE .....	14
3.1.4 DEVIATION FROM TEST STANDARD .....	14
3.1.5 TEST SETUP .....	15
3.1.6 EUT OPERATING CONDITIONS .....	15
3.1.7 TEST RESULTS .....	16
3.2 RADIATED EMISSION MEASUREMENT .....	18
3.2.1 LIMITS OF RADIATED EMISSION MEASUREMENT .....	18
3.2.2 TEST INSTRUMENTS .....	19
3.2.3 TEST PROCEDURE .....	20
3.2.4 DEVIATION FROM TEST STANDARD .....	21
3.2.5 TEST SETUP .....	22
3.2.6 EUT OPERATING CONDITIONS .....	22
3.2.7 TEST RESULTS .....	23
3.3 HARMONICS CURRENT MEASUREMENT (<16A) .....	25
3.3.1 LIMITS OF HARMONICS CURRENT MEASUREMENT .....	25
3.3.2 TEST INSTRUMENTS .....	26
3.3.3 TEST PROCEDURE .....	26
3.3.4 DEVIATION FROM TEST STANDARD .....	27
3.3.5 TEST SETUP .....	27
3.3.6 EUT OPERATING CONDITIONS .....	27
3.3.7 TEST RESULTS .....	28
3.4 VOLTAGE FLUCTUATION AND FLICKS MEASUREMENT .....	32
3.4.1 LIMITS OF VOLTAGE FLUCTUATION AND FLICKS MEASUREMENT .....	32
3.4.2 TEST INSTRUMENTS .....	32
3.4.3 TEST PROCEDURE .....	32
3.4.4 DEVIATION FROM TEST STANDARD .....	33
3.4.5 TEST SETUP .....	33
3.4.6 EUT OPERATING CONDITIONS .....	33
3.4.7 TEST RESULTS .....	34
4 IMMUNITY TEST .....	36
4.1 GENERAL DESCRIPTION .....	36





4.1.1	GENERAL DESCRIPTION OF EN 61000-6-2	36
4.1.2	PERFORMANCE CRITERIA	37
4.1.3	EUT OPERATING CONDITION	37
4.2	ELECTROSTATIC DISCHARGE IMMUNITY TEST (ESD)	38
4.2.1	TEST SPECIFICATION	38
4.2.2	TEST INSTRUMENTS	38
4.2.3	TEST PROCEDURE	39
4.2.4	DEVIATION FROM TEST STANDARD	39
4.2.5	TEST SETUP	40
4.2.6	TEST RESULTS	41
4.3	RADIATED, RADIO-FREQUENCY, ELECTROMAGNETIC FIELD IMMUNITY TEST (RS)	42
4.3.1	TEST SPECIFICATION	42
4.3.2	TEST INSTRUMENTS	42
4.3.3	TEST PROCEDURE	43
4.3.4	DEVIATION FROM TEST STANDARD	43
4.3.5	TEST SETUP	44
4.3.6	TEST RESULTS	45
4.4	ELECTRICAL FAST TRANSIENT/BURST IMMUNITY TEST (EFT)	46
4.4.1	TEST SPECIFICATION	46
4.4.2	TEST INSTRUMENTS	46
4.4.3	TEST PROCEDURE	46
4.4.4	DEVIATION FROM TEST STANDARD	46
4.4.5	TEST SETUP	47
4.4.6	TEST RESULTS	48
4.5	SURGE IMMUNITY TEST	49
4.5.1	TEST SPECIFICATION	49
4.5.2	TEST INSTRUMENTS	49
4.5.3	TEST PROCEDURE	50
4.5.4	DEVIATION FROM TEST STANDARD	50
4.5.5	TEST SETUP	50
4.5.6	TEST RESULTS	51
4.6	IMMUNITY TO CONDUCTED DISTURBANCES INDUCED BY RF FIELDS (CS)	52
4.6.1	TEST SPECIFICATION	52
4.6.2	TEST INSTRUMENTS	52
4.6.3	TEST PROCEDURE	53
4.6.4	DEVIATION FROM TEST STANDARD	53
4.6.5	TEST SETUP	54
4.6.6	TEST RESULTS	55
4.7	POWER FREQUENCY MAGNETIC FIELD IMMUNITY TEST	56
4.7.1	TEST SPECIFICATION	56
4.7.2	TEST INSTRUMENTS	56
4.7.3	TEST PROCEDURE	56
4.7.4	DEVIATION FROM TEST STANDARD	56
4.7.5	TEST SETUP	57
4.7.6	TEST RESULTS	58
5	PHOTOGRAPHS OF THE TEST CONFIGURATION	59

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China

Tel: +86 769 8593 5858  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)



Test Report No.: CE140508N005R1

6	APPENDIX A – MODIFICATIONS RECORDERS FOR ENGINEERING CHANGES TO THE EUT BY THE LAB .....	66
---	---	----

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China

Tel: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd.,  
Houjie Town, Dongguan City, Guangdong  
523942, China

Tel: +86 769 8593 5656  
Fax: +86 769 8599 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)  
TEST REPORT C11/C10 VER.0



Test Report No.: CE140508N005R1

### RELEASE CONTROL RECORD

ISSUE NO.	REASON FOR CHANGE	DATE ISSUED
CE140508N005	Original release	Jul. 10, 2014
CE140508N005R1	Based on the original report CE140508N005 change power supply information, model and technical characteristics.	Jul. 21, 2014

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China

Tel: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd.,  
Houjie Town, Dongguan City, Guangdong  
523942, China

Tel: +86 769 8593 5656  
Fax: +86 769 8599 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

## 1 SUMMARY OF TEST RESULTS

The EUT has been tested according to the following specifications:

EMISSION			
Standard	Test Type	Result	Remarks
EN61000-6-3:2007+ A1:2011	Conducted test	PASS	Meets requirement limit Minimum passing margin is -3.00 dB at 0.36094MHz
	Radiated test (30MHz~1GHz)	PASS	Meets limits minimum passing margin is -5.08 dB at 191.02MHz
EN 61000-3-2:2006 + A1:2009 + A2:2009	Harmonic current emissions	PASS	Meets the requirements.
EN 61000-3-3:2013	Voltage fluctuations & flicker	PASS	Meets the requirements.

IMMUNITY (EN 61000-6-2:2005)			
Standard	Test Type	Result	Remarks
IEC 61000-4-2:2008	Electrostatic discharge immunity test	PASS	Electrostatic Discharge – ESD: 8kV Air discharge, 4kV Contact discharge, Performance Criterion A
IEC 61000-4-3:2005 + A1:2007+A2:2010	Radiated, radio-frequency, electromagnetic field immunity test	PASS	Radio-Frequency Electromagnetic Field Susceptibility Test – RS: 80-1000 MHz, 10V/m, 80% AM (1kHz), 1400-2000 MHz, 3V/m, 80% AM (1kHz) 2000-2700 MHz, 1V/m, 80% AM (1kHz) Performance Criterion A
IEC 61000-4-4:2012	Electrical fast transient / burst immunity test.	PASS	Electrical Fast Transient/Burst - EFT AC Power line: 2kV, DC Power line: 2kV, Performance Criterion A
IEC 61000-4-5:2005	Surge immunity test	PASS	Surge Immunity Test: 1.2/50 us Open Circuit Voltage, 8 /20 us Short Circuit Current, AC Power Line: line to line 1 kV, Line to earth 2kV , DC Power Line: line to line 0.5 kV Performance Criterion B
IEC 61000-4-6:2008	Immunity to conducted disturbances, induced by radio-frequency fields	PASS	Conducted Radio Frequency Disturbances Test – CS: 0.15-80 MHz, 10Vrms, 80% AM, 1kHz, Performance Criterion A
IEC 61000-4-8:2009	Power frequency magnetic field immunity test.	PASS	Power Frequency Magnetic Field Test, 50 Hz / 60Hz, 30A/m, Performance Criterion A



## 1.1 MEASUREMENT UNCERTAINTY

Where relevant, the following measurement uncertainty levels have been estimated for tests performed on the EUT as specified in CISPR 16-4-2:

This uncertainty represents an expanded uncertainty expressed at approximately the 95% confidence level using a coverage factor of  $k=2$ .

MEASUREMENT	FREQUENCY	UNCERTAINTY
Mains Terminal Disturbance Voltage Test	0.15MHz ~ 30MHz	+ /-2.67 dB
Radiated Disturbance Test	30MHz ~ 1000MHz	+ /-4.36 dB



**BUREAU  
VERITAS** Test Report No.: CE140508N005R1

## 2 GENERAL INFORMATION

### 2.1 GENERAL DESCRIPTION OF EUT

<b>PRODUCT</b>	PV Grid Inverter
<b>MODEL NO.</b>	SOFAR 3000TL, SOFAR 1100TL, SOFAR 2200TL
<b>ADDITIONAL MODEL</b>	SOFAR 1600TL, SOFAR 2700TL
<b>POWER SUPPLY</b>	DC Input: DC 110 - 380V Max. 10A For SOFAR 1100TL; DC Input: DC 165 - 380V Max. 10A For SOFAR 1600TL ; DC Input: DC 170 - 450V Max. 13A For SOFAR 2200TL; DC Input: DC 210 - 450V Max. 13A For SOFAR 2700TL; DC Input: DC 230 - 450V Max. 13A For SOFAR 3000TL Output: AC 230V, 50/60Hz, Power: 1000W / 1500W / 2000W / 2500W / 2800W Output Voltage/Current: SOFAR 1100TL:230V/4.5A; SOFAR 1600TL:230V/7.0A; SOFAR 2200TL:230V/9.5A; SOFAR 2700TL:230V/11.5A; SOFAR 3000TL:230V/13.0A
<b>SOFTWARE VERSION</b>	V1.00
<b>HARDWARE VERSION</b>	V1.00
<b>THE HIGHEST OPERATING FREQUENCY</b>	Below 108MHz
<b>DATA CABLE SUPPLIED</b>	DC Cable: Shielded; Detachable 1.8m; AC Cable: Shielded; Detachable 1.8m

#### NOTE:

1. This report CE140508N005R1 supersedes the previous one with the report number CE140508N005 dated on Jul. 10, 2014.
2. For the test results, the EUT had been tested with all conditions. But only the worst case was showed in test report.
3. For a more detailed features description, please refer to the manufacturer's specifications or the User's Manual.
4. RS485 port on the product is for client to collect data, according to client requirements, no need to test.
5. All models shell include red, blue, white and other colors. All models of DC switch and WIFI module is optional accessories, optional installation according to the need of client.

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China

Tel: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

Page 9 of 66

Report Version 1

6. This is a series of PV Grid Inverter with the same as in hardware except the amount of BUS capacitor, inverter inductor, Boost and IGBT component and DC switch are different. Identical in software the output power just adjusted by software; models SOFAR 3000TL, SOFAR 1100TL, SOFAR 2200TL are selected to test. full test was performed for the model SOFAR 3000TL, and partial test for the models SOFAR 1100TL, SOFAR 2200TL.

Ratings .....	SOFAR 1100TL	SOFAR 1600TL	SOFAR 2200TL	SOFAR 2700TL	SOFAR 3000TL
MPP DC voltage range [V] .....	110-380	165-380	170-450	210-450	230-450
Input DC voltage range [V] .....	90-400, max. 450		100-480, max. 500		
Input DC current [A] .....	10		13		
Output AC voltage [V] .....	230V, 50Hz				
Output AC current [A] .....	4,5	7,0	9,5	11,5	13,0
Output power [W] .....	1000	1500	2000	2500	2800

7. Model Difference:

Difference:	SOFAR 3000TL	SOFAR 2700TL	SOFAR 2200TL	SOFAR 1600TL	SOFAR 1100TL
Boost inductor	1.9mH	1.9mH	1.9mH	2.6mH	2.6mH
Input sampling resistor (RP105,RP108 /RP189,RP109)	200ohm / 7.5Kohm	200ohm / 7.5Kohm	200ohm / 7.5Kohm	220ohm / 10Kohm	220ohm / 10Kohm
Bus capacitor	3pcs	3pcs	3pcs	2pcs	2pcs
Inverter inductor	1.3mH	1.5mH	2.1mH	2.3mH	3.4mH
Output sampling resistor (RP118, RP119, RC18 /RP120, RP121,RC22)	2Kohm,100ohm,100ohm	2Kohm,100ohm,100ohm	1.0Kohm,330ohm,330ohm	1.0Kohm,200ohm,100ohm	499ohm,200ohm,200ohm



## 2.2 DESCRIPTION OF TEST MODES

The EUT was tested under the following modes' the final worst mode were marked in boldface and recorded in this report.

◆ For Conducted Emission Test

Test Mode	TEST VOLTAGE	Model
Full Load	DC 380V	SOFAR 2200TL
Full Load	DC 380V	SOFAR 1100TL
Full Load	DC 230V	<b>SOFAR 3000TL</b>
<b>Full Load</b>	<b>DC 360V</b>	
Full Load	DC 450V	

◆ For Radiated Emission Test

Test Mode	TEST VOLTAGE	Model
Full Load	DC 380V	SOFAR 2200TL
Full Load	DC 380V	SOFAR 1100TL
Full Load	DC 230V	<b>SOFAR 3000TL</b>
<b>Full Load</b>	<b>DC 360V</b>	
Full Load	DC 450V	

◆ For Harmonics and Flicker Tests

Test Mode	TEST VOLTAGE	Model
Full Load	DC 380V	<b>SOFAR 1100TL</b>
Full Load	DC 380V	<b>SOFAR 3000TL</b>

◆ For Immunity Test

Test Mode	TEST VOLTAGE	Model
10% Load	DC 300V	<b>SOFAR 3000TL</b>



Test Report No.: CE140508N005R1

### 2.3 GENERAL DESCRIPTION OF APPLIED STANDARDS

The EUT has been tested and complied with the requirements of the following standards:

EN 61000-6-3:2007 + A1:2011  
 EN 61000-3-2:2006 + A1:2009 + A2:2009  
 EN 61000-3-3:2013  
 EN 61000-6-2:2005  
 IEC 61000-4-2:2008  
 IEC 61000-4-3:2005 + A1:2007 + A2:2010  
 IEC 61000-4-4:2012  
 IEC 61000-4-5:2005  
 IEC 61000-4-6:2008  
 IEC 61000-4-8:2009

Notes: The above IEC basic standards are applied with latest version if customer has no special requirement

### 2.4 DESCRIPTION OF SUPPORT UNITS

The EUT has been tested as an independent unit together with other necessary accessories or support units. The following support units or accessories were used to form a representative test configuration during the tests.

NO.	PRODUCT	BRAND	MODEL NO.	SERIAL NO.	FCC ID
1	DC Source	Chroma	62150H-1000S	62150EF00488	N/A

NO.	SIGNAL CABLE DESCRIPTION OF THE ABOVE SUPPORT UNITS
1	AC Line: Unshielded, Detachable 2.0m, DC Line: Unshielded, Detachable 2.0m;

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China

Tel: +86 769 8593 5656  
 Fax: +86 769 8593 1080  
 Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

Page 12 of 86

Report Version 1



### 3 EMISSION TEST

#### 3.1 CONDUCTED EMISSION MEASUREMENT

##### 3.1.1 LIMITS OF CONDUCTED EMISSION MEASUREMENT

FREQUENCY (MHz)	Class A (dBuV)		Class B (dBuV)	
	Quasi-peak	Average	Quasi-peak	Average
0.15 - 0.5	79	66	66 - 56	56 - 46
0.50 - 5.0	73	60	56	46
5.0 - 30.0	73	60	60	50

- Note:**
- (1) The lower limit shall apply at the transition frequencies.
  - (2) The limit decreases in line with the logarithm of the frequency in the range of 0.15 to 0.50 MHz.
  - (3) All emanations from a class A/B digital device or system, including any network of conductors and apparatus connected thereto, shall not exceed the level of field strengths specified above.

##### 3.1.2 TEST INSTRUMENTS

Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Next Cal.
EMI Test Receiver	Rohde&Schwarz	ESCS30	100199	May 17,14	May 16,15
Pulse Limiter	Rohde&Schwarz	ESH3-Z2	100168	Oct. 12,13	Oct. 11,14
Artificial Mains Network	Rohde&Schwarz	ESH2-Z5	100071	May 13,14	May 12,15
Test software	ADT	ADT_Cond_V7.3.7	N/A	N/A	N/A

- NOTE:**
1. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to CEPREI/CHINA, GRGT/CHINA and NIM/CHINA.
  2. The test was performed in shielding room 843.




### 3.1.3 TEST PROCEDURE

- a. The EUT was placed 0.4 meters from the conducting wall of the shielded room with EUT being connected to the power mains through a line impedance stabilization network (LISN). Other support units were connected to the power mains through another LISN. The two LISNs provide 50 Ohm/ 50uH of coupling impedance for the measuring instrument.
- b. Both lines of the power mains connected to the EUT were checked for maximum conducted interference.
- c. The frequency range from 150 kHz to 30 MHz was searched. Emission levels under (Limit – 20dB) were not recorded.

### 3.1.4 DEVIATION FROM TEST STANDARD

No deviation

### 3.1.5 TEST SETUP



- Note:**
1. Support units were connected to second LISN.
  2. Both of LISNs (AMN) are 80cm from EUT and at least 80cm from other units and other metal planes support units.

### 3.1.6 EUT OPERATING CONDITIONS


- a. Turned on the power of all equipment.
- b. EUT was operated according to the type description in manufacturer's specifications or the User's Manual.

### 3.1.7 TEST RESULTS

TEST MODE	SOFAR 3000TL	6dB BANDWIDTH	9 kHz
	Grid Mode		
TEST VOLTAGE	DC 360V	PHASE	Line (L)
ENVIRONMENTAL CONDITIONS	23 deg. C, 42% RH	TESTED BY: Heise	

No	Freq. [MHz]	Corr. Factor (dB)	Reading Value		Emission Level		Limit		Margin	
			[dB (uV)]		[dB (uV)]		[dB (uV)]		(dB)	
			Q.P.	AV.	Q.P.	AV.	Q.P.	AV.	Q.P.	AV.
1	0.16172	5.20	48.57	45.49	53.77	50.69	65.38	55.38	-11.60	-4.68
2	0.27891	9.16	40.76	37.52	49.92	46.68	60.85	50.85	-10.93	-4.17
3	0.31797	9.23	39.58	36.34	48.81	45.57	59.76	49.76	-10.95	-4.19
4	0.36094	9.32	39.63	36.39	48.95	45.71	58.71	48.71	-9.76	-3.00
5	0.43906	9.47	36.61	34.20	46.08	43.67	57.08	47.08	-11.00	-3.41
6	4.25000	10.01	32.52	25.58	42.53	35.59	56.00	46.00	-13.47	-10.41


REMARKS: The emission levels of other frequencies were very low against the limit.



<b>TEST MODE</b>	SOFAR 3000TL Grid Mode	<b>6dB BANDWIDTH</b>	9 kHz
<b>TEST VOLTAGE</b>	DC 360V	<b>PHASE</b>	Neutral (N)
<b>ENVIRONMENTAL CONDITIONS</b>	23 deg. C, 42% RH	<b>TESTED BY:</b> Heise	

No	Freq. [MHz]	Corr. Factor (dB)	Reading Value		Emission Level		Limit		Margin	
			[dB (uV)]		[dB (uV)]		[dB (uV)]		(dB)	
			Q.P.	AV.	Q.P.	AV.	Q.P.	AV.	Q.P.	AV.
1	0.15781	4.85	47.50	43.90	52.35	48.75	65.58	55.58	-13.22	-6.82
2	0.28281	9.19	39.88	36.67	49.07	45.86	60.73	50.73	-11.67	-4.88
3	0.37656	9.35	38.15	35.11	47.50	44.46	58.35	48.35	-10.85	-3.89
4	0.43906	9.46	36.24	33.89	45.70	43.35	57.08	47.08	-11.38	-3.73
5	0.48203	9.54	35.42	33.03	44.96	42.57	56.30	46.30	-11.35	-3.74
6	4.22266	10.05	33.58	25.62	43.63	35.67	56.00	46.00	-12.37	-10.33

REMARKS: The emission levels of other frequencies were very low against the limit.





**BUREAU VERITAS** Test Report No.: CE140508N005R1

### 3.2 RADIATED EMISSION MEASUREMENT

#### 3.2.1 LIMITS OF RADIATED EMISSION MEASUREMENT

**TEST STANDARD: EN 61000-6-3  
FOR FREQUENCY BELOW 1000 MHz**

FREQUENCY (MHz)	Class A (at 10m)	Class B (at 10m)
	dBuV/m	dBuV/m
30 – 230	40	30
230 – 1000	47	37

#### FREQUENCY RANGE OF RADIATED MEASUREMENT (For unintentional radiators)

Highest frequency generated or Upper frequency of measurement used in the device or on which the device operates or tunes (MHz)	Range (MHz)
Below 108	1000
108 – 500	2000
500 – 1000	5000
Above 1000	Up to 5 times of the highest frequency or 6 GHz, whichever is less

#### FOR FREQUENCY ABOVE 1000 MHz

FREQUENCY (GHz)	Class A (dBuV/m) (at 3m)		Class B (dBuV/m) (at 3m)	
	PEAK	AVERAGE	PEAK	AVERAGE
1 to 3	76	56	70	50
3 to 6	80	60	74	54

- NOTE:** (1) The lower limit shall apply at the transition frequencies.  
 (2) Emission level (dBuV/m) = 20 log Emission level (uV/m).  
 (3) All emanation from a class A/B digital device or system, including any network of conductors and apparatus connected thereto, shall not exceed the level of field strengths specified above.

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China

Tel: +86 769 8593 5656  
 Fax: +86 769 8593 1080  
 Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)





### 3.2.2 TEST INSTRUMENTS

#### Frequency Range 30MHz-1GHz

Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Next Cal.
EMI Test Receiver	Rohde&Schwarz	ESCI	100962	Mar. 06, 14	Mar. 05, 15
Bilog Antenna	Teseq	CBL 6111D	27089	Jul. 27, 13	Jul. 26, 14
Trilog-Broadband Antenna	SCHWARZBECK	VULB 9168	9168-554	Dec. 03, 13	Dec. 02, 14
Trilog-Broadband Antenna	SCHWARZBECK	VULB 9168	9168-555	Dec. 03, 13	Dec. 02, 14
10m Semi-anechoic Chamber	CHANGLING	21.4m*12.1m*8.8m	NSEMC006	Jun. 11, 13	Jun. 10, 14
Amplifier (9kHz-1GHz)	SONOMA	310D	186955	Mar. 05, 14	Mar. 04, 15
Test Software	ADT	ADT_Radiated_V7.6.15.9.2	N/A	N/A	N/A

#### Frequency Range Above1GHz

Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Next Cal.
Horn Antenna	ETS-Lindgren	3117	00062558	Oct. 18, 12	Oct. 17, 14
EMI Test Receiver	Rohde&Schwarz	ESCI	100962	Mar. 06, 14	Mar. 05, 15
Spectrum Analyzer	Rohde&Schwarz	FSV40	101003	Apr. 09, 14	Apr. 08, 15
Pre-Amplifier (100MHz-26.5GHz)	EMCI	EMC 012645	980077	Nov. 07, 13	Nov. 06, 14
Pre-Amplifier (18GHz-40GHz)	EMCI	EMC 184045	980102	Nov. 04, 13	Nov. 03, 14
Test Software	ADT	ADT_Radiated_V7.6.15.9.2	N/A	N/A	N/A

- NOTE: 1. The calibration interval of the above test instruments is 12 months. And the calibrations are traceable to CEPREI/CHINA and NIM/CHINA.  
2. The test was performed in Chamber 10m.

### 3.2.3 TEST PROCEDURE

#### <Frequency Range below 1GHz>

- a. The EUT was placed on the top of a rotating table 0.8 meters above the ground at a 10 meter chamber room. The table was rotated 360 degrees to determine the position of the highest radiation.
- b. The EUT was set 10 meters away from the interference-receiving antenna, which was mounted on the top of a variable-height antenna tower.
- c. The height of antenna is varied from one meter to four meters above the ground to determine the maximum value of the field strength. Both horizontal and vertical polarizations of the antenna are set to make the measurement.
- d. For each suspected emission, the EUT was arranged to its worst case and then the antenna was tuned to heights from 1 meter to 4 meters and the turn table was turned from 0 degrees to 360 degrees to find the maximum reading.
- e. The test-receiver system was set to quasi-peak detect function and specified bandwidth with maximum hold mode when the test frequency is below 1 GHz.

#### NOTE:

1. The resolution bandwidth of test receiver/spectrum analyzer is 120kHz for Quasi-peak detection (QP) at frequency below 1GHz.
2. Emission level(dBuV/m)=Raw Value(dBuV) + Correction Factor(dB/m)
3. Correction Factor(dB/m) = Antenna Factor (dB/m) + Cable Factor (dB)
4. Margin value = Emission level – Limit value.

#### <Frequency Range above 1GHz>

- a. The EUT was placed on the top of a rotating table 0.8 meters above the ground at a 10 meter Semi-anechoic chamber room. The table was rotated 360 degrees to determine the position of the highest radiation.
- b. The EUT was set 3 meters away from the interference-receiving antenna, which was mounted on the top of a variable-height antenna tower.
- c. The height of antenna can be varied from one meter to four meters, the height of adjustment depends on the EUT height and the antenna 3dB beamwidth both, to detect the maximum value of the field strength. Both horizontal and vertical polarizations of the antenna are set to make the measurement.
- d. For each suspected emission, the EUT was arranged to its worst case and then the antenna was tuned to heights and the rotatable table was turned from 0 degrees to 360 degrees to find the maximum reading.
- e. The test receiver/spectrum was set to peak and average detect function and specified bandwidth with maximum hold mode when the test frequency is above 1 GHz.

#### NOTE:


1. The resolution bandwidth is 1MHz and video bandwidth of test receiver/spectrum analyzer is 3MHz for Peak detection at frequency above 1GHz. The resolution bandwidth of test receiver/spectrum analyzer is 1 MHz for Average detection (AV) at frequency above 1GHz.
2. For measurement of frequency above 1000 MHz, the EUT was set 3 meters away from the receiver antenna.

### 3.2.4 DEVIATION FROM TEST STANDARD


No deviation

### 3.2.5 TEST SETUP

<Frequency Range below 1GHz>



<Frequency Range above 1GHz>



\* : depends on the EUT height and the antenna 3dB beamwidth both, refer to section 7.3 of CISPR 16-2-3.

### 3.2.6 EUT OPERATING CONDITIONS

Same as item 3.1.6




**BUREAU VERITAS** Test Report No.: CE140508N005R1

### 3.2.7 TEST RESULTS

<b>TEST MODE</b>	SOFAR 3000TL Grid Mode	<b>FREQUENCY RANGE</b>	30-1000 MHz
<b>TEST VOLTAGE</b>	DC 360V	<b>DETECTOR FUNCTION &amp; BANDWIDTH</b>	Quasi-Peak, 120kHz
<b>ENVIRONMENTAL CONDITIONS</b>	25 deg. C, 50% RH	<b>TESTED BY:</b> Robert	

ANTENNA POLARITY & TEST DISTANCE: HORIZONTAL AT 10 M								
No.	Freq. (MHz)	Correction Factor (dB/m)	Raw Value (dBuV)	Emission Level (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Antenna Height (cm)	Table Angle (Degree)
1	43.58	14.96	-0.74	14.22	30.00	-15.78	143	12
2	92.08	10.26	9.47	19.73	30.00	-10.27	400	31
3	113.42	12.35	9.75	22.10	30.00	-7.90	400	313
4	130.88	13.26	11.50	24.76	30.00	-5.24	400	122
5	183.26	12.88	6.59	19.47	30.00	-10.53	219	132
6	247.28	14.09	5.71	19.80	37.00	-17.20	100	13

**REMARKS:** The emission levels of other frequencies were very low against the limit..



Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch


No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China

Tel: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

TEST MODE	SOFAR 3000TL Grid Mode	FREQUENCY RANGE	30-1000 MHz
TEST VOLTAGE	DC 360V	DETECTOR FUNCTION & BANDWIDTH	Quasi-Peak, 120kHz
ENVIRONMENTAL CONDITIONS	25 deg. C, 50% RH	TESTED BY: Robert	

ANTENNA POLARITY & TEST DISTANCE: VERTICAL AT 10 M								
No.	Freq. (MHz)	Correction Factor (dB/m)	Raw Value (dBuV)	Emission Level (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Antenna Height (cm)	Table Angle (Degree)
1	43.58	14.96	9.04	24.00	30.00	-6.00	195	129
2	61.04	13.28	9.31	22.59	30.00	-7.41	165	104
3	94.00	10.50	12.90	23.40	30.00	-6.60	100	20
4	130.88	13.26	6.84	20.10	30.00	-9.90	100	20
5	191.02	12.37	12.55	24.92	30.00	-5.08	128	72
6	220.12	12.64	8.38	21.02	30.00	-8.98	231	160

REMARKS: The emission levels of other frequencies were very low against the limit.





### 3.3 HARMONICS CURRENT MEASUREMENT (<16A)

#### 3.3.1 LIMITS OF HARMONICS CURRENT MEASUREMENT

TEST STANDARD: EN 61000-3-2

Limits for Class A equipment		Limits for Class D equipment		
Harmonic Order n	Max. permissible harmonics current A	Harmonic Order n	Max. permissible harmonics current per watt mA/W	Max. permissible harmonics current A
Odd harmonics		Odd Harmonics only		
3	2.30	3	3.4	2.30
5	1.14	5	1.9	1.14
7	0.77	7	1.0	0.77
9	0.40	9	0.5	0.40
11	0.33	11	0.35	0.33
13	0.21	13	0.30	0.21
15<=n<=39	0.15x15/n	15<=n<=39	3.85/n	0.15x15/n
Even harmonics				
2	1.08			
4	0.43			
6	0.30			
8<=n<=40	0.23x8/n			

NOTE: 1. Class A and Class D are classified according to section 5 of EN 61000-3-2.

2. According to section 7 of EN 61000-3-2, the above limits for all equipment except for lighting equipment having an active power input > 75 W and no limits apply for equipment with an active power input up to and including 75 W.

◆ **Limits for Class B equipment:**

For class B equipment, the harmonics of the input current shall not exceed the maximum permissible values given for class A equipment multiplied by a factor of 1.5.

Limits for Class C equipment	
Harmonic Order n	Max. permissible harmonics current expressed as a percentage of the input current at the fundamental frequency %
2	2
3	30 · λ
5	10
7	7
9	5
11<=n<=39 (odd harmonics only)	3

λ is the circuit power factor

NOTE: Discharge lighting equipment having an active TEST VOLTAGE smaller than or equal to 25W, the harmonic currents shall not exceed the power related limits of Class D.



### 3.3.2 TEST INSTRUMENTS

DESCRIPTION & MANUFACTURER	MANUFACTURER	MODEL NO.	SERIAL NO.	CALIBRATED DATE	CALIBRATED UNTIL
PRECISION POWER ANALYZER	YOKOGAWA	WT3000	91M210852	Mar. 12,14	Mar. 11,15
Test Software	YOKOGAWA	IEC61000	N/A	N/A	N/A
REFERENCE IMPEDANCE NETWORK	Voltech	EUR	3018	N/A	N/A

NOTE: 1. The test was performed in PV Room.

2. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to CEPREI/CHINA, GRGT/CHINA and NIM/CHINA.

### 3.3.3 TEST PROCEDURE

- a. The EUT was placed on the top of a wooden table 0.8 meters above the ground and operated to produce the maximum harmonic components under normal operating conditions for each successive harmonic component in turn.
- b. The classification of EUT is according to section 5 of EN 61000-3-2:2006 + A1:2009 + A2:2009.

The EUT is classified as follows:

Class A: Balanced three-phase equipment, Household appliances excluding equipment as Class D, Tools excluding portable tools, Dimmers for incandescent lamps, audio equipment, equipment not specified in one of the three other classes.

Class B: Portable tools. ; Arc welding equipment which is not professional equipment

Class C: Lighting equipment.

Class D: Equipment having a specified power less than or equal to 600 W of the following types: Personal computers and personal computer monitors and television receivers.


- c. The correspondent test program of test instrument to measure the current harmonics emanated from EUT is chosen. The measure time shall be not less than the time necessary for the EUT to be exercised.



### 3.3.4 DEVIATION FROM TEST STANDARD

No deviation

### 3.3.5 TEST SETUP



### 3.3.6 EUT OPERATING CONDITIONS

Same as item 3.1.6

### 3.3.7 TEST RESULTS

SOFAR 1100TL

\*\*\*\*\* appliances (Average)


Print Date : Mon May 26 14:15:38 2014  
 MeasureDate : Mon May 26 14:15:34 2014  
 Comment : Experimental model Pattern A

Regulation : IEC61000-3-2 Ed3.0 am2  
 IEC61000-4-7 Ed2.0 A1  
 Class : CLASS A  
 MeasureTime : 150.00sec  
 Model : YOKOGAWA WT3000  
 Rating Voltage : 230.00 V  
 Wiring : single-phase 2-wire  
 Element : 1  
 Range : 300V/30A  
 Current(rms) : 4.2800 A  
 Voltage(rms) : 230.42 V  
 Frequency : 50.000 Hz  
 Power Factor : 0.9957  
 PCHC Limit : 0.2514 A  
 PCHC Max : 0.0040 A  
 THC : 0.0658 A

**PASS**

Set Fundamental I : -----  
 Set Power Factor : -----  
 Set P : -----  
 Sigma W Max : 982.9105 W  
 Sigma PF : 0.9957  
 Distortion factor(V) : 0.05 %  
 V THDS : 0.05 %  
 V THDG : 0.05 %  
 Distortion factor(A) : 1.53 %  
 A THDS : 1.53 %  
 A THDG : 1.64 %  
 P THD : 0.00 %  
 Power Limit : 75 W

Order	Measure[A]	Limit[A]	Margin[%]	Order	Measure[A]	Limit[A]	Margin[%]
1	4.2795			2	0.0030	1.0000	99.1
3	0.0632	2.3000	97.3	4	0.0040	0.4300	98.0
5	0.0094	1.1400	99.2	6	0.0031	0.3000	99.0
7	0.0061	0.7700	98.2	8	0.0022	0.2300	99.0
9	0.0038	0.4000	99.1	10	0.0023	0.1840	98.8
11	0.0023	0.3300	99.4	12	0.0023	0.1833	98.5
13	0.0018	0.2100	99.1	14	0.0018	0.1314	98.8
15	0.0018	0.1500	98.0	16	0.0016	0.1150	98.8
17	0.0014	0.1324	99.0	18	0.0015	0.1022	98.3
19	0.0010	0.1184	98.8	20	0.0010	0.0920	98.3
21	0.0017	0.1071	98.4	22	0.0015	0.0836	98.4
23	0.0014	0.0978	98.6	24	0.0012	0.0767	98.4
25	0.0018	0.0900	98.3	26	0.0014	0.0708	98.0
27	0.0012	0.0833	98.6	28	0.0011	0.0857	98.3
29	0.0012	0.0775	98.5	30	0.0010	0.0813	98.4
31	0.0010	0.0725	98.7	32	0.0011	0.0575	98.1
33	0.0011	0.0682	98.4	34	0.0010	0.0541	97.8
35	0.0011	0.0645	98.3	36	0.0010	0.0511	97.7
37	0.0009	0.0608	98.5	38	0.0010	0.0484	97.8
39	0.0008	0.0577	98.5	40	0.0010	0.0460	98.0



\*\*\*\*\* appliances (Maximum)


Print Date : Mon May 26 14:15:38 2014  
 MeasureDate : Mon May 26 14:15:34 2014  
 Comment : Experimental model Pattern A

Regulation : IEC61008-3-2 Ed3.0 an2  
 IEC61008-4-7 Ed2.0 A1  
 Class : CLASS A  
 MeasureTime : 150.00sec  
 Model : YOKOGAWA WT3000  
 Rating Voltage : 230.00 V  
 Wiring : single-phase 2-wire  
 Element : 1  
 Range : 300V/30A  
 Current(rms) : 4.2840 A  
 Voltage(rms) : 230.42 V  
 Frequency : 50.004 Hz  
 Power Factor : 0.9657  
 Beyond Limit Time : 15.0000 s  
 Beyond Total Time : 0.0000 s  
 THC : 0.0661 A

PASS

Set Fundamental I : -----  
 Set Power Factor : -----  
 Set P : -----  
 Sigma W Max : 982.9105 W  
 Sigma PF : 0.9957  
 Distortion factor(V) : 0.05 %  
 V THDS : 0.05 %  
 V THDG : 0.05 %  
 Distortion factor(A) : 1.55 %  
 A THDS : 1.55 %  
 A THDG : 1.56 %  
 P THD : 0.00 %  
 Power Limit : 75 W

Order	Measure[A]	Limit[A]	Margin[%]	Order	Measure[A]	Limit[A]	Margin[%]
1	4.2835			2	0.0100	1.6200	99.4
3	0.0835	3.4500	98.2	4	0.0047	0.6450	99.3
5	0.0289	1.7100	99.4	6	0.0033	0.4500	99.3
7	0.0050	1.1550	98.5	8	0.0024	0.3450	99.3
9	0.0039	0.6000	99.4	10	0.0025	0.2760	99.1
11	0.0022	0.4950	99.5	12	0.0025	0.2300	98.9
13	0.0021	0.3150	99.3	14	0.0023	0.1971	99.0
15	0.0015	0.2250	99.3	16	0.0019	0.1725	99.0
17	0.0015	0.1985	99.2	18	0.0019	0.1533	98.8
19	0.0016	0.1776	99.1	20	0.0017	0.1390	98.7
21	0.0019	0.1907	98.8	22	0.0015	0.1255	98.8
23	0.0016	0.1467	98.9	24	0.0013	0.1150	98.8
25	0.0016	0.1360	98.8	26	0.0015	0.1052	98.6
27	0.0013	0.1250	98.9	28	0.0012	0.0985	98.8
29	0.0013	0.1154	98.9	30	0.0013	0.0920	98.9
31	0.0011	0.1059	99.0	32	0.0012	0.0862	98.6
33	0.0011	0.1023	98.8	34	0.0014	0.0812	98.3
35	0.0012	0.0954	98.7	36	0.0013	0.0767	98.4
37	0.0010	0.0912	98.9	38	0.0013	0.0725	98.3
39	0.0010	0.0865	98.9	40	0.0019	0.0690	97.7



Bureau Veritas Shenzhen Co., Ltd.  
 Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
 Town, Dongguan City,  
 Guangdong 523942, China

Tel: +86 769 8593 5656  
 Fax: +86 769 8593 1080  
 Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)



**Test Report No.: CE140508N005R1**  
**SOFAR 3000TL**

**\*\*\*\*\* appliances (Average)**


Print Date : Wed Jun 11 11:32:38 2014  
 MeasureDate : Wed Jun 11 11:31:38 2014  
 Comment : Experimental model Pattern A

Regulation : IEC61000-3-2 Ed3.0 am2  
 IEC61000-4-7 Ed2.0 A1  
 Class : CLASS A  
 MeasureTime : 150.00sec  
 Model : YOKOGAWA WT3000  
 Rating Voltage : 230.00 V  
 Wiring : single-phase 2-wire  
 Element : 2  
 Range : 300V/30A  
 Current(rms) : 12.1883 A  
 Voltage(rms) : 229.99 V  
 Frequency : 49.999 Hz  
 Power Factor : 0.9990  
 POHC Limit : 0.2514 A  
 POHC Max : 0.0365 A  
 THC : 0.1683 A

**PASS**

Set Fundamental I : -----  
 Set Power Factor : -----  
 Set P : -----  
 Sigma W Max : 2804.014 W  
 Sigma PF : 0.9990  
 Distortion factor(V) : 0.04 %  
 V THDS : 0.04 %  
 V THDG : 0.04 %  
 Distortion factor(A) : 1.38 %  
 A THDS : 1.38 %  
 A THDG : 1.38 %  
 P THD : 0.00 %  
 Power Limit : 75 W

Order	Measure[A]	Limit[A]	Margin[%]	Order	Measure[A]	Limit[A]	Margin[%]
1	12.1882			2	0.0291	1.0800	99.2
3	0.1580	2.3000	93.1	4	0.0062	0.4300	98.6
5	0.0313	1.1400	97.2	6	0.0231	0.3000	99.0
7	0.0138	0.7700	98.2	8	0.0231	0.2300	98.7
9	0.0254	0.4000	98.6	10	0.0242	0.1840	97.7
11	0.0209	0.3300	98.2	12	0.0337	0.1533	97.6
13	0.0121	0.2100	94.3	14	0.0240	0.1314	96.9
15	0.0102	0.1600	93.2	16	0.0232	0.1180	97.3
17	0.0129	0.1324	90.3	18	0.0234	0.1022	97.7
19	0.0130	0.1184	88.3	20	0.0229	0.0920	97.2
21	0.0188	0.1071	86.3	22	0.0219	0.0836	97.8
23	0.0137	0.0978	88.0	24	0.0219	0.0767	97.9
25	0.0133	0.0900	85.2	26	0.0219	0.0708	97.3
27	0.0133	0.0833	84.4	28	0.0217	0.0657	97.3
29	0.0119	0.0776	84.7	30	0.0215	0.0613	97.8
31	0.0107	0.0726	85.3	32	0.0212	0.0575	98.0
33	0.0094	0.0682	86.1	34	0.0212	0.0541	97.7
35	0.0091	0.0643	85.9	36	0.0211	0.0511	97.8
37	0.0079	0.0608	87.1	38	0.0213	0.0484	97.2
39	0.0077	0.0577	86.6	40	0.0212	0.0460	97.4



Bureau Veritas Shenzhen Co., Ltd.  
 Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
 Town, Dongguan City,  
 Guangdong 523942, China

Tel: +86 769 8593 5656  
 Fax: +86 769 8593 1080  
 Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

\*\*\*\*\* appliances (Maximum)


Print Date : Wed Jun 11 11:32:39 2014  
 MeasureDate : Wed Jun 11 11:31:38 2014  
 Comment : Experimental model Pattern A

Regulation : IEC61000-3-2 Ed3.0 am2  
 IEC61000-4-7 Ed2.0 A1  
 Class : CLASS A  
 MeasureTime : 150.00sec  
 Model : YOKOGAWA WT3000  
 Rating Voltage : 230.00 V  
 Wiring : single-phase 2-wire  
 Element : 2  
 Range : 300V/30A  
 Current(rms) : 12.1941 A  
 Voltage(rms) : 229.89 V  
 Frequency : 50.018 Hz  
 Power Factor : 0.9998  
 Beyond Limit Time : 15.0002 s  
 Beyond Total Time : 0.0000 s  
 THC : 0.1694 A

**PASS**

Set Fundamental I : -----  
 Set Power Factor : -----  
 Set P : -----  
 Sigma W Max : 2804.014 W  
 Sigma PF : 0.9998  
 Distortion factor(V) : 0.04 %  
 V THDi : 0.04 %  
 V THDg : 0.04 %  
 Distortion factor(A) : 1.40 %  
 A THDi : 1.40 %  
 A THDg : 1.40 %  
 P THD : 0.00 %  
 Power Limit : 75 W

Order	Measure[A]	Limit[A]	Margin[%]	Order	Measure[A]	Limit[A]	Margin[%]
1	12.1929			2	0.0007	1.6200	99.5
3	0.1591	3.4500	95.4	4	0.0007	0.6450	99.0
5	0.0323	1.7100	98.1	6	0.0035	0.4650	99.2
7	0.0145	1.1550	98.7	8	0.0054	0.3450	99.0
9	0.0058	0.9000	99.0	10	0.0047	0.2760	99.3
11	0.0055	0.4850	98.7	12	0.0042	0.2300	99.2
13	0.0129	0.3150	95.9	14	0.0029	0.1971	97.4
15	0.0199	0.2250	95.2	16	0.0035	0.1725	99.0
17	0.0154	0.1985	93.3	18	0.0027	0.1633	99.2
19	0.0142	0.1776	92.0	20	0.0028	0.1360	97.9
21	0.0150	0.1607	90.7	22	0.0021	0.1256	99.4
23	0.0159	0.1487	90.5	24	0.0019	0.1150	99.4
25	0.0150	0.1350	89.9	26	0.0022	0.1062	99.0
27	0.0152	0.1250	89.4	28	0.0020	0.0966	99.0
29	0.0121	0.1164	89.6	30	0.0019	0.0920	99.4
31	0.0108	0.1089	90.0	32	0.0019	0.0882	99.5
33	0.0097	0.1023	90.6	34	0.0014	0.0812	99.3
35	0.0092	0.0964	90.4	36	0.0012	0.0767	99.4
37	0.0081	0.0912	91.1	38	0.0016	0.0726	97.9
39	0.0079	0.0865	90.8	40	0.0014	0.0660	97.9





**BUREAU VERITAS** Test Report No.: CE140508N005R1

### 3.4 VOLTAGE FLUCTUATION AND FLICKS MEASUREMENT

#### 3.4.1 LIMITS OF VOLTAGE FLUCTUATION AND FLICKS MEASUREMENT

TEST STANDARD: EN 61000-3-3

TEST ITEM	LIMIT	NOTE
$P_{st}$	1.0	$P_{st}$ means short-term flicker indicator.
$P_{lt}$	0.65	$P_{lt}$ means long-term flicker indicator.
$T_{d(t)}$ (ms)	500	$T_{d(t)}$ means maximum time that $d(t)$ exceeds 3.3%.
$d_{max}$ (%)	4	$d_{max}$ means maximum relative voltage change.
dc (%)	3.3	dc means relative steady-state voltage change

#### 3.4.2 TEST INSTRUMENTS

DESCRIPTION & MANUFACTURER	MANUFACTURER	MODEL NO.	SERIAL NO.	CALIBRATED DATE	CALIBRATED UNTIL
PRECISION POWER ANALYZER	YOKOGAWA	WT3000	91M210852	Mar. 12,14	Mar. 11,15
Test Software	YOKOGAWA	IEC61000	N/A	N/A	N/A
REFERENCE IMPEDANCE NETWORK	Voltech	EUR	3018	N/A	N/A

NOTE: 1. The test was performed in PV Room.

2. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to CEPREI/CHINA, GRGT/CHINA and NIM/CHINA.

#### 3.4.3 TEST PROCEDURE

- a. The EUT was placed on the top of a wooden table 0.8 meters above the ground and operated to produce the most unfavorable sequence of voltage changes under Normal Operating conditions.
- b. During the flick measurement, the measure time shall include that part of whole operation cycle in which the EUT produce the most unfavorable sequence of voltage changes. The observation period for short-term flicker indicator is 120 minutes

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China

Tel: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

Page 32 of 66


Report Version 1



### 3.4.4 DEVIATION FROM TEST STANDARD

No deviation

### 3.4.5 TEST SETUP



### 3.4.6 EUT OPERATING CONDITIONS

Same as item 3.1.6.



### 3.4.7 TEST RESULTS

SOFAR 1100TL

#### PV Inverter

Print Date : Mon May 26 16:26:18 2014  
 MeasureDate : Mon May 26 16:25:54 2014  
 Comment : Experimental model Pattern A

Regulation : IEC81000-3-3 Ed2.0  
 IEC81000-4-15 Ed1.1  
 Interval : 10Min0Sec  
 Model : YOKOGAWA WT3000  
 Wiring : single-phase 2-wire  
 Voltage Range : 300.00V  
 Voltage U1 : 231.81V  
 Set Frequency : 50Hz  
 Frequency U1 : 50.000Hz  
 Element : 1  
 dmin : 0.10%

#### PASS(Under dmin)

Element1 : Pass(Under dmin)  
 dc (3.90%) : Pass  
 dmax (4.00%) : Pass  
 d(t) (500ms) : Pass  
 Pst (1.00) : Pass  
 Plt (0.65) : Pass

No.	dc(%)	dmax(%)	d(t)(ms)	Pst
1	0.00	0.00	0.00	0.07
2	0.00	0.00	0.00	0.07
3	0.00	0.00	0.00	0.07
4	0.00	0.00	0.00	0.07
5	0.00	0.00	0.00	0.07
6	0.00	0.00	0.00	0.07
7	0.00	0.00	0.00	0.07
8	0.00	0.00	0.00	0.07
9	0.00	0.00	0.00	0.07
10	0.00	0.00	0.00	0.07
11	0.00	0.00	0.00	0.07
12	0.00	0.00	0.00	0.07
			Plt	0.07





### PV Inverter

Print Date : Fri Jun 13 11:17:38 2014  
 Measure Date : Fri Jun 13 11:17:28 2014  
 Comment : Experimental model Pattern A

Regulation : IEC61000-3-3 Ed2.0  
 : IEC61000-4-15 Ed1.1  
 Interval : 10Min05Sec  
 Model : YOKOGAWA WT3000  
 Wiring : single-phase 2-wire  
 Voltage Range : 300.00V  
 Voltage U1 : 234.15V  
 Set Frequency : 50Hz  
 Frequency U1 : 50.000Hz  
 Element : 1  
 dmin : 0.10%

### PASS (Under dmin)

Element1	:	Pass(Under dmin)
dc	(3.30%)	: Pass
dmax	(4.00%)	: Pass
d(t)	(500ms)	: Pass
Pst	(1.00)	: Pass
Pit	(0.65)	: Pass

No.	dc[%]	dmax[%]	d(t)[ms]	Pst
1	0.00	0.00	0.00	0.07
2	0.00	0.00	0.00	0.07
3	0.00	0.00	0.00	0.07
4	0.00	0.00	0.00	0.07
5	0.00	0.00	0.00	0.07
6	0.00	0.00	0.00	0.07
7	0.00	0.00	0.00	0.07
8	0.00	0.00	0.00	0.07
9	0.00	0.00	0.00	0.07
10	0.00	0.00	0.00	0.07
11	0.00	0.00	0.00	0.07
12	0.00	0.00	0.00	0.07
				Pit
				0.07



**BUREAU  
VERITAS** Test Report No.: CE140508N005R1

## 4 IMMUNITY TEST

### 4.1 GENERAL DESCRIPTION

#### 4.1.1 GENERAL DESCRIPTION OF EN 61000-6-2

<b>Product Standard:</b>	<b>EN 61000-6-2:2005</b>	
<b>Basic Standard, specification requirement, and Performance Criteria:</b>	IEC 61000-4-2	Electrostatic Discharge – ESD: 4kV Contact discharge, 8kV air discharge, Performance Criterion B
	IEC 61000-4-3	Radio-Frequency Electromagnetic Field Susceptibility Test – RS: 80-1000 MHz, 10V/m, 80% AM (1kHz), 1400-2000 MHz, 3V/m, 80% AM (1kHz) 2000-2700 MHz, 1V/m, 80% AM (1kHz) Performance Criterion A
	IEC 61000-4-4	Electrical Fast Transient/Burst - EFT AC Power line: 2kV, DC Power line: 2kV Signal line: 1kV Performance Criterion B
	IEC 61000-4-5	Surge Immunity Test: 1.2/50 us Open Circuit Voltage, 8 /20 us Short Circuit Current, AC Power Line: line to line 1 kV, line to earth 2kV DC Power Line: line to line 0.5kV line to earth 0.5kV Signal line: 1kV Performance Criterion B
	IEC 61000-4-6	Conducted Radio Frequency Disturbances Test – CS: 0.15-80 MHz, 10Vrms, 80% AM, 1kHz, Performance Criterion A
	IEC 61000-4-8	Power Frequency Magnetic Field Test, 50 Hz, 30A/m, Performance Criterion A

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China

Tel: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

Page 36 of 66

Report Version 1

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd.,  
Houjie Town, Dongguan City, Guangdong  
523942, China

Tel: +86 769 8593 5656  
Fax: +86 769 8599 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

Page 66 of 123

TEST REPORT C11/C10 VER.0



#### 4.1.2 PERFORMANCE CRITERIA

According to Clause 4 of EN 61000-6-2:2005 standard, the following describes the general performance criteria.

CRITERION A	The apparatus shall continue to operate as intended during and after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, either of these may be derived from the product description and documentation and what the user may reasonably expect from the apparatus if used as intended.
CRITERION B	The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended. The performance level may be replaced by a permissible loss of performance. During the test, degradation of performance is however allowed. No change of operating state or stored data is allowed. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, either of these may be derived from the product description and documentation and what the user may reasonably expect from the apparatus if used as intended.
CRITERION C	Temporary loss of function is allowed, provided the function is self-recoverable or can be restored by the operation of the controls.

#### 4.1.3 EUT OPERATING CONDITION

Same as item 3.1.6



## 4.2 ELECTROSTATIC DISCHARGE IMMUNITY TEST (ESD)

### 4.2.1 TEST SPECIFICATION

Basic Standard:	IEC 61000-4-2
Discharge Impedance:	330 ohm / 150 pF
Discharge Voltage:	Air Discharge: 8 kV (Direct) Contact Discharge: 4 kV (Indirect)
Polarity:	Positive & Negative
Number of Discharge:	20 times at each test point
Discharge Mode:	Single Discharge
Discharge Period:	1 second

### 4.2.2 TEST INSTRUMENTS

Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Next Cal.
ESD Generator	TESEQ	NSG 437	279	Oct. 12, 13	Oct. 11, 14
Test Software	TESEQ	V03.03	N/A	N/A	N/A
ESD Generator	EM TEST	Dito	V1211112265	Jun. 19,14	Jun. 18,15
Test Software	EM TEST	V 2.31	N/A	N/A	N/A

NOTE: 1. The test was performed in ESD Room.

2. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to CEPREI/CHINA, GRGT/CHINA and NIM/CHINA.

#### 4.2.3 TEST PROCEDURE


The basic test procedure was in accordance with IEC 61000-4-2:

- a. Electrostatic discharges were applied only to those points and surfaces of the EUT that are accessible to users during normal operation.
- b. The test was performed with at least ten single discharges on the pre-selected points in the most sensitive polarity.
- c. The time interval between two successive single discharges was at least 1 second.
- d. The ESD generator was held perpendicularly to the surface to which the discharge was applied and the return cable was at least 0.2 meters from the EUT.
- e. Contact discharges were applied to the non-insulating coating, with the pointed tip of the generator penetrating the coating and contacting the conducting substrate.
- f. Air discharges were applied with the round discharge tip of the discharge electrode approaching the EUT as fast as possible (without causing mechanical damage) to touch the EUT. After each discharge, the ESD generator was removed from the EUT and re-triggered for a new single discharge. The test was repeated until all discharges were complete.
- g. At least ten single discharges (in the most sensitive polarity) were applied to the Horizontal Coupling Plane at points on each side of the EUT. The ESD generator was positioned horizontal at a distance of 0.1 meters from the EUT with the discharge electrode touching the HCP.
- h. At least ten single discharges (in the most sensitive polarity) were applied to the center of one vertical edge of the Vertical Coupling Plane in sufficiently different positions that the four faces of the EUT were completely illuminated. The VCP (dimensions 0.5m x 0.5m) was placed vertically to and 0.1 meters from the EUT.

#### 4.2.4 DEVIATION FROM TEST STANDARD

No Deviation

## 4.2.5 TEST SETUP



### NOTE:

#### TABLE-TOP EQUIPMENT

The configuration consisted of a wooden table 0.8 meters high standing on the Ground Reference Plane. The GRP consisted of a sheet of aluminum at least 0.25mm thick, and 2.5 meters square connected to the protective grounding system. A Horizontal Coupling Plane (1.6m x 0.8m) was placed on the table and attached to the GRP by means of a cable with 940kΩ total impedance. The equipment under test, was installed in a representative system as described in section 7 of IEC 61000-4-2, and its cables were placed on the HCP and isolated by an insulating support of 0.5mm thickness. A distance of 1-meter minimum was provided between the EUT and the walls of the laboratory and any other metallic structure.

#### FLOOR-STANDING EQUIPMENT

The equipment under test was installed in a representative system as described in section 7 of IEC 61000-4-2, and its cables were isolated from the Ground Reference Plane by an insulating support of 0.1-meter thickness. The GRP consisted of a sheet of aluminum that is at least 0.25mm thick, and 2.5 meters square connected to the protective grounding system and extended at least 0.5 meters from the EUT on all sides.



BUREAU  
VERITAS Test Report No.: CE140508N005R1

#### 4.2.6 TEST RESULTS

TEST MODE	See item 2.2	TEST VOLTAGE	DC 300V
ENVIRONMENTAL CONDITIONS	21.2deg. C, 51% RH 101.3kPa	TESTED BY: Heise	

Direct Discharge Application				
Test Level (kV)	Polarity	Test Point	Test Result of Contact Discharge	Test Result of Air Discharge
4	+/-	All Metal Part	A	N/A
8	+/-	All Non-metal Part	N/A	A

Indirect Discharge Application				
Discharge Level (kV)	Polarity	Test Point	Test Result of HCP	Test Result of VCP
4	+/-	HCP&VCP	A	A

NOTE: A: There was no change compared with initial operation during the test.

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China

Tel: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

Page 41 of 66

Report Version 1



## 4.3 RADIATED, RADIO-FREQUENCY, ELECTROMAGNETIC FIELD IMMUNITY TEST (RS)

### 4.3.1 TEST SPECIFICATION

Basic Standard:	IEC 61000-4-3
Frequency Range:	80-1000MHz, 1400-2000MHz, 2000-2700MHz
Field Strength:	10V/m, 3V/m, 1V/m
Modulation:	1kHz Sine Wave, 80%, AM Modulation
Frequency Step:	1 % of fundamental
Polarity of Antenna:	Horizontal and Vertical
Antenna Height:	1.5m
Dwell Time:	at least 3 seconds

### 4.3.2 TEST INSTRUMENTS

Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Next Cal.
Signal Generator	Agilent	N5181A	MY50142530	Nov. 01,13	Oct. 31,14
Antenna Log-Periodic	CORAD	ATR80M6G	0337307	N/A	N/A
Antenna Log-Periodic	CORAD	ATS700M11G	0336821	N/A	N/A
Switch Controller	CORAD	SC1000	0337343	N/A	N/A
RF Power Meter	ESE	4242	13984	Nov. 04,13	Nov. 03,14
Power Sensor	ESE	51011EMC	35716	Nov. 04,13	Nov. 03,14
Power Sensor	ESE	51011EMC	35715	Nov. 04,13	Nov. 03,14
E-Field probe	Narda	NBM-520	2403/01B	May 07,14	May 06,15
Power Amplifier	TESEQ	CBA 1G-150	T44029	N/A	N/A
Power Amplifier	TESEQ	CBA 3G-100	T44030	N/A	N/A
Power Amplifier	TESEQ	CBA 6G-050	1041204	N/A	N/A
Dual Directional Coupler	TESEQ	C5982	95208	Dec. 23,13	Dec. 22,14
Dual Directional Coupler	TESEQ	C6187	95175	Dec. 23,13	Dec. 22,14
Dual Directional Coupler	TESEQ	CPH-274F	M251304-01	Dec. 23,13	Dec. 22,14
Test Software	ADT	BVADT_RS_V7.6 .4-DG	N/A	N/A	N/A

NOTE: 1. The test was performed in RS chamber.

2. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to CEPREI/CHINA, GRGT/CHINA and NIM/CHINA.



### 4.3.3 TEST PROCEDURE


The test procedure was in accordance with IEC 61000-4-3

- a. The testing was performed in a fully-anechoic chamber.
- b. The frequency range is swept from 80 MHz to 1000 MHz, 1400MHz to 2000MHz, 2000MHz to 2700MHz with the signal 80% amplitude modulated with a 1kHz sine wave.
- c. The dwell time at each frequency shall not be less than the time necessary for the EUT to be exercised and to respond, but shall in no case be less than 0,5s.
- d. The field strength levels were 10V/m, 3V/m, 1V/m.
- e. The test was performed with the EUT exposed to both vertically and horizontally polarized fields on each of the four sides.

### 4.3.4 DEVIATION FROM TEST STANDARD

No Deviation

### 4.3.5 TEST SETUP



#### NOTE:

##### TABLETOP EQUIPMENT

The EUT installed in a representative system as described in section 7 of IEC 61000-4-3 was placed on a non-conductive table 0.8 meters in height. The system under test was connected to the power and signal wire according to relevant installation instructions.

##### FLOOR STANDING EQUIPMENT

The EUT installed in a representative system as described in section 7 of IEC 61000-4-3 was placed on a non-conductive wood support 0.1 meters in height. The system under test was connected to the power and signal wire according to relevant installation instructions.



#### 4.3.6 TEST RESULTS

<b>TEST MODE</b>	See item 2.2	<b>TEST VOLTAGE</b>	DC 300V
<b>ENVIRONMENTAL CONDITIONS</b>	21.6deg. C, 57.5% RH	<b>TESTED BY:</b> Heise	

Field Strength (V/m)	Test Frequency Note#1 (MHz)	Polarization of antenna (Horizontal / Vertical)	Test Distance (m)	Test Result	Remark
10	80 - 1000	H&V	3	A	N/A
3	1400 - 2000	H&V	3	A	N/A
1	2000 - 2700	H&V	3	A	N/A

Note#1:

Tested Israel SII Frequencies 89,100,107,144,163,196,244,315,434,460,600,825,845,880 MHz

**NOTE:** A: There was no change compared with initial operation during the test.



**BUREAU VERITAS** Test Report No.: CE140508N005R1

## 4.4 ELECTRICAL FAST TRANSIENT/BURST IMMUNITY TEST (EFT)

### 4.4.1 TEST SPECIFICATION

Basic Standard:	IEC 61000-4-4
Test Voltage:	Power Line: 2kV
Polarity:	Positive & Negative
Impulse Frequency:	5 kHz
Impulse Waveshape :	5/50 ns
Burst Duration:	15 ms
Burst Period:	300 ms
Test Duration:	1 min.

### 4.4.2 TEST INSTRUMENTS

Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Next Cal.
EFT Tester	HAEFELY	PEFT4010	150546	May 17,14	May 16,15
EFT Coupling Clamp	HAEFELY	IP4A	150407	May 17,14	May 16,15
Test Software	HAEFELY	SWPE4010 1.22	N/A	N/A	N/A

NOTE: 1. The test was performed in EMS Room 1.  
 2. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to CEPREI/CHINA, GRGT/CHINA and NIM/CHINA.


### 4.4.3 TEST PROCEDURE

- Both positive and negative polarity discharges were applied.
- The length of the "hot wire" from the coaxial output of the EFT generator to the terminals on the EUT should not exceed 0.5 meter  $\pm$  0.05 meter.
- The duration time of each test sequential was 1 minute.
- The transient/burst waveform was in accordance with IEC 61000-4-4, 5/50ns.

### 4.4.4 DEVIATION FROM TEST STANDARD

No deviation.

### 4.4.5 TEST SETUP



**NOTE:**

**TABLETOP EQUIPMENT**

The configuration consisted of a wooden table standing on the Ground Reference Plane and should be located 0.1m +/- 0.01m above the Ground Reference Plane. The GRP consisted of a sheet of aluminum (at least 0.25mm thick and 2.5m square) connected to the protective grounding system. A minimum distance of 0.5m was provided between the EUT and the walls of the laboratory or any other metallic structure.

**FLOOR STANDING EQUIPMENT**

The EUT installed in a representative system as described in section 7 of IEC 61000-4-4 and its cables, were isolated from the Ground Reference Plane by an insulating support that is 0.1-meter thick. The GRP consisted of a sheet of aluminum (at least 0.25mm thick and 2.5m square) connected to the protective grounding system.



#### 4.4.6 TEST RESULTS

TEST MODE	See item 2.2	TEST VOLTAGE	DC 300V
ENVIRONMENTAL CONDITIONS	21.5 deg. C, 58.2% RH	TESTED BY: Heise	

Pulse Voltage	2 kV		kV		kV		kV	
	+	-	+	-	+	-	+	-
L	A	A	/	/	/	/	/	/
N	A	A	/	/	/	/	/	/
PE	A	A	/	/	/	/	/	/
L+N	A	A	/	/	/	/	/	/
L+PE	A	A	/	/	/	/	/	/
N+PE	A	A	/	/	/	/	/	/
L+N+PE	A	A	/	/	/	/	/	/
DC Line	A	A	/	/	/	/	/	/

NOTE: A: There was no change compared with initial operation during the test.



## 4.5 SURGE IMMUNITY TEST

### 4.5.1 TEST SPECIFICATION

<b>Basic Standard:</b>	IEC 61000-4-5
<b>Wave-Shape:</b>	Combination Wave 1.2/50 us Open Circuit Voltage 8 /20 us Short Circuit Current
<b>Test Voltage:</b>	AC Power Line: Line to Line:1kV Line to PE:2kV Signal Line: 1kV DC Power Line: Line to Line:0.5kV Line to PE:0.5kV
<b>Surge Input/Output:</b>	L-N&L-PE&N-PE, RJ 45 Line
<b>Generator Source</b>	2 ohm between networks
<b>Impedance:</b>	12 ohm between network and ground
<b>Polarity:</b>	Positive/Negative
<b>Phase Angle:</b>	0° /90°/180°/270°
<b>Pulse Repetition Rate:</b>	1 time / 60 sec.
<b>Number of Tests:</b>	5 positive and 5 negative at selected points

### 4.5.2 TEST INSTRUMENTS

Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Next Cal.
Combination wave Module	TESEQ AG	CDN 3061	1361	Feb. 17,14	Feb. 16,15
Telecom Surge Module	TESEQ AG	NSG 3060 Mainframe	1404	Feb. 17,14	Feb. 16,15
CDN	TESEQ	CDN HSS-2	34275	Nov.06, 13	Nov.05, 14
CDN	TESEQ	CDN 118	30741	Nov.06, 13	Nov.05, 14
Test Software	TESEQ	CDM 3061_0002.30	1361	N/A	N/A
Test Software	TESEQ	HVM 3060_0002.30	293	N/A	N/A

NOTE: 1. The test was performed in EMS Room 1.

2. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to CEPREI/CHINA, GRGT/CHINA and NIM/CHINA.

### 4.5.3 TEST PROCEDURE

a. For EUT power supply:

The surge is to be applied to the EUT power supply terminals via the capacitive coupling network. Decoupling networks are required in order to avoid possible adverse effects on equipment not under test that may be powered by the same lines, and to provide sufficient decoupling impedance to the surge wave. The power cord between the EUT and the coupling/decoupling networks shall be 2 meters in length (or shorter).

b. For test applied to unshielded unsymmetrically operated interconnection lines of EUT:

The surge is applied to the lines via the capacitive coupling. The coupling / decoupling networks shall not influence the specified functional conditions of the EUT. The interconnection line between the EUT and the coupling/decoupling networks shall be 2 meters in length (or shorter).


c. For test applied to unshielded symmetrically operated interconnection / telecommunication lines of EUT:

The surge is applied to the lines via gas arrestors coupling. Test levels below the ignition point of the coupling arrestor cannot be specified. The interconnection line between the EUT and the coupling/decoupling networks shall be 2 meters in length (or shorter).

### 4.5.4 DEVIATION FROM TEST STANDARD

No deviation.

### 4.5.5 TEST SETUP





### 4.5.6 TEST RESULTS

<b>TEST MODE</b>	See item 2.2	<b>TEST VOLTAGE</b>	DC 300V
<b>ENVIRONMENTAL CONDITIONS</b>	21.5deg. C, 59.2% RH	<b>TESTED BY:</b> Heise	

**AC/DC Power ports:**

Voltage (kV)	Phase angle \ Test point	Test result Polarity	0°	90°	180°	270°	DC Power Port
1	L-N	+	B	B	B	B	N/A
		-	B	B	B	B	N/A
2	L-PE	+	B	B	B	B	N/A
		-	B	B	B	B	N/A
2	N-PE	+	B	B	B	B	N/A
		-	B	B	B	B	N/A

**Signal ports and telecommunication ports:**

Voltage (kV)	Test Point	Polarity	Test result	Voltage (kV)	Test Point	Polarity	Test result
/	/	+/-	/	/	/	+/-	/

**NOTE:** A: There was no change compared with initial operation during the test.  
 B: During test, EUT stopped grid, and could automatically return to normal after test.



## 4.6 IMMUNITY TO CONDUCTED DISTURBANCES INDUCED BY RF FIELDS (CS)

### 4.6.1 TEST SPECIFICATION

Basic Standard:	IEC 61000-4-6
Frequency Range:	0.15 MHz - 80 MHz
Field Strength:	10V <sub>r.m.s</sub>
Modulation:	1kHz Sine Wave, 80%, AM Modulation
Frequency Step:	1 % of fundamental
Coupled Cable:	Power Mains & DC Power Line
Coupling Device:	CDN-M3(3 wires) & Clamp

### 4.6.2 TEST INSTRUMENTS

Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Next Cal.
Signal Generator	Rohde&Schwarz	SME06	829498/006	Oct.15,13	Oct.14, 14
CDN	Luthi	L-801M2/M3	2015	Oct.18,13	Oct. 17,14
CDN(AUX)	TESEQ	CDN M016	27452	Nov. 20,13	Nov. 19,14
CDN	TESEQ	T200A	26944	Apr. 08,14	Apr. 07,15
CDN	TESEQ	T400A	26536	Apr. 08,14	Apr. 07,15
CDN	TESEQ	ST08A	32256	Apr. 08,14	Apr. 07,15
6dB 50Watt Attenuator	HUBER+SUHNER	5906.17.0005	303688	Oct.15,13	Oct.14,14
Signal Amplifier	HAEFELY	PAMP250	149594	NA	NA
Electromagnetic Injection Clamp	Luthi	EM101	35640	Oct.16,13	Oct.15,14
C/S Test System	HAEFELY	WinPAMP	NSEMC002	N/A	N/A
Test Software	ADT	BVADT_CS_V7.5.1	N/A	N/A	N/A

NOTE: 1. The test was performed in CS test room.

2. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to CEPREI/CHINA, GRGT/CHINA and NIM/CHINA.


#### 4.6.3 TEST PROCEDURE

- a. The EUT shall be tested within its intended operating and climatic conditions.
- b. An artificial hand was placed on the hand-held accessory and connected to the ground reference plane.
- c. The test shall be performed with the test generator connected to each of the coupling and decoupling devices in turn, while the other non-excited RF input ports of the coupling devices are terminated by a 50-ohm load resistor.
- d. The frequency range is swept from 150 kHz to 80 MHz, using the signal level established during the setting process and with a disturbance signal of 80 % amplitude. The signal is modulated with a 1 kHz sine wave, pausing to adjust the RF signal level or the switch coupling devices as necessary. Where the frequency is swept incrementally, the step size shall not exceed 1 % of the preceding frequency value.
- e. The dwell time of the amplitude modulated carrier at each frequency shall not be less than the time necessary for the EUT to be exercised and to respond, but shall in no case be less than 0,5 s. The sensitive frequencies (e.g. clock frequencies) shall be analyzed separately.
- f. Attempts should be made to fully exercise the EUT during testing, and to fully interrogate all exercise modes selected for susceptibility.

#### 4.6.4 DEVIATION FROM TEST STANDARD

No deviation.

### 4.6.5 TEST SETUP



NOTE: The EUT clearance from any metallic obstacles shall be at least 0.5m.  
All non-excited input ports of the CDNs shall be terminated by  $50\Omega$  loads.

**NOTE:**

**FLOOR-STANDING EQUIPMENT**

The equipment to be tested is placed on an insulating support of 0.1 meters height above a ground reference plane. All relevant cables shall be provided with the appropriate coupling and decoupling devices at a distance between 0.1 meters and 0.3 meters from the projected geometry of the EUT on the ground reference plane.



#### 4.6.6 TEST RESULTS

TEST MODE	See Item 2.2	TEST VOLTAGE	DC 300V
ENVIRONMENTAL CONDITIONS	22.5deg. C, 56.6% RH	TESTED BY: Heise	

Voltage (V)	Test Frequency Note <sup>#1</sup> (MHz)	Tested Line	Injection Method.	Test Result	Remark
10	0.15 – 80	AC Mains	CDN-M3	A	N/A
10	0.15 – 80	DC line	Clamp	A	N/A

Note<sup>#1</sup>: Tested Israel SII Frequencies 0.2,0.53,1,1.5,7.1,13.56,21,27.12,40.68,65,68 MHz

NOTE: A: There was no change compared with initial operation during the test.



## 4.7 POWER FREQUENCY MAGNETIC FIELD IMMUNITY TEST

### 4.7.1 TEST SPECIFICATION

Basic Standard:	IEC 61000-4-8
Frequency Range:	50Hz, 60Hz
Field Strength:	30A/m
Observation Time:	5 minute
Inductance Coil:	Rectangular type, 1mx1m

### 4.7.2 TEST INSTRUMENTS

Equipment	Manufacturer	Model No.	Serial No.	Last Cal.	Next Cal.
Magnetic Field Tester	HAEFELY	MAG100.1	150579	Oct.18,13	Oct.17,14
Test Software	N/A	N/A	N/A	N/A	N/A

NOTE: 1. The test was performed in Shielding Room 843.

2. The calibration interval of the above test instruments is 12 months and the calibrations are traceable to CEPREI/CHINA, GRGT/CHINA and NIM/CHINA.


### 4.7.3 TEST PROCEDURE

- The equipment is configured and connected to satisfy its functional requirements.
- The power supply, input and output circuits shall be connected to the sources of power supply, control and signal.
- The cables supplied or recommended by the equipment manufacturer shall be used. 1 meter of all cables used shall be exposed to the magnetic field.

### 4.7.4 DEVIATION FROM TEST STANDARD

No Deviation

#### 4.7.5 TEST SETUP



#### NOTE:

##### TABLETOP EQUIPMENT

The equipment shall be subjected to the test magnetic field by using the induction coil of standard dimension (1 m x 1 m). The induction coil shall then be rotated by 90 degrees in order to expose the EUT to the test field with different orientations.

##### FLOOR-STANDING EQUIPMENT

The equipment shall be subjected to the test magnetic field by using induction coils of suitable dimensions. The test shall be repeated by moving and shifting the induction coils, in order to test the whole volume of the EUT for each orthogonal direction. The test shall be repeated with the coil shifted to different positions along the side of the EUT, in steps corresponding to 50 % of the shortest side of the coil. The induction coil shall then be rotated by 90 degrees in order to expose the EUT to the test field with different orientations.



#### 4.7.6 TEST RESULTS

<b>TEST MODE</b>	See Item 2.2	<b>TEST VOLTAGE</b>	DC 300V
<b>ENVIRONMENTAL CONDITIONS</b>	22deg. C, 59% RH	<b>TESTED BY:</b> Heise	

<b>MAGNETIC FIELD DIRECTION</b>	<b>TESTING RESULT</b>	<b>REMARK</b>
X - Axis	A	30A/ m
Y - Axis	A	30A/ m
Z - Axis	A	30A/ m

**NOTE:** A: There is no change compared with the initial operation during the test.





## 5 PHOTOGRAPHS OF THE TEST CONFIGURATION

### CONDUCTED EMISSION TEST



RADIATED EMISSION TEST



Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China

Tel: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

Page 60 of 66

Report Version 1

Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd.,  
Houjie Town, Dongguan City, Guangdong  
523942, China

Page 90 of 123

Tel: +86 769 8593 5656  
Fax: +86 769 8599 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)  
TEST REPORT C11/C10 VER.0

HARMONICS EMISSION TEST &  
VOLTAGE FLUCTUATIONS AND FLICKER TEST



ESD TEST



Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China

Tel: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)

RS TEST



EFT TEST(AC Mains)



Test Report No.: CE140508N005R1

EFT TEST (DC Port)



SURGE TEST



CONDUCTED SUSCEPTIBILITY TEST (AC Mains)



CONDUCTED SUSCEPTIBILITY TEST (DC Cable)



POWER-FREQUENCY MAGNETIC FIELDS TEST



## 6 APPENDIX A – MODIFICATIONS RECORDERS FOR ENGINEERING CHANGES TO THE EUT BY THE LAB

No any modifications were made to the EUT by the lab during the test.


---END---



## PHOTOGRAPHS OF THE EUT

SOFAR 1100TL:












Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China


Tel.: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)



Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch

No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China


Tel.: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)



SOFAR 2200TL:








Bureau Veritas Shenzhen Co., Ltd.  
Dongguan Branch


No. 34, Chenwulu Section, Guantai Rd., Houjie  
Town, Dongguan City,  
Guangdong 523942, China

Tel.: +86 769 8593 5656  
Fax: +86 769 8593 1080  
Email: [customerservice.dg@cn.bureauveritas.com](mailto:customerservice.dg@cn.bureauveritas.com)











SOFAR 3000TL:












# Annex 2

## Pictures of the unit

**Enclosure front view**




**Enclosure rear view**



### Enclosure bottom view




### Internal view-1



**Internal view-2**



**Internal view-3**



Internal view-4




Main power board component side view




**Main power board solder side view**




**Control board component side view**



**Control board solder side view**




**Display board component side view**





### Display board solder side view



# Annex 3

## Test equipment list

Equipment	Internal No.	Manufacturer	Type	Serial No.	Last Calibration
Power Analyzer	A4080002DG	YOKOGAWA	WT3000	91M210852	Mar. 12, 2014
AC Source	A7040019DG	Chroma	61512	61512000439	Monitored by Power Analyzer
AC Source	A7040020DG	Chroma	61512	61512000438	Monitored by Power Analyzer
DC Simulation Power Supply	A7040015DG	Chroma	62150H-1000S	62150EF00488	Monitored by Power Analyzer
DC Simulation Power Supply	A7040016DG	Chroma	62150H-1000S	62150EF00490	Monitored by Power Analyzer
Four Channel Digital Phosphor Oscilloscope	A4089003DG	Tektronix	DPO4104B	C010624	Oct. 17, 2013
Current transducer	A1060007DG	YOKOGAWA	CT200	1130700012	Jan 20, 2014
RLC Load	A7150027DG	Qunling	ACLT-3803H	93VOO2869	Monitored by Power Analyzer
Oscilloscope probe	A4089010DG	Tektronix	TPP1000	C008228	Dec. 20, 2013
Oscilloscope probe	A4089011DG	Tektronix	TPP1000	C008229	Dec. 20, 2013
LCR Hitester	A1060006DG	HIOKI	3535	120112505	Mar. 06, 2014