




TEST REPORT



AS_NZS 4777.2

Grid connection of energy systems via inverters

Part 2: Inverter requirements

Report reference number	PVAU200224N005-5-R1
Date of issue	2021-03-23
Total number of pages	38
Testing laboratory name	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch
Address	No. 96, Guantai Road (Houjie Section), Houjie Town, Dongguan City, Guangdong Province, 523942, People's Republic of China
Applicant's name	Shenzhen SOFAR SOLAR Co., Ltd.
Address	401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China.
Test specification	
Standard	Short duration under voltage response test (LVRT capability) - Inverter Conformance Test Procedure For South Australia
Test report form number.....	LVRT For South Australia VER.0
Master TRF originator	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch
Matster TRF	Dated 2020-08-13
Test item description	Grid connected photovoltaic inverter
Trademark	
Model / Type.....	SOFAR 10000TL-Sx Series, SOFAR 15000TL-Sx Series, SOFAR 17000TL-Sx Series, SOFAR 20000TL-Sx Series,
<small>This report is governed by, and incorporates by reference, CPS Conditions of Service as posted at the date of issuance of this report at http://www.bureauveritas.com/home/about-us/our-business/cps/about-us/terms-conditions and is intended for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. The results set forth in this report are not indicative or representative of the quality or characteristics of the lot from which a test sample was taken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. Measurement uncertainty is only provided upon request for accredited tests. You have 60 days from date of issuance of this report to notify us of any material error or omission caused by our negligence or if you require measurement uncertainty; provided, however, that such notice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise such issue within the prescribed time shall constitute your unqualified acceptance of the completeness of this report, the tests conducted and the correctness of the report contents.</small>	

Ratings	SOFAR 10000TL-Sx Series	SOFAR 15000TL-Sx Series	SOFAR 17000TL-Sx Series	SOFAR 20000TL-Sx Series
Maximum input DC voltage [V]	1000			
Operating input DC voltage range [V]:	250 - 960			
Full load MPPT input DC voltage range [V]	350 - 850	370 - 850	420 - 850	430 - 850
Input DC current [A]	Max. 15,0 x 2	Max. 21,0 x 2		Max. 24,0 x 2
Output AC voltage [V]	230, 50Hz			
Output AC current [A].....	Max. 3 x 15,0	Max. 3 x 22,0	Max. 3 x 25,0	Max. 3 x 29,0
Output power [VA].....	10000	15000	17000	20000

Testing Location.....:	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch
Address	No. 96, Guantai Road (Houjie Section), Houjie Town, Dongguan City, Guangdong Province, 523942, People's Republic of China
Tested by (name, function and signature)	Lukes Lin 
Approved by (name, function and signature)	James Huang 
Manufacturer's name	Shenzhen SOFAR SOLAR Co., Ltd.
Factory address.....	401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China.
Factory's name	Dongguan SOFAR SOLAR Co.,Ltd.
Factory address	1F - 6F, Building E, No. 1 JinQi Road, Bihu Industrial Park, Wulian Village, Fenggang Town, Dongguan City

Document History			
Date	Internal reference	Modification / Change / Status	Revision
2020-09-22	Lukes Lin	Initial report was written	0
2021-03-23	Lukes Lin	Update test results of VDRT	R1
Supplementary information:			

Test items particulars	
Equipment mobility	Permanent connection
Operating condition	Continuous
Class of equipment.....	Class I
Protection against ingress of water ..	IP65 according to EN 60529
Mass of equipment [kg]	45kg for SOFAR 10000TL-Sx Series, SOFAR 15000TL-Sx Series; 48kg for SOFAR 17000TL-Sx Series, SOFAR 20000TL-Sx Series;
Test case verdicts	
Test case does not apply to the test object	N/A
Test item does meet the requirement	P(ass)
Test item does not meet the requirement	F(ail)
Testing	
Date of receipt of test item	2020-09-11
Date(s) of performance of test	2020-09-11 to 2020-09-14, 2021-03-22
General remarks:	
<p>The test result presented in this report relate only to the object(s) tested.</p> <p>The report shall state compliance of the tested objects with the requirements of Short Duration Undervoltage Disturbance Ride-Through – Inverter Conformance Test Procedure for South Australia.</p> <p>This report must not be reproduced in part or in full without the written approval of the issuing testing laboratory.</p> <p>"(see Annex #)" refers to additional information appended to the report.</p> <p>"(see appended table)" refers to a table appended to the report.</p> <p>Throughout this report a comma is used as the decimal separator.</p>	

Copy of marking plate

SOFAR SOLAR Solar Inverter
光伏并网逆变器

Sofar 10000TL-Sx Series

Max. DC input voltage(最大直流输入电压):	1000V
Operating MPPT voltage range(MPPT电压范围):	250-960V
Max. Input current(最大输入电流):	2x15A
Max. PV Isc(最大输入短路电流):	2x20A
Nominal Grid Voltage(额定电网电压):	3/N/PE, 230/400V~
Max. Output Current(最大输出电流):	3x15A
Nominal Grid Frequency(额定电网频率):	50Hz
Max. Output power(最大输出功率):	10000VA
Power factor(功率因数):	>0.99(adjustable+/-0.8)
Ingress protection(IP等级):	IP65
Operating Temperature Range(运行环境温度):	-25-+60°C
Protective Class(保护级别):	Class I
Made in China(中国制造)	

Manufacturer: Shenzhen SOFARSOLAR Co., Ltd.
制造商: 深圳市首航新能源有限公司
SAA140078
VDE0126-1-1, VDE-AR-N4105, G83/2, EN50438, C10/11, RD1699, UTE C15-712-1, AS4777



SOFAR SOLAR Solar Inverter
光伏并网逆变器

Sofar 15000TL-Sx Series

Max. DC input voltage(最大直流输入电压):	1000V
Operating MPPT voltage range(MPPT电压范围):	250-960V
Max. Input current(最大输入电流):	2x21A
Max. PV Isc(最大输入短路电流):	2x27A
Nominal Grid Voltage(额定电网电压):	3/N/PE, 230/400V~
Max. Output Current(最大输出电流):	3x22A
Nominal Grid Frequency(额定电网频率):	50Hz
Max. Output power(最大输出功率):	15000VA
Power factor(功率因数):	>0.99(adjustable+/-0.8)
Ingress protection(IP等级):	IP65
Operating Temperature Range(运行环境温度):	-25-+60°C
Protective Class(保护级别):	Class I
Made in China(中国制造)	

Manufacturer: Shenzhen SOFARSOLAR Co., Ltd.
制造商: 深圳市首航新能源有限公司
SAA140078
VDE0126-1-1, VDE-AR-N4105, G59/3, IEC61727, IEC62116, C10/11, RD1699, UTE C15-712-1, AS4777



SOFAR SOLAR Solar Inverter
光伏并网逆变器

Sofar 17000TL-Sx Series

Max. DC input voltage(最大直流输入电压):	1000V
Operating MPPT voltage range(MPPT电压范围):	250-960V
Max. Input current(最大输入电流):	2x21A
Max. PV Isc(最大输入短路电流):	2x27A
Nominal Grid Voltage(额定电网电压):	3/N/PE, 230/400V~
Max. Output Current(最大输出电流):	3x25A
Nominal Grid Frequency(额定电网频率):	50Hz
Max. Output power(最大输出功率):	17000VA
Power factor(功率因数):	>0.99(adjustable+/-0.8)
Ingress protection(IP等级):	IP65
Operating Temperature Range(运行环境温度):	-25-+60°C
Protective Class(保护级别):	Class I
Made in China(中国制造)	

Manufacturer: Shenzhen SOFARSOLAR Co., Ltd.
制造商: 深圳市首航新能源有限公司
SAA140078
VDE0126-1-1, VDE-AR-N4105, G59/3, IEC61727, IEC62116, C10/11, RD1699, UTE C15-712-1, AS4777



SOFAR SOLAR Solar Inverter
光伏并网逆变器

Sofar 20000TL-Sx Series

Max. DC input voltage(最大直流输入电压):	1000V
Operating MPPT voltage range(MPPT电压范围):	250-960V
Max. Input current(最大输入电流):	2x24A
Max. PV Isc(最大输入短路电流):	2x30A
Nominal Grid Voltage(额定电网电压):	3/N/PE, 230/400V~
Max. Output Current(最大输出电流):	3x29A
Nominal Grid Frequency(额定电网频率):	50Hz
Max. Output power(最大输出功率):	20000VA
Power factor(功率因数):	>0.99(adjustable+/-0.8)
Ingress protection(IP等级):	IP65
Operating Temperature Range(运行环境温度):	-25-+60°C
Protective Class(保护级别):	Class I
Made in China(中国制造)	

Manufacturer: Shenzhen SOFARSOLAR Co., Ltd.
制造商: 深圳市首航新能源有限公司
SAA140078
VDE0126-1-1, VDE-AR-N4105, G59/3, IEC61727, IEC62116, C10/11, RD1699, UTE C15-712-1, AS4777



Inverter topology: Non-isolated

DRM 0	<input checked="" type="checkbox"/>	DRM 1	<input type="checkbox"/>	DRM 2	<input type="checkbox"/>
DRM 3	<input type="checkbox"/>	DRM 4	<input type="checkbox"/>	DRM 5	<input checked="" type="checkbox"/>
DRM 6	<input checked="" type="checkbox"/>	DRM 7	<input checked="" type="checkbox"/>	DRM 8	<input checked="" type="checkbox"/>

General product information:

The Solar converter converts DC voltage into AC voltage.

The DC input of Solar converter can be supplied from PV array.

The input and output are protected by Varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high power switching bridge and a two relays. This assures that the opening of the output circuit will also operate in case of one error.

Description of the electrical circuit: (Figure 1):

The internal control is redundant built. It consists of Microcontroller Controller A (UC20) and Controller B (UC73).

The Controller A (UC20) control the relays (RLB1-RLB6) by switching signals; measures the PV voltage, PV current, Bus voltage, grid voltage, frequency, AC current with injected DC and the array insulation resistance to ground. In addition it tests the current sensors and the RCMU circuit before each start up.

The Controller B (UC73) is measures the grid voltage, AC current, grid frequency and residual current, also can switch off the relays (RLB1-RLB6) independently, and communicate with Controller A (UC20) each other.

The current is measured by a current sensor. The AC current signal and the injected DC current signal are sent to the Master DSP. The Master DSP tests and calibrates before each start up all current sensors.

The unit provides two relays in series in all output conductors. When single fault applied to one relay, alarm an error code in display panel, another redundant relay provides basic insulation maintained between the PV array and the mains. All the relays are tested before each start up.




Figure 1 – Block diagram

Differences of the models in the series:

The models SOFAR 10000TL-Sx Series, SOFAR 15000TL-Sx Series, SOFAR 17000TL-Sx Series and SOFAR 20000TL-Sx Series are same as in hardware except the components are in the difference table. Identical in software the output power just adjusted by software.

Difference table				
	Sofar10000TL-Sx Serise	Sofar15000TL-Sx Serise	Sofar17000TL-Sx Serise	Sofar20000TL-Sx Serise
Input sample resistance of current: REA71, REA73, REA79, REA81	10Kohm/1/10W/F/0603	13Kohm/1/10W/F/0603	13Kohm/1/10W/F/0603	15Kohm/1/10W/F/0603
Output sample resistance of current: RB46, RB52, RB58, RB79, RB81, RB95	1.5Kohm/1/10W/F/0603	2Kohm/1/10W/F/0603	2Kohm/1/10W/F/0603	2.7Kohm/1/10W/F/0603
Output sample resistance of current: RB47, RB53, RB59, RB80, RB82, RB96	30ohm/1/10W/F/0603	30ohm/1/10W/F/0603	330ohm/1/10W/F/0603	30ohm/1/10W/F/0603
Full BUS Capacitor: CA129, CA131, CA145, CA148	2pcs (CA129, CA145,) (25UF/1100V/57.5*35*50)	3pcs (CA129, CA145, CA148), (25UF/1100V/57.5*35*50)	4pcs (CA129, CA131, CA145, CA148), (25UF/1100V/57.5*35*50)	4pcs (CA129, CA131, CA145, CA148), (25UF/1100V/57.5*35*50)
Half BUS Capacitor: CD1, CD2, CD3, CD4, CD5, CD6, CD7, CD8, CD39, CD40	4pcs (CD1, CD2, CD3, CD4), (75UF/700Vdc/57.5*35*50)	6pcs (CD1, CD2, CD3, CD4, CD5, CD6), (75UF/700Vdc/57.5*35*50)	8pcs (CD1, CD2, CD3, CD4, CD5, CD6, CD7, CD8), (75UF/700Vdc/57.5*35*50)	10pcs (CD1, CD2, CD3, CD4, CD5, CD6, CD7, CD8, CD39, CD40), (75UF/700Vdc/57.5*35*50)
IGBT module: QD1, QD2, QD3	FZ12NMA040SH-M267F	FZ12NMA040SH-M267F	10-FZ12NMA080SH01-M260F	10-FZ12NMA080SH01-M260F
Boosting diode	2pcs (DA20, DA25, SC S220KE2)	4pcs (DA19, DA20, DA24, DA25, SCS220 KE2)	4pcs (DA19, DA20, DA24, DA25, SCS220 KE2)	4pcs (DA19, DA20, DA24, DA25, SCS220 KE2)
Boosting IGBT: QA19, QA20, QA28, QA29	2pcs FGH40T120SMD-F155 (QA20, QA28, QA29)	4pcs FGH40T120SMD-F155 (QA19, QA20, QA28, QA29)	4pcs FGY40T120SMD (QA19, QA20, QA28, QA29)	4pcs FGY40T120SMD (QA19, QA20, QA28, QA29)
Boosting conductor	2pcs 10KW Boost/MS226060-2*4/2.7mH+/-10/90mΩ MAX/P7&P12	2pcs 15KW/17KW BOOST/2100uH/AMCC80/φ2.1*3P/21A/CUT-80	2pcs 15KW/17KW BOOST/2100uH/AMCC80/φ2.1*3P/21A/CUT-80	2pcs 20KW BOOST/1.8mH±10%/AMCC80/CUT-80
INT conductor	3pcs 10KW INV/MS226060-2*4/1.38mH+/-10/47mΩ MAX/P1/R	3pcs 15KW 960uH/AMCC63/φ2.1*3P/22A/CUT-63	3pcs 17KW 850uH/AMCC80/φ2.3*3P/25A/CUT-80	3pcs 20KW 0.73mH±10%/AMCC80/CUT-80
internal fan	without	with	with	with

Model difference table			
		AC SPD	DC SPD
Sofar10000TL Sx;			
Sofar15000TL Sx;	x=2	with out	with out
Sofar17000TL Sx;	x=4	with out	contain
Sofar20000TL Sx;	x=5	contain	contain

The product was tested on:

Hardware Version: V2.0

Software Version: V4.40

Test Results

1 General test and reporting requirements		
Clause	Requirement – Test	Verdict
1.1	General	P
1.2	Test condition	P
1.3	Inverter setup	P
1.4	Grid source	P
2 Test procedure		
2.1	General	P
2.2	Undervoltage (V<) disconnection test in response to event duration exceeding trip delay time	P
2.3	Undervoltage (V<) withstand test in response to event duration of less than trip delay time	P

2.2 Under voltage (V<) trip setting of disconnection test in response to event duration exceeding trip delay time								P
L1 phase								
Output Current level: 50+/-5% of rated current								
Test	Voltage (V)			Time to disconnect (s) (Trip delay 1s)			Time to reconnection (s)	
Limit	--			<=2s			>=60s	
Grid source voltage 230V down to 177,5 V (2,5 V below 180 V)	177,5			2,0			--	
Measured value	177,8	177,8	177,3	1,740	1,710	1,720	--	
Return the voltage (177.5 V) to the grid test voltage (230V)	230			--			--	
Measured value	230,1			--			67,0	
L2 phase								
Output Current level: 50+/-5% of rated current								
Test	Voltage (V)			Time to disconnect (s) (Trip delay 1s)			Time to reconnection (s)	
Limit	--			<=2s			>=60s	
Grid source voltage 230V down to 177,5 V (2,5 V below 180 V)	177,5			2,0			--	
Measured value	177,4	177,9	177,6	1,710	1,710	1,710	--	
Return the voltage (177.5 V) to the grid test voltage (230V)	230			--			--	
Measured value	230,1			--			67,0	
L3 phase								
Output Current level: 50+/-5% of rated current								
Test	Voltage (V)			Time to disconnect (s) (Trip delay 1s)			Time to reconnection (s)	
Limit	--			<=2s			>=60s	
Grid source voltage 230V down to 177,5 V (2,5 V below 180 V)	177,5			2,0			--	
Measured value	177,6	177,9	177,3	1,710	1,720	1,720	--	
Return the voltage (177.5 V) to the grid test voltage (230V)	230			--			--	
Measured value	230,2			--			67,0	

2.2 Under voltage (V<) trip setting of disconnection test in response to event duration exceeding trip delay time							P	
All phases								
Output Current level: 50+/-5% of rated current								
Test	Voltage (V)			Time to disconnect (s) (Trip delay 1s)			Time to reconnection (s)	
Limit	--			<=2s			>=60s	
Grid source voltage 230V down to 177,5 V (2,.5 V below 180 V)	177,5			2,0			--	
Measured value	177,8	177,8	177,9	1,525	1,520	1,510	--	
Return the voltage (177.5 V) to the grid test voltage (230V)	230			--			--	
Measured value	230,3			--			67,0	

2.2 Under voltage (V<) trip setting of disconnection test in response to event duration exceeding trip delay time

P

Test procedure:

The disconnection time for the protective function undervoltage (180 V) for a voltage step shall be confirmed. The procedure shall be as follows:

(a) Set the grid source equal to the grid test voltage. The energy source shall be varied until the a.c. output of the device under test equals $50 \pm 5\%$ of its rated current output.

NOTE: For three-phase inverters or inverter combinations, the required inverter output is based on the per phase inverter current rating.

(b) The grid source voltage shall be stepped to 177.5 V (2.5 V below 180 V) with the step change completed within 2 ms and occurring at the zero crossing of the grid source voltage. The time interval between the start of the voltage step and the device under test disconnecting from the grid source shall be recorded.

(c) Adjust the grid source to return the voltage to the grid test voltage. The reconnection time (the time taken for the device under test to reconnect to the grid source) shall be recorded.

Note:

The Voltage required to trip is the setting 177.5V (180V minus 2.5V). The time delay can be measured at a larger deviation than the minimum required to operate the protection. It has to be in the range of $\pm 2,3V$ of the grid test voltage.

Diagram of under-voltage protection: L1 phase



Diagram of under-voltage protection: L2 phase



Diagram of under-voltage protection: L3 phase




Diagram of under-voltage protection: All phase



2.3 Undervoltage (V<) withstand test in response to event duration of less than trip delay time

Test procedure




Figure 1 – Test circuit of voltage limits

The trip delay requirement for the protective function undervoltage 1 (V <) of 180 V for a voltage step shall be confirmed. The procedure shall be as follows:

(d) Set the grid source equal to the grid test voltage. Vary the energy source until the a.c. output of the device under test equals $50 \pm 5\%$ of its rated current output.

NOTE: For three-phase inverters or inverter combinations, the required inverter output is based on the per phase inverter current rating.




(e) Record the stabilised active power output.

(f) Step the grid source voltage down to 50 V with the step change completed within 2 ms and occurring at the zero crossing of the grid source voltage, remain at 50 V for 220 ms. Increase the grid source voltage to the grid test voltage with the step change completed within 2 ms and occurring at the zero crossing of the grid source voltage. Record the time interval between each voltage step passing through 180 V (i.e. the duration for which voltage lies below 180 V).

NOTE: For three phase systems, the test shall be conducted at the zero-crossing for each phase individually, and additionally for all three phases stepped together at the zero-crossing for one of the phases.

(g) After 1 second, record the active power output, and confirm it is equal to that recorded at Step (e) $\pm 4\%$.

NOTE: There is no defined behaviour of the inverter during the simulated fault. Monitor and recording at this stage is to better understand the anticipated inverter response.

List of tests	Residual amplitude of phase-to-neutral voltage V	Tolerance	Duration [ms]	Form (*)
Type for single phase inverter				
test 1 one-phase symmetrical fault	50V	$\pm 0,01U_n$	220	
Type for three phase inverter				
test 1 a) one-phase: L1 symmetrical fault	50V	$\pm 0,01U_n$	220	
test 1 b) one-phase: L1 symmetrical fault	50V	$\pm 0,01U_n$	220	



test 1 c) one-phase: L1 symmetrical fault	50V	$\pm 0,01Un$	220	
test 2 a) one-phase: L2 symmetrical fault	50V	$\pm 0,01Un$	220	
test 2 b) one-phase: L2 symmetrical fault	50V	$\pm 0,01Un$	220	
test 2 c) one-phase: L2 symmetrical fault	50V	$\pm 0,01Un$	220	
test 3 a) one-phase: L3 symmetrical fault	50V	$\pm 0,01Un$	220	
test 3 b) one-phase: L3 symmetrical fault	50V	$\pm 0,01Un$	220	
test 3 c) one-phase: L3 symmetrical fault	50V	$\pm 0,01Un$	220	
test 4 a) all-phase: L1, L2, L3 symmetrical fault	50V	$\pm 0,01Un$	220	
test 4 b) all-phase: L1, L2, L3 symmetrical fault	50V	$\pm 0,01Un$	220	
test 4 c) all-phase: L1, L2, L3 symmetrical fault	50V	$\pm 0,01Un$	220	

Criteria for acceptance

- a. The device under test shall remain connected for the duration of test step (f).
- b. At Step (g) the device under test shall have recovered its active power output to that recorded at Step (e) $\pm 4\%$ within 1 second.

Graph of LVRT testing

Output Current level: 50+/-5% of rated current				
List of tests	Residual amplitude of phase-to-phase voltage (V)	Duration limit of Voltage dips [ms]	Measured duration [ms]	Measured power recover time (ms)
L1 phase				
Test 1 a) – one-phase symmetrical fault	50	220	221	33
Test 1 b) – one-phase symmetrical fault	50	220	221	31
Test 1 c) – one-phase symmetrical fault	50	220	222	33
Test voltage	Voltage 230V +/- 1%			
Before test - Active power output (W)	10,283	10,377	10,283	
After test - Active power output(W) after 1s	10,281	10,383	10,288	
Limit(%)	+/- 4 %	+/- 4 %	+/- 4 %	
L2 phase				
Test 2 a) – one-phase symmetrical fault	50	220	222	33
Test 2 b) – one-phase symmetrical fault	50	220	222	35
Test 2 c) one-phase symmetrical fault	50	220	222	35
Test voltage	Voltage 230V +/- 1%			
Before test - Active power output (W)	10,283	10,377	10,377	
After test - Active power output(W) after 1s	10,291	10,381	10,279	
Limit(%)	+/- 4 %	+/- 4 %	+/- 4 %	
L3 phase				
Test 3 a) – one-phase symmetrical fault	50	220	220	31
Test 3 b) – one-phase symmetrical fault	50	220	221	33
Test 3 c) one-phase symmetrical fault	50	220	221	27
Test voltage	Voltage 230V +/- 1%			
Before test - Active power output (W)	10,377	10,472	10,377	
After test - Active power output(W) after 1s	10,372	10,419	10,377	

Graph of LVRT testing

Limit(%)	+/- 4 %	+/- 4 %	+/- 4 %
All (L1,L2,L3) phase			
Test 4 a) – All-phase symmetrical fault (P = 0,5)	50	220	31
Test 4 a) – All-phase symmetrical fault	50	220	31
Test 4 a) – All-phase symmetrical fault	50	220	30
Test voltage	Voltage 230V +/- 1%		
Before test - Active power output (W)	10,377	10,377	10,377
After test - Active power output(W) after 1s	10,379	10,381	10,371
Limit(%)	+/- 4 %	+/- 4 %	+/- 4 %


Test conditions:

Voltage simulator fall and rise time: < 2ms


The test conditions are performed as 50% ± 5% of In conditions. The inverter feeds maximal active and reactive power during the complete test.

Note:


Test 1 a) – one-phase symmetrical fault




Test 1 b) – one-phase symmetrical fault




Test 1 c) – one-phase symmetrical fault




Test 2 a) – one-phase symmetrical fault




Test 2 b) – one-phase symmetrical fault




Test 2 c) – one-phase symmetrical fault




Test 3 a) – one-phase symmetrical fault




Test 3 b) – one-phase symmetrical fault




Test 3 c) – one-phase symmetrical fault




Test 4 a) – all-phase symmetrical fault



Test 4 b) – all-phase symmetrical fault




Test 4 c) – all-phase symmetrical fault




Annex No. 1

Pictures of the unit

Enclosure front view




Enclosure rear view




Enclosure bottom view




Internal view-1



Internal view-2




Internal view-3




Internal view-4




Main power board component side view




Main power board solder side view




Control board component side view




Control board solder side view




Display board component side view




Display board solder side view




Communication board component side view




Communication board solder side view




AC EMI board component side view




AC EMI board solder side view



DC EMI board component side view



DC EMI board solder side view



Annex No. 2

Test Equipment list

Date(s) of performance test: 2020-09-11 to 2020-09-14

Equipment	Internal No.	Manufacturer	Type	Serial No.	Next calibration date
Power Analyser	A4080002DG	YOKOGAWA	WT3000	91M210852	Jun. 16, 2021
AC Source	A7040019DG	Chroma	61512	61512000439	Monitored by Power Analyser
AC Source	A7040020DG	Chroma	61512	61512000438	
DC Simulation Power Supply	A7040015DG	Chroma	62150H-1000S	62150EF00488	
DC Simulation Power Supply	A7040016DG	Chroma	62150H-1000S	62150EF00490	
DC Simulation Power Supply	A7040017DG	Chroma	620028	620028EF00120	
RLC Load	A7150027DG	Qunling	ACLT-3803H	93VOO2869	
Eight Channel Digital Phosphor Oscilloscope	A4089017DG	YOKOGAWA	DL850	91N726247	Sep. 24, 2020
Oscilloscope probe	A4089008DG	Tektronix	TPP1000	C008230	Aug. 10, 2021
Oscilloscope probe	A4089010DG	Tektronix	TPP1000	C008228	Aug. 10, 2021
Oscilloscope probe	A4089011DG	Tektronix	TPP1000	C008229	Aug. 10, 2021
Current transducer	A1060007DG	YOKOGAWA	CT200	1130700012	Sep. 02, 2021
Current transducer	A1060008DG	YOKOGAWA	CT200	1130700017	Sep. 02, 2021
Current transducer	A1060012DG	YOKOGAWA	CT200	1130700018	Sep. 02, 2021

End of Test Report