

**TESTING FOR THE VERIFICATION OF COMPLIANCE OF
PV INVERTER WITH :
ENGINEERING RECOMMENDATION G98 ISSUE 1-
AMENDMENT 3 MARCH 2019,
REQUIREMENTS FOR THE CONNECTION OF FULLY TYPE
TESTED MICRO-GENERATORS (UP TO AND INCLUDING
16 A PER PHASE) IN PARALLEL WITH PUBLIC LOW
VOLTAGE DISTRIBUTION NETWORKS ON OR AFTER 27
APRIL 2019**

Test Report Number: **GZES190701991201**

Type



Tested Model: **SOFAR 3.6KTLM-G2**

Variant Models: **SOFAR 3KTLM-G2**

APPLICANT

Hired by: Shenzhen SOFAR SOLAR Co., Ltd.
401, Building 4, AnTongDa Industrial Park, District 68,
Address: XingDong Community, XinAn Street, BaoAn District,
Shenzhen City, Guangdong Province, P.R. China.

TESTING LABORATORY

Name: SGS-CSTC Standards Technical Services Co., Ltd. - E&E
Lab Guangzhou

Address: 198 Kezhu Road, Sciencetech Park, Guangzhou Economic &
Technology Development District, Guangzhou, Guangdong,
China 510663

Conducted (tested) by: Michael Tong *Michael Tong*
(Project Engineer)

Approved by: Roger Hu *Roger Hu*
(Technical Reviewer)



Date of issue: **04/07/2019**

Number of pages: **122**

Important Note:

- This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.
- This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

Test Report Historical Revision:

| Test Report Version | Date | Resume |
|---------------------|----------------|---|
| GZES190101070001 | 27 / 05 / 2019 | First issuance |
| GZES190701991201 | 04 / 07 / 2019 | Update the Limited Frequency Sensitive Mode - Overfrequency test. |

INDEX

| | | |
|----------|--|------------|
| 1 | SCOPE | 4 |
| 2 | GENERAL INFORMATION | 5 |
| 2.1 | Testing Period and Climatic conditions | 5 |
| 2.2 | Equipment under Testing | 5 |
| 2.3 | Test equipment list | 8 |
| 2.4 | Measurement uncertainty | 9 |
| 2.5 | Test set up of the different standard | 10 |
| 2.6 | Definitions | 11 |
| 3 | RESUME OF TEST RESULTS..... | 12 |
| 4 | TEST RESULTS..... | 13 |
| 4.1 | Operating Range | 13 |
| 4.2 | Power Quality | 16 |
| 4.2.1 | Current Harmonics | 16 |
| 4.2.2 | Voltage fluctuations and Flicker | 19 |
| 4.2.3 | DC Injection | 22 |
| 4.2.4 | Power Factor | 23 |
| 4.3 | Protection | 25 |
| 4.3.1 | Frequency tests | 25 |
| 4.3.2 | Voltage tests | 46 |
| 4.3.3 | Loss of Mains test | 67 |
| 4.3.4 | Frequency change, Vector Shift Stability test and RoCoF Stability test | 96 |
| 4.4 | Limited Frequency Sensitive Mode - Overfrequency test | 99 |
| 4.5 | Power output with falling frequency test | 101 |
| 4.6 | Re-connection timer | 102 |
| 4.6.1 | Voltage Reconnection Conditions | 102 |
| 4.6.2 | Frequency Reconnection Conditions | 104 |
| 4.7 | Fault level contribution | 106 |
| 4.8 | Self-Monitoring solid state switching | 111 |
| 4.9 | Electromagnetic Compatibility (EMC) | 111 |
| 4.10 | Logic Interface | 112 |
| 5 | PICTURES | 113 |
| 6 | ELECTRICAL SCHEMES | 122 |

1 SCOPE

SGS-CSTC Standards Technical Services Co., Ltd. - E&E Lab Guangzhou has been contracted by Shenzhen SOFAR SOLAR Co., Ltd, in order to perform the testing according to the "ENGINEERING RECOMMENDATION G98 ISSUE 1 - AMENDMENT 3 March 2019, REQUIREMENTS FOR THE CONNECTION OF FULLY TYPE TESTED MICRO-GENERATORS (UP TO AND INCLUDING 16 A PER PHASE) IN PARALLEL WITH PUBLIC LOW VOLTAGE DISTRIBUTION NETWORKS ON OR AFTER 27 APRIL 2019".

2 GENERAL INFORMATION

2.1 TESTING PERIOD AND CLIMATIC CONDITIONS


The necessary testing has been performed along 12 working days between February 22, 2019 and May 14, 2019 and at July 3, 2019.

All the tests and checks have been performed at $25 \pm 5^{\circ}\text{C}$, $96 \text{ kPa} \pm 10 \text{ kPa}$ and $50\% \text{ RH} \pm 10\% \text{ RH}$).

SITE TEST

Name.....: Shenzhen SOFAR SOLAR Co., Ltd.
 Address.....: 401, Building 4, AnTongDa Industrial Park, District 68,
 XingDong Community, XinAn Street, BaoAn District,
 Shenzhen City, Guangdong Province, P.R. China.

2.2 EQUIPMENT UNDER TESTING

Apparatus type.....: Solar Grid-tied Inverter
 Installation.....: Fixed (permanent connection)
 Manufacturer.....: Shenzhen SOFAR SOLAR Co., Ltd.
 Address.....: 1F – 6F, Building E, No.1 JinQi Road, Bihu Industrial Park,
 Wulian Village, Fenggang Town, Dongguan, P.R. China.
 Trade mark.....: 
 Model / Type reference.....: SOFAR 3.6KTLM-G2
 Serial Number.....: SH1CS060JCM381
 Software Version.....: V1.50
 Rated Characteristics.....: DC input: 90-580V, 11/11A
 AC output: 230V, 50Hz, 16A, 3680VA

Date of manufacturing: 2018

Test item particulars

Input.....: DC
 Output.....: AC
 Class of protection against electric shock...: Class I
 Degree of protection against moisture.....: IP 65
 Type of connection to the main supply.....: TN
 Cooling group.....: Heat sink
 Modular.....: No
 Internal Transformer.....: No

Copy of marking plate:

| Solar Grid-tied Inverter | | Solar Grid-tied Inverter | |
|--|----------------------|--|----------------------|
| Model No: | SOFAR 3.6KTLM-G2 | Model No: | SOFAR 3KTLM-G2 |
| Max.DC Input Voltage | 600V | Max.DC Input Voltage | 600V |
| Operating MPPT Voltage Range | 90~580V | Operating MPPT Voltage Range | 90~580V |
| Max. Input Current | 2x11A | Max. Input Current | 2x11A |
| Max. PV Isc | 2x13.2A | Max. PV Isc | 2x13.2A |
| Nominal Grid Voltage | 230V | Nominal Grid Voltage | 230V |
| Max. Output Current | 16A | Max. Output Current | 13.7A |
| Nominal Grid Frequency | 50/60Hz | Nominal Grid Frequency | 50/60Hz |
| Nominal Output Power | 3680W | Nominal Output Power | 3000W |
| Max. Output Power | 3680VA | Max. Output Power | 3000VA |
| Power Factor | 1(adjustable +/-0.8) | Power Factor | 1(adjustable +/-0.8) |
| Ingress Protection | IP65 | Ingress Protection | IP65 |
| Operating Temperature Range | -25°C~+60°C | Operating Temperature Range | -25°C~+60°C |
| Protective Class | Class I | Protective Class | Class I |
| Inverter Topology | Non-Isolated | Inverter Topology | Non-Isolated |
| Manufacturer : Shenzhen SOFAR SOLAR Co.,Ltd. Address : 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community,XinAn Street, BaoAn District, Shenzhen, China | | Manufacturer : Shenzhen SOFAR SOLAR Co.,Ltd. Address : 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community,XinAn Street, BaoAn District, Shenzhen, China | |
| SAA 180100 VDE0126-1-1,G99,EN50438,AS4777,IEC62116,IEC61727 | | SAA 180100 VDE0126-1-1,G59/3,EN50438,C10/11, AS4777,RD1699,UTE C15-712-1 | |
| | | | |

Note:

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation.

Equipment Under Testing:

- SOFAR 3.6KTLM-G2

The variants models are:

- SOFAR 3KTLM-G2

The variants models are:

The variants models have been included in this test report without tests because the following features don't change regarding to the tested model:

- Same connection system and hardware topology
- Same control algorithm.
- Output power within 2.5 and 2/3 of the EUT or Modular inverters.
- Same Firmware Version

The results obtained apply only to the particular sample tested that is the subject of the present test report. The most unfavorable result values of the verifications and tests performed are contained herein. Throughout this report a point (~~comma~~) is used as the decimal separator.

2.3 TEST EQUIPMENT LIST

| From | No. | Equipment Name | MARK/Model No. | Equipment No. | Equipment calibration due date |
|-------------|-----|------------------------------|----------------------|-----------------------|--------------------------------|
| Sofar Solar | 1 | Digital oscilloscope | Agilent / DSO5014A | MY50070266 | 2020-02-12 |
| | 2 | Current clamp | FLUKE / i1000s | 29503223 | 2020-02-12 |
| | 3 | Current clamp | FLUKE / i1000s | 30413441 | 2020-02-12 |
| | 4 | Current clamp | FLUKE / i1000s | 30413448 | 2020-02-12 |
| | 5 | Differential probe | Sanhua / SI-9110 | 111541 | 2020-02-12 |
| | 6 | Differential probe | Sanhua / SI-9110 | 152627 | 2020-02-12 |
| | 7 | Differential probe | Sanhua / SI-9110 | 111134 | 2020-02-12 |
| | 8 | Power analyzer | ZLG / PA3000 | PA3005-P0005-1246 | 2020-02-12 |
| | 9 | Temperature & Humidity meter | Anymetre/ TH101B | 201030245220 | 2020-02-12 |
| | 10 | Power analyzer | Yokogawa / WT3000 | 91N610888 | 2020-02-12 |
| | 11 | Digital oscilloscope | KEYSIGHT / DSOX3024T | MY57251898 | 2020-02-12 |
| SGS | 12 | True RMS Multimeter | Fluke / 289C | SHES100602 (15100038) | 2020-01-06 |

2.4 MEASUREMENT UNCERTAINTY

Associated uncertainties through measurements showed in this this report are the maximum allowable uncertainties.


| Magnitude | Uncertainty |
|-----------------------|------------------------|
| Voltage measurement | $\pm 0.05\%$ |
| Current measurement | $\pm 0.05\%$ |
| Frequency measurement | $\pm 0.001\text{ Hz}$ |
| Time measurement | $\pm 0.001\text{ s}$ |
| Power measurement | $\pm 0.5\%$ |
| Phase Angle | $\pm 0.1^\circ$ |
| Temperature | $\pm 3^\circ\text{ C}$ |

Note1: Measurements uncertainties showed in this table are maximum allowable uncertainties. The measurement uncertainties associated with other parameters measured during the tests are in the laboratory at disposal of the solicitant.

Note2: Where the standard requires lower uncertainties that those in this table. Most restrictive uncertainty has been considered.

2.5 TEST SET UP OF THE DIFFERENT STANDARD

Below is the simplified construction of the test set up.



Different equipment has been used to take measures as it shows in chapter 2.3. Current and voltage clamps have been connected to the inverter input / output for all the tests. All the tests described in the following pages have used this specified test setup.

The test bench used includes:

| No. | Equipment Name | MARK/Model No. | Equipment No, |
|-----|--------------------|------------------|---------------|
| 1 | AC Source | Parwa / PVS7030T | 16100790 |
| 2 | PV Array Simulator | Chroma 62150H | BZ-EP-L002 |
| 3 | RLC Load | ACLT-38160H | BZ-DGD-L003 |

2.6 Definitions

| | | | |
|------------------|--|----------------|-------------------------------|
| EUT | Equipment Under Testing | Hz | Hertz |
| A | Ampere | V | Volt |
| VA _r | Volt-Ampere reactive | W | Watt |
| EMC | Electromagnetic Compatibility | p.u | Per unit |
| U _n | Nominal Voltage | P _n | Nominal Active Power |
| I _n | Nominal Current | Q _n | Nominal Reactive Power |
| I _a | Active Current | S _n | Nominal Apparent Power |
| I _r | Reactive Current | THD | Total Harmonic Distortion |
| I _h | Harmonic Current | TDD | Total Demand Distortion |
| PWHD | Partial Weighted Harmonic Distortion | PLT | Severity of Flicker Long-Term |
| PST | Severity of Flicker Short-Term | d(t) | Variation of Voltage |
| d _{max} | Maximum Absolute Value of Voltage Variation | OV | Over Voltage |
| UV | Under Voltage | OF | Over Frequency |
| | | UF | Under Frequency |

3 RESUME OF TEST RESULTS

INTERPRETATION KEYS

Test object does meet the requirement **P** Pass
 Test object does not meet the requirement..... **F** Fails
 Test case does not apply to the test object..... **N/A** Not applicable
 To make a reference to a table or an annex. See additional sheet
 To indicate that the test has not been realized **N/R** Not realized

| STANDAARD CLAUSE | STANDARD REQUIREMENTS | | RESULT |
|------------------------------|---|-------------------------------------|--------|
| | G98 Issue 1 Amendment 3 March 2019 | | |
| | TEST | REMARKS | |
| EN 50438 D.3.1. | Operating Range | | P |
| EREC G98 Annex A1 A1.3.1 | Harmonics | | P |
| EREC G98 Annex A1 A1.3.3 | Voltage fluctuations and Flicker | | P |
| EN 50438 Annex D.3.10 | DC injection | | P |
| EN 50538 Annex D.3.4.1 | Power factor | | P |
| EREC G98 Annex A1 A.1.2.3 | Frequency tests | | P |
| EREC G98 Annex A1 A.1.2.2 | Voltage tests | | P |
| BS EN 62116 | Loss of Mains test | | P |
| EREC G98 Annex A1 A.1.2.6 | Frequency change, Vector Shift Stability test | | P |
| EREC G98 Annex A1 A.1.2.6 | Frequency change, RoCoF Stability test | | P |
| EN 50438 Annex D.3.3 | Overfrequency test | | P |
| EN 50438 Annex D.3.2 | Power output with falling frequency test | | P |
| EN 50438 Annex A12 | Re-connection timer. | | P |
| EREC G98 Annex A1 A.1.3.5 | Fault level contribution | | P |
| EREC G98 Annex A1 A.1.3.6 | Self-Monitoring solid state switching | No solid state switching devices | N/A |
| EREC G98 Annex A1 A.1.3.7 | Electromagnetic Compatibility (EMC) | | P |

4 TEST RESULTS

4.1 Operating Range

This test should be carried out as specified in EN 50438 D.3.1.

Active Power shall be recorded every second. The tests will verify that the Micro-generator can operate within the required ranges for the specified period of time.

The Interface Protection shall be disabled during the tests.

In case of a PV Micro-generator the PV primary source may be replaced by a DC source.

In case of a full converter Micro-generator (eg wind) the primary source and the prime mover Inverter/rectifier may be replaced by a DC source.

In case of a DFIG Micro-generator the mechanical drive system may be replaced by a test bench motor.

Test 1:

Voltage = 85% of nominal (195.5 V)

Frequency = 47.5 Hz

Power factor = 1

Period of test 90 minutes

Test 2:

Voltage = 110% of nominal (253 V).

Frequency = 51.5 Hz

Power factor = 1

Period of test 90 minutes

Test 3:

Voltage = 110% of nominal (253 V).


Frequency = 52.0 Hz

Power factor = 1


Period of test 15 minutes

Test results are graphically shown in following pages.


Test 1



Test 2



Test 3



4.2 POWER QUALITY

4.2.1 Current Harmonics

The tests should be carried out as specified in BS EN 61000-3-2 and can be undertaken with a fixed source of energy at two power levels firstly between 45 and 55% and at 100% of Registered Capacity. The test requirements are specified in Annex A1 A.1.3.1 (Inverter connected) or Annex A2 A.2.3.1 (Synchronous).

Measures have been repeated at 50%P_n and 100%P_n.

Following tables show the test results:


| Micro-generator rating per phase (rpp) | | | 3.68 | kW | | | |
|--|----------------------------------|-------|-----------------------------|-------|----------------------------------|---|--|
| Harmonic | At 45-55% of Registered Capacity | | 100% of Registered Capacity | | | | |
| | Measured Value MV in Amps | Ih(%) | Measured Value MV in Amps | Ih(%) | Limit in BS EN 61000-3-2 in Amps | Higher limit for odd harmonics 21 and above | |
| 2 | 0.003 | 0.019 | 0.005 | 0.031 | 1.080 | | |
| 3 | 0.114 | 0.713 | 0.194 | 1.213 | 2.300 | | |
| 4 | 0.004 | 0.025 | 0.003 | 0.019 | 0.430 | | |
| 5 | 0.086 | 0.538 | 0.111 | 0.694 | 1.140 | | |
| 6 | 0.004 | 0.025 | 0.004 | 0.025 | 0.300 | | |
| 7 | 0.078 | 0.488 | 0.085 | 0.531 | 0.770 | | |
| 8 | 0.003 | 0.019 | 0.004 | 0.025 | 0.230 | | |
| 9 | 0.067 | 0.419 | 0.084 | 0.525 | 0.400 | | |
| 10 | 0.002 | 0.013 | 0.004 | 0.025 | 0.184 | | |
| 11 | 0.062 | 0.388 | 0.087 | 0.544 | 0.330 | | |
| 12 | 0.002 | 0.013 | 0.002 | 0.013 | 0.153 | | |
| 13 | 0.047 | 0.294 | 0.071 | 0.444 | 0.210 | | |
| 14 | 0.003 | 0.019 | 0.002 | 0.013 | 0.131 | | |
| 15 | 0.038 | 0.238 | 0.060 | 0.375 | 0.150 | | |
| 16 | 0.002 | 0.013 | 0.002 | 0.013 | 0.115 | | |
| 17 | 0.026 | 0.163 | 0.043 | 0.269 | 0.132 | | |

ENA Engineering Recommendation G98 Issue 1 Amendment 3 2019


| | | | | | | |
|----|-------|-------|-------|-------|-------|-------|
| 18 | 0.002 | 0.013 | 0.003 | 0.019 | 0.102 | |
| 19 | 0.013 | 0.081 | 0.030 | 0.188 | 0.118 | |
| 20 | 0.002 | 0.013 | 0.002 | 0.013 | 0.092 | |
| 21 | 0.012 | 0.075 | 0.025 | 0.156 | 0.107 | 0.160 |
| 22 | 0.002 | 0.013 | 0.002 | 0.013 | 0.084 | |
| 23 | 0.006 | 0.038 | 0.009 | 0.056 | 0.098 | 0.147 |
| 24 | 0.004 | 0.025 | 0.004 | 0.025 | 0.077 | |
| 25 | 0.004 | 0.025 | 0.009 | 0.056 | 0.090 | 0.135 |
| 26 | 0.003 | 0.019 | 0.002 | 0.013 | 0.071 | |
| 27 | 0.007 | 0.044 | 0.007 | 0.044 | 0.083 | 0.124 |
| 28 | 0.003 | 0.019 | 0.004 | 0.025 | 0.066 | |
| 29 | 0.002 | 0.013 | 0.005 | 0.031 | 0.078 | 0.117 |
| 30 | 0.002 | 0.013 | 0.002 | 0.013 | 0.061 | |
| 31 | 0.002 | 0.013 | 0.010 | 0.063 | 0.073 | 0.109 |
| 32 | 0.005 | 0.031 | 0.003 | 0.019 | 0.058 | |
| 33 | 0.011 | 0.069 | 0.009 | 0.056 | 0.068 | 0.102 |
| 34 | 0.001 | 0.006 | 0.003 | 0.019 | 0.054 | |
| 35 | 0.006 | 0.038 | 0.007 | 0.044 | 0.064 | 0.096 |
| 36 | 0.003 | 0.019 | 0.002 | 0.013 | 0.051 | |
| 37 | 0.003 | 0.019 | 0.007 | 0.044 | 0.061 | 0.091 |
| 38 | 0.002 | 0.013 | 0.006 | 0.038 | 0.048 | |
| 39 | 0.003 | 0.019 | 0.014 | 0.088 | 0.058 | 0.087 |
| 40 | 0.004 | 0.025 | 0.002 | 0.013 | 0.046 | |

Note the higher limits for odd harmonics 21 and above are only allowable under certain conditions, if these higher limits are utilised please state the exemption used as detailed in part 6.2.3.4 of BS EN 61000-3-2 in the box below.

Current Harmonics



THD



4.2.2 Voltage fluctuations and Flicker

These tests should be undertaken in accordance with EREC G98 Annex A1 A.1.3.3 (Inverter connected) or Annex A2 A.2.3.3 (Synchronous).

The measurements of voltage fluctuations have been measured according to the standard, at 100 % of the nominal power value of the inverter.

The test impedance is recorded in the table below:

| | | | | | | |
|--------------------|---|-----|----------|---|------|----------|
| Test Impedance | R | 0.4 | Ω | X | 0.25 | Ω |
| Standard Impedance | R | 0.4 | Ω | X | 0.25 | Ω |
| Maximum Impedance | R | 0.4 | Ω | X | 0.25 | Ω |

| Starting operation and Stopping operation | | | |
|---|---------------|--------------------------|--------------------------|
| Pbin (%) | 100% | | |
| | Limit | Starting measured values | Stopping measured values |
| PST | ≤ 1 | 0.28 | 0.12 |
| PLT | ≤ 0.65 | 0.13 | 0.13 |
| dc | $\leq 3.30\%$ | 0.08 | 0.14 |
| d(t) | $\leq 3.30\%$ | 0 | 0 |
| dmax | 4% | 0.44% | 0.41% |

As it can be seen in the next screenshots, this test has two steps:

1. Starting operation
2. Stopping operation

All values are the most unfavorable of the two steps.

Starting operation and Stopping operation

100% Pn

Flicker Mode Uover: ■ ■ ■ ■ I1-3 : 30A YOKOGAWA ◆
 Iover: ■ ■ ■ ■ Flicker: Complete 0:20:00
 Count ████████████████████ 2/2
 Interval ████████████████████ 10m00s/10m00s
 Element 1
 Volt Range 600V/50Hz Element1 Judgement: Pass
 Un (Set) 230.000 V Total Judgement: Pass
 Freq(U1) 49.999 Hz (Element1,2,3)

| | dc[%] | dmax[%] | d(t)[ms] | Pst | P1t |
|--------|-----------|-----------|----------------|-----------|--------------|
| Limit | 3.30 | 4.00 | 500 3.30(%) | 1.00 | 0.65 N:12 |
| No. 1 | 0.08 Pass | 0.44 Pass | 0 Pass | 0.28 Pass | |
| 2 | 0.14 Pass | 0.41 Pass | 0 Pass | 0.12 Pass | |
| Result | Pass | Pass | Pass | Pass | 0.13 Pass |

Update 600

2019/05/14 18:30:16

ENA Engineering Recommendation G98 Issue 1 Amendment 3 2019

| Running operation 2 hours | | |
|----------------------------------|--------------|------------------------|
| Pbin (%) | 100% | |
| | Limit | Measured values |
| PST | ≤ 1 | 0.38 |
| PLT | ≤ 0.65 | 0.29 |
| dc | ≤ 3.30% | 0.57% |
| d(t) | ≤ 3.30% | 0 |
| dmax | 4% | 1.96% |

As it can be seen in the next screenshots is running operation. The values took of Pst and Plt are the most unfavorable of the twelve steps.


| Running operation | | | | | |
|-----------------------------|--------------|------------------------------------|-----------------|---------------------------|---------------|
| 100% Pn | | | | | |
| Flicker Mode | | Uover: ■ ■ ■ ■ | | YOKOGAWA ◆ | |
| | | Iover: ■ ■ ■ ■ | | Flicker: Complete 2:00:00 | |
| Count | | ■■■■■■■■■■■■■■■■■■■■ 12/12 | | | |
| Interval | | ■■■■■■■■■■■■■■■■■■■■ 10m00s/10m00s | | | |
| Element 1 | | Element1 Judgement: Pass | | | |
| Volt Range 300v/50Hz | | Total Judgement: Pass | | | |
| Un (Set) 230.000 V | | (Element1) | | | |
| Freq(U1) 49.969 Hz | | | | | |
| | dc[%] | dmax[%] | d(t)[ms] | Pst | Plt |
| Limit | 3.30 | 4.00 | 500 3.30(%) | 1.00 | 0.65 N: 12 |
| No. 1 | 0.08 Pass | 1.06 Pass | 0 Pass | 0.27 Pass | |
| 2 | 0.30 Pass | 1.19 Pass | 0 Pass | 0.31 Pass | |
| 3 | 0.31 Pass | 1.75 Pass | 0 Pass | 0.31 Pass | |
| 4 | 0.11 Pass | 1.75 Pass | 0 Pass | 0.31 Pass | |
| 5 | 0.26 Pass | 1.50 Pass | 0 Pass | 0.28 Pass | |
| 6 | 0.33 Pass | 1.60 Pass | 0 Pass | 0.38 Pass | |
| 7 | 0.11 Pass | 1.10 Pass | 0 Pass | 0.26 Pass | |
| 8 | 0.34 Pass | 0.95 Pass | 0 Pass | 0.24 Pass | |
| 9 | 0.57 Pass | 1.22 Pass | 0 Pass | 0.26 Pass | |
| 10 | 0.48 Pass | 1.96 Pass | 0 Pass | 0.35 Pass | |
| 11 | 0.22 Pass | 0.53 Pass | 0 Pass | 0.19 Pass | |
| 12 | 0.23 Pass | 0.81 Pass | 0 Pass | 0.20 Pass | |
| Result | Pass | Pass | Pass | Pass | 0.29 Pass |
| Update 3600 | | 2019/04/10 12:01:26 | | | |

4.2.3 DC Injection

The DC component shall be measured under steady-state conditions for the following power levels: 20 %, 50 %, 75 %, and 100 % of nominal power with a tolerance of ± 5 % of nominal power and as far as adjustable for the tested micro-generator. These tests should be undertaken in accordance with Annex A1.3.4.

Following tables show the test results:

| Power quality – DC injection: This test should be carried out in accordance with EN 50438 Annex D.3.10 | | | | |
|---|-------|-------|-------|-------|
| Test power level | 20% | 50% | 75% | 100% |
| Recorded value in Amps | 0.005 | 0.006 | 0.006 | 0.003 |
| as % of rated AC current | 0.03% | 0.04% | 0.04% | 0.02% |
| Limit | 0.25% | 0.25% | 0.25% | 0.25% |




4.2.4 Power Factor

This test shall be carried out in accordance with EN 50538 Annex D.3.4.1 but with nominal voltage -6% and +10%. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test.


The following table shows the test results at required voltage levels:

| | 216.2 V | 230 V | 253 V |
|------------------------------------|---------|-------|-------|
| 20% of Registered Capacity | 0.96 | 0.96 | 0.97 |
| 50% of Registered Capacity | 0.99 | 0.99 | 0.99 |
| 75% of Registered Capacity | 0.99 | 0.99 | 0.99 |
| 100% of Registered Capacity | 0.99 | 0.99 | 0.99 |
| Limit | >0.95 | >0.95 | >0.95 |


Test results are graphically shown below.



Power Factor 230V



Power Factor 253V



4.3 PROTECTION

4.3.1 Frequency tests

These tests should be carried out in accordance with EN 50438 Annex D.2.4 and the notes in EREC G98 Annex A1 A.1.2.3 (Inverter connected) or Annex A2 A.2.2.3 (Synchronous).


To establish a trip frequency, the test frequency should be applied in a slow ramp rate of less than 0.1 Hz/s, or if this is not possible in steps of 0.05 Hz for a duration that is longer than the trip time delay.

To establish the trip time, the test frequency should be applied starting from 0.3 Hz below or above the recorded trip frequency and should be changed to 0.3 Hz above or below the recorded trip frequency in a single step. For each trip setting five tests shall be carried out.

Following tables show the test results:


| Function | Setting | | Trip test (5 times) | | "No trip tests" | |
|-------------|-----------|------------|---------------------|----------------|-------------------|-----------------|
| | Frequency | Time delay | Frequency (Hz) | Time delay (s) | Frequency /time | Confirm no trip |
| U/F stage 1 | 47.5 Hz | 20 s | 47.5 | 20.100 | 47.7 Hz / 25 s | Pass |
| | | | 47.5 | 20.150 | | |
| | | | 47.5 | 20.120 | | |
| | | | 47.5 | 20.065 | | |
| | | | 47.5 | 20.100 | | |
| U/F stage 2 | 47 Hz | 0.5 s | 47.0 | 0.528 | 47.2 Hz / 19.98 s | Pass |
| | | | 47.0 | 0.514 | | |
| | | | 47.0 | 0.512 | | |
| | | | 47.0 | 0.524 | | |
| | | | 47.0 | 0.524 | | |
| | | | | | 46.8 Hz / 0.48 s | Pass |
| O/F stage 1 | 52 Hz | 0.5 s | 52.0 | 0.530 | 51.8 Hz / 89.98 s | Pass |
| | | | 52.0 | 0.526 | | |
| | | | 52.0 | 0.536 | | |
| | | | 52.0 | 0.520 | | |
| | | | 52.0 | 0.534 | | |
| | | | | | 52.2 Hz / 0.48 s | Pass |

Test results are graphically shown below.




Agilent Technologies

SAT APR 06 15:48:31 2019



U/F stage 1



Agilent Technologies

SAT APR 06 15:50:50 2019

1 500V/ 2 50.0A/ 3 5.00V/ 4


5.000s/ Stop Roll

$\Delta X = 20.150000000000s$ $1/\Delta X = 49.628mHz$ $\Delta Y(1) = 0.0V$

Mode Manual Source 1 X Y X1 X2 X1 X2

-33.5500s -13.4000s

U/F stage 1



Agilent Technologies

SAT APR 06 15:54:09 2019

1 500V/ 2 50.0A/ 3 5.00V/ 4


5.000s/ Stop Roll

$\Delta X = 20.120000000000s$ $1/\Delta X = 49.702mHz$ $\Delta Y(1) = 0.0V$

Mode Manual Source 1 X Y X1 X2

X1 -33.7000s X2 -13.5800s X1 X2

U/F stage 1




Agilent Technologies

SAT APR 06 15:57:04 2019

1 500V/ 2 50.0A/ 3 5.00V/ 4 [Symbol] 5.000s/ Stop Roll

$\Delta X = 20.065000000000s$ $1/\Delta X = 49.838mHz$ $\Delta Y(1) = 0.0V$
 Mode Manual Source 1 X Y X1 -33.8700s X2 -13.8050s X1 X2

U/F stage 1



Agilent Technologies

SAT APR 06 16:00:13 2019

1 500V/ 2 50.0A/ 3 5.00V/ 4


5.000s/ Stop Roll

$\Delta X = 20.100000000000s$ $1/\Delta X = 49.751mHz$ $\Delta Y(1) = 0.0V$

Mode Manual Source 1 X Y X1 X2 X1 X2


-35.6000s -15.5000s

U/F stage 2




Agilent Technologies

SAT APR 06 14:59:51 2019




U/F stage 2




Agilent Technologies

SAT APR 06 15:01:28 2019




U/F stage 2




Agilent Technologies

SAT APR 06 15:03:14 2019




U/F stage 2




Agilent Technologies

SAT APR 06 15:05:11 2019




U/F stage 2




Agilent Technologies

SAT APR 06 15:07:38 2019




O/F stage 1




Agilent Technologies

SAT APR 06 14:18:37 2019




O/F stage 1




Agilent Technologies

SAT APR 06 14:20:27 2019




O/F stage 1




Agilent Technologies

SAT APR 06 14:22:18 2019




O/F stage 1




Agilent Technologies

SAT APR 06 14:25:20 2019




O/F stage 1




Agilent Technologies

SAT APR 06 14:27:16 2019




No trip tests - 47.7Hz




Agilent Technologies

SAT APR 06 16:06:59 2019



No trip tests – 47.2Hz



SAT APR 06 16:04:16 2019

1 500V/ 2 50.0A/ 3 5.00V/ 4


5.000s/ Stop Roll

$\Delta X = 20.070000000000s$ $1/\Delta X = 49.826mHz$ $\Delta Y(1) = 0.0V$

Mode Manual Source 1 X Y X1 X2 X1 X2


-34.2400s -14.1700s

No trip tests – 46.8Hz




Agilent Technologies

WED MAY 22 13:06:56 2019



No trip tests - 51.8Hz



Agilent Technologies

SAT APR 06 16:15:33 2019


1 500V/ 2 50.0A/ 3 5.00V/ 4 10.00s/ Stop Roll

$\Delta X = 89.980000000000s$ $1/\Delta X = 11.114mHz$ $\Delta Y(1) = 0.0V$

Mode Manual Source 1 X Y X1 X2 X1 X2


X1 -95.1000s X2 -5.12000s

No trip tests – 52.2Hz



Agilent Technologies

SAT APR 06 16:18:45 2019



4.3.2 Voltage tests

To establish the certified trip voltage, the test voltage should be applied in steps of $\pm 0.5\%$ of setting for a duration that is longer than the trip time delay.


To establish the certified trip time, the test voltage should be applied starting from $\pm 1.8\%$ below the certified trip voltage in a step of at least $\pm 0.5\%$ of setting for a duration that is longer than the trip time delay. For each trip setting five tests shall be carried out.

Following tables show the test results:


| Function | Setting | | Trip test | | "No trip tests" | |
|-------------|---------|------------|-------------|----------------|------------------|-----------------|
| | Voltage | Time delay | Voltage (V) | Time delay (s) | Voltage /time | Confirm no trip |
| U/V | 184 V | 2.5 s | 183.85 | 2.540 | 188 V / 3.50 s | Pass |
| | | | 183.91 | 2.524 | | |
| | | | 183.81 | 2.522 | | |
| | | | 183.87 | 2.510 | | |
| | | | 183.88 | 2.515 | | |
| | | | | | 180 V / 2.48 s | Pass |
| O/V stage 1 | 262.2 V | 1.0 s | 262.01 | 1.019 | 258.2 V / 2.0 s | Pass |
| | | | 261.97 | 1.010 | | |
| | | | 261.98 | 1.017 | | |
| | | | 261.97 | 1.006 | | |
| | | | 262.85 | 1.015 | | |
| O/V stage 2 | 273.7 V | 0.5 s | 273.41 | 0.534 | 269.7 V / 0.98 s | Pass |
| | | | 273.46 | 0.508 | | |
| | | | 273.41 | 0.518 | | |
| | | | 273.43 | 0.510 | | |
| | | | 273.67 | 0.530 | | |
| | | | | | 277.7 V / 0.48 s | Pass |


Note for Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

Test results are graphically shown in following pages.




SAT APR 06 09:39:02 2019






Agilent Technologies

SAT APR 06 09:41:33 2019





Agilent Technologies

SAT APR 06 09:43:28 2019


1 500V/ 2 50.0A/ 3 5.00V/ 4 500.0mV/ Stop Roll

The oscilloscope display shows three waveforms: 1 (yellow), 2 (green), and 3 (purple). Waveform 1 is a high-frequency signal with a peak-to-peak amplitude of approximately 0.5V. Waveform 2 is a high-frequency signal with a peak-to-peak amplitude of approximately 0.5V. Waveform 3 is a high-frequency signal with a peak-to-peak amplitude of approximately 0.5V. The display includes a grid and various control buttons.

$\Delta X = 2.5220000000000s$ $1/\Delta X = 396.51mHz$ $\Delta Y(1) = 0.0V$

Mode Manual Source 1 X Y X1 X2 X1 X2

-4.20000s -1.67800s




SAT APR 06 09:45:15 2019

1 500V/ 2 50.0A/ 3 5.00V/ 4 500.0mV/ Stop Roll

$\Delta X = 2.5100000000000s$ $1/\Delta X = 398.41mHz$ $\Delta Y(1) = 0.0V$

Mode Manual Source 1 X Y X1 X2 X1 X2

-6.20000s -3.69000s



Agilent Technologies

SAT APR 06 09:47:00 2019


1 500V/ 2 50.0A/ 3 5.00V/ 4 500.0mV/ Stop Roll

$\Delta X = 2.515000000000s$ $1/\Delta X = 397.61mHz$ $\Delta Y(1) = 0.0V$

Mode Manual Source 1 X Y X1 X2 X1 X2


✓ -6.40000s -3.88500s

O/V stage 1




Agilent Technologies


SAT APR 06 10:33:41 2019




O/V stage 1



SAT APR 06 10:35:19 2019



O/V stage 1




Agilent Technologies

SAT APR 06 10:37:07 2019

1 500V/ 2 50.0A/ 3 5.00V/ 4 500.0µs/ Stop Roll

$\Delta X = 1.017000000000s$ $1/\Delta X = 983.28mHz$ $\Delta Y(1) = 0.0V$
 Mode Manual Source 1 X Y X1 -3.27500s X2 -2.25800s X1 X2

O/V stage 1




Agilent Technologies

SAT APR 06 10:38:56 2019

1 500V/ 2 50.0A/ 3 5.00V/ 4 500.0mV/ Stop Roll


$\Delta X = 1.006000000000s$ $1/\Delta X = 994.04mHz$ $\Delta Y(1) = 0.0V$
 Mode Manual Source 1 X Y X1 -3.11000s X2 -2.10400s X1 X2

O/V stage 1




Agilent Technologies

SAT APR 06 10:40:50 2019



O/V stage 2




Agilent Technologies

SAT APR 06 10:59:35 2019




O/V stage 2




Agilent Technologies

SAT APR 06 11:01:18 2019



O/V stage 2



Agilent Technologies


SAT APR 06 11:03:09 2019

1 500V/ 2 50.0A/ 3 5.00V/ 4 200.0μ/ Stop Roll

$\Delta X = 518.00000000ms$ $1/\Delta X = 1.9305Hz$ $\Delta Y(1) = 0.0V$


Mode Manual Source 1 X Y X1 -3.75800s X2 -3.24000s X1 X2

O/V stage 2




Agilent Technologies

SAT APR 06 11:04:49 2019




O/V stage 2




Agilent Technologies

SAT APR 06 11:06:34 2019




No trip tests – 188V




Agilent Technologies


SAT APR 06 12:52:08 2019




No trip tests – 180V



SAT APR 06 12:53:49 2019



No trip tests – 258.2V



SAT APR 06 12:55:36 2019

1 500V/ 2 50.0A/ 3 5.00V/ 4

1.000s/ Stop Roll


The oscilloscope shows three waveforms stacked vertically. Trace 1 (yellow) is the top trace, trace 2 (green) is the middle trace, and trace 3 (purple) is the bottom trace. All traces show a steady-state signal with a step change at approximately 100ns. Two vertical dashed lines are present: a red one at approximately 100ns and an orange one at approximately 150ns.

$\Delta X = 2.000000000000s$ $1/\Delta X = 500.00mHz$ $\Delta Y(1) = 0.0V$

Mode Manual Source 1 X Y X1 X2 X1 X2

✓ -6.47000s -4.47000s

No trip tests – 269.7V



SAT APR 06 12:57:49 2019


1 500V/ 2 50.0A/ 3 5.00V/ 4 500.0µs/ Stop Roll

$\Delta X = 1.026000000000s$ $1/\Delta X = 974.66mHz$ $\Delta Y(1) = 0.0V$

Mode Manual Source 1 X Y X1 X2 X1 X2


-5.88000s -4.85400s

No trip tests – 277.7V



Agilent Technologies

SAT APR 06 12:59:04 2019



4.3.3 Loss of Mains test

For PV Inverters shall be tested in accordance with BS EN 62116.

The maximum trip time is 0.5 s.

Note for technologies which have a substantial shut down time this can be added to the 0.5 s in establishing that the trip occurred in less than 0.5 s. Maximum shut down time could therefore be up to 1.0 s for these technologies.


Following tables show the test results:

ENA Engineering Recommendation G98 Issue 1 Amendment 3 2019


| Table: tested condition and trip time | | | | | | P |
|---------------------------------------|------------------------------------|-----------------------------|-----------------|-----------------|--------------|--|
| No. | P _{EUT} (% of EUT rating) | Reactive load (% of normal) | P _{AC} | Q _{AC} | Trip time(s) | Which load is selected to be adjusted (R or L) |
| Test condition A | | | | | | |
| 1 | 100 | 100 | 0 | 0 | 466 | -- |
| 2 | 100 | 100 | -5 | -5 | 460 | R/L |
| 3 | 100 | 100 | -5 | 0 | 422 | R |
| 4 | 100 | 100 | -5 | +5 | 354 | R/L |
| 5 | 100 | 100 | 0 | -5 | 360 | L |
| 6 | 100 | 100 | 0 | +5 | 404 | L |
| 7 | 100 | 100 | +5 | -5 | 398 | R/L |
| 8 | 100 | 100 | +5 | 0 | 380 | R |
| 9 | 100 | 100 | +5 | +5 | 372 | R/L |
| 10 | 100 | 100 | -10 | +10 | 358 | R/L |
| 11 | 100 | 100 | -5 | +10 | 352 | R/L |
| 12 | 100 | 100 | 0 | +10 | 410 | L |
| 13 | 100 | 100 | +10 | +10 | 382 | R/L |
| 14 | 100 | 100 | +10 | +5 | 386 | R/L |
| 15 | 100 | 100 | +10 | 0 | 408 | R |
| 16 | 100 | 100 | +10 | -5 | 366 | R/L |
| 17 | 100 | 100 | +10 | -10 | 378 | R/L |
| 18 | 100 | 100 | +5 | -10 | 388 | R/L |
| 19 | 100 | 100 | +5 | +10 | 400 | R/L |
| 20 | 100 | 100 | 0 | -10 | 380 | L |
| 21 | 100 | 100 | -5 | -10 | 402 | R/L |
| 22 | 100 | 100 | -10 | -10 | 370 | R/L |
| 23 | 100 | 100 | -10 | -5 | 448 | R/L |
| 24 | 100 | 100 | -10 | 0 | 460 | R |
| 25 | 100 | 100 | -10 | +5 | 432 | R/L |
| Test condition B | | | | | | |
| 1 | 66 | 66 | 0 | 0 | 478 | -- |
| 2 | 66 | 66 | 0 | -5 | 306 | L |
| 3 | 66 | 66 | 0 | -4 | 400 | L |
| 4 | 66 | 66 | 0 | -3 | 444 | L |
| 5 | 66 | 66 | 0 | -2 | 466 | L |
| 6 | 66 | 66 | 0 | -1 | 390 | L |
| 7 | 66 | 66 | 0 | 1 | 362 | L |
| 8 | 66 | 66 | 0 | 2 | 406 | L |
| 9 | 66 | 66 | 0 | 3 | 426 | L |
| 10 | 66 | 66 | 0 | 4 | 406 | L |
| 11 | 66 | 66 | 0 | 5 | 298 | L |
| Test condition C | | | | | | |
| 1 | 33 | 33 | 0 | 0 | 458 | -- |
| 2 | 33 | 33 | 0 | -5 | 356 | L |
| 3 | 33 | 33 | 0 | -4 | 430 | L |
| 4 | 33 | 33 | 0 | -3 | 442 | L |
| 5 | 33 | 33 | 0 | -2 | 428 | L |
| 6 | 33 | 33 | 0 | -1 | 424 | L |
| 7 | 33 | 33 | 0 | 1 | 356 | L |
| 8 | 33 | 33 | 0 | 2 | 364 | L |
| 9 | 33 | 33 | 0 | 3 | 444 | L |
| 10 | 33 | 33 | 0 | 4 | 370 | L |
| 11 | 33 | 33 | 0 | 5 | 302 | L |

Test results are graphically shown in following pages.


Test Condition A







Test Condition B






Test Condition C



















































































4.3.4 Frequency change, Vector Shift Stability test and RoCoF Stability test

Four tests are required to be carried out with all protection functions enabled including loss of mains. For each stability test the Micro-generator should not trip during the test.

For the step change test the Micro-generator should be operated with a measurable output at the start frequency and then a vector shift should be applied by extending or reducing the time of a single cycle with subsequent cycles returning to the start frequency. The start frequency should then be maintained for a period of at least 10 s to complete the test. The Micro-generator should not trip during this test.


For frequency drift tests the Micro-generator should be operated with a measurable output at the start frequency and then the frequency changed in a ramp function at 0.95 Hzs⁻¹ to the end frequency. On reaching the end frequency it should be maintained for a period of at least 10 s. The Micro-generator should not trip during this test.

Test results are graphically shown in following pages.


Protection – Frequency change, Vector Shift Stability test: This test should be carried out in accordance with EREC G98 Annex A1 A.1.2.6 (**Inverter** connected) or Annex A2 A.2.2.6 (Synchronous).

| | Start Frequency | Change | Confirm no trip |
|-----------------------|-----------------|--------------|-----------------|
| Positive Vector Shift | 49.0 Hz | +50 degrees | Pass |
| Negative Vector Shift | 50.0 Hz | - 50 degrees | Pass |

Positive Vector Shift:




Negative Vector Shift:




Protection – Frequency change, RoCoF Stability test: The requirement is specified in section 11.3, test procedure in Annex A.1.2.6 (Inverter connected) or Annex A2 A.2.2.6 (Synchronous).

| Ramp range | Test frequency ramp: | Test Duration | Confirm no trip |
|--------------------|-------------------------|---------------|-----------------|
| 49.0 Hz to 51.0 Hz | +0.95 Hzs ⁻¹ | 2.1 s | Pass |
| 51.0 Hz to 49.0 Hz | -0.95 Hzs ⁻¹ | 2.1 s | Pass |

+0.95 Hz/s:



-0.95 Hz/s:



4.4 Limited Frequency Sensitive Mode - Overfrequency test

The test serves to verify the active power reduction of the micro-generator at over-frequency. We perform the test according to EN 50438 Annex D.3.3 Power response to over-frequency.

The tests for providing evidence of the frequency dependent active power feed-in of the micro-generator shall be carried out on a network simulator.

The test should be carried out using the specific threshold frequency of 50.4 Hz and Droop of 10%.


Following tables show the test results:

| Test sequence at Registered Capacity >80% | Measured Active Power Output (W) | Frequency (Hz) | Primary Power Source | Active Power Gradient |
|---|----------------------------------|----------------|----------------------|-----------------------|
| Step a) 50.00 Hz ±0.01 Hz | 3625.78 | 50.00 | DC Souce | N/A |
| Step b) 50.45 Hz ±0.05 Hz | 3589.27 | 50.45 | | 9.93% |
| Step c) 50.70 Hz ±0.10 Hz | 3409.01 | 50.70 | | 10.04% |
| Step d) 51.15 Hz ±0.05 Hz | 3113.45 | 51.15 | | 10.62% |
| Step e) 50.70 Hz ±0.10 Hz | 3416.37 | 50.70 | | 10.39% |
| Step f) 50.45 Hz ±0.05 Hz | 3589.21 | 50.45 | | 9.91% |
| Step g) 50.00 Hz ±0.01 Hz | 3625.86 | 50.00 | | N/A |

| Test sequence at Registered Capacity 40% - 60% | Measured Active Power Output (W) | Frequency (Hz) | Primary Power Source | Active Power Gradient |
|--|----------------------------------|----------------|----------------------|-----------------------|
| Step a) 50.00 Hz ±0.01 Hz | 1816.61 | 50.00 | DC Souce | N/A |
| Step b) 50.45 Hz ±0.05 Hz | 1798.45 | 50.45 | | 10.00% |
| Step c) 50.70 Hz ±0.10 Hz | 1707.72 | 50.70 | | 10.00% |
| Step d) 51.15 Hz ±0.05 Hz | 1553.54 | 51.15 | | 10.36% |
| Step e) 50.70 Hz ±0.10 Hz | 1711.17 | 50.70 | | 10.34% |
| Step f) 50.45 Hz ±0.05 Hz | 1798.39 | 50.45 | | 9.97% |
| Step g) 50.00 Hz ±0.01 Hz | 1816.94 | 50.00 | | N/A |


Test results are graphically shown in following pages.

Over-frequency curve (droop of 10 % at 100% Pn)



Remark: Test for frequency threshold 50.4Hz with droop 10%, intentional delay is setting to 0s.

Over-frequency curve (droop of 10 % at 50% Pn)



Remark: Test for frequency threshold 50.4Hz with droop 10%, intentional delay is setting to 0s.


4.5 Power output with falling frequency test

This test should be carried out in accordance with EN 50438 Annex D.3.2 active power feed-in at under-frequency.

| Test sequence | Measured Active Power Output (W) | Frequency (Hz) | Primary power source |
|---|----------------------------------|----------------|----------------------|
| Test a) 50 Hz \pm 0.01 Hz | 3596 | 50.00 | - |
| Test b) Point between 49.5 Hz and 49.6 Hz | 3589 | 49.50 | - |
| Test c) Point between 47.5 Hz and 47.6 Hz | 3594 | 47.52 | - |

NOTE: The operating point in Test (b) and (c) shall be maintained for at least 5 minutes

Test results are graphically shown in following pages.



4.6 Re-connection timer

Test should prove that the reconnection sequence starts after a minimum delay of 20 s for restoration of voltage and frequency to within the stage 1 settings of Table 2. These tests should be undertaken in accordance with Annex A.2.2.5.


4.6.1 Voltage Reconnection Conditions

The following table detail tests performed.


| Test at | Time delay setting(s) | Measured delay(s) | Checks on no reconnection when voltage is brought to just outside stage 1 limits of table 1. | |
|--|-----------------------|-------------------|--|------------------|
| UV | 65 | 71 | At 266.2V | At 196.1V |
| OV | 65 | 71 | | |
| Confirmation that the Micro-generator does not re-connect. | | | Not reconnection | Not reconnection |

Test results are graphically shown below.

Under voltage reconnection



Over voltage reconnection




4.6.2 Frequency Reconnection Conditions

The following table detail tests performed.


| Test at | Time delay setting(s) | Measured delay(s) | Checks on no reconnection when frequency is brought to just outside stage 1 limits of table 1. | |
|--|-----------------------|-------------------|--|------------------|
| UF | 65 | 72 | At 47.4Hz | At 52.1Hz |
| OF | 65 | 71 | | |
| Confirmation that the Micro-generator does not re-connect. | | | Not reconnection | Not reconnection |

Test results are graphically shown below.

Under frequency reconnection



Over frequency reconnection





4.7 Fault level contribution

These tests shall be carried out in accordance with EREC G98 Annex A1 A.1.3.5 (Inverter connected) and Annex A2 A.2.3.4 (Synchronous).

They have been performed different short circuit tests that are detailed in the table and pictures below.


| Short circuit current | | |
|-----------------------|----------|------------|
| Time after fault | Volts(V) | Amps(A) |
| 20ms | 31.25 | -7.5 |
| 100ms | 0 | -28.8 |
| 250ms | 0 | 0 |
| 500ms | 0 | 0 |
| Time to trip | 0 | In seconds |






Time after 250ms fault

Voltage:




Current





Time after 500ms fault

Voltage:



Current





4.8 SELF-MONITORING SOLID STATE SWITCHING

The evaluation of this point has been made according to EREC G98 Annex A1 A.1.3.6.

This test does not apply because in the inverter there are not solid-state switching devices.

4.9 ELECTROMAGNETIC COMPATIBILITY (EMC)

All equipment shall conform to the generic EMC standards: BS EN61000-6-3: Electromagnetic Compatibility, Generic Emission Standard; and BS EN61000-6-1: Electromagnetic Compatibility, Generic Immunity Standard.

The compliances with these requirements are stated in the following test report:

-EN 61000-6-3:2007 + A1:2011, EN 61000-3-2:2014, EN 61000-3-3:2013, EN 61000-3-11:2011, EN 61000-3-12:2011, EN61000-6-2:2005: Test Report no. CE170829N003 on 2017/12/08 which issued by Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.


4.10 LOGIC INTERFACE.

Confirm that an input port is provided and can be used to shut down the module.

The evaluation of this point has been made according to Clause 9.4.3 of the standard.

Power Generating Modules connected to the DNO's Distribution Network shall be equipped with a logic interface (input port) in order to cease Active Power output within 5 s following an instruction being received at the input port.

Test results are graphically shown as below.



5 PICTURES

Front




Side




Connection interface



Back Side




Internal




Internal




Front side of communication board




Back side of communication board



Front side of Main board




Front side of Main board




Front side of Bus capacitors board




Back side of Bus capacitors board




Front side of display board



Back side of display board



Removed all PCBAs



Cover




Serial Number



Software version



6 ELECTRICAL SCHEMES



-----END OF REPORT-----