

ATTESTATION OF CONFORMITY



**BUREAU
VERITAS**

Attestation No.: 1788AS0607N055001

Equipment: AC-coupled Storage Converter

Brand Name: 

Test Model No.: ME 3000SP

Applicant: Shenzhen SOFAR SOLAR Co., Ltd.
5/F, Building 4, Antongda Industrial Park, No.1 Liuxian Avenue, Xin'an Street, Bao'an District, Shenzhen City, Guangdong Province, P.R. China.

Report No.: PVFR170607N055

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with DIN V VDE V 0126-1-1/A1 VFR2014 (Protections des installations de production raccordées Identification au réseau public de distribution, ERDF-NOI-RES_13E, Version 6, 11/07/2016) for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

At the time of issue of this attestation the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**UTE C15-712-1:2013-07,
UTE C15-712-1:2010-07, rectificatif 0:2010-09 et rectificatif 1:2012-02,
DIN V VDE V 0126-1-1/A1:2012-02
ERDF-NOI-RES_13E:2013-06**

**Ted Wu/ Senior Manager/ PV Inverter Team
July 13, 2017**

No. 34, Chenwulu Section, Guantai Rd., Houjie Town,
Dongguan City, Guangdong 523942, China.
Tel: +86 769 8593 5656; Fax: +86 769 8593 1080.
Email: customerservice.dg@cn.bureauveritas.com
<http://ee.bureauveritas.com.tw/cn/>

