


<h2>VERIFICATION REPORT</h2> <h3>The requirement on Grid Connection of Provincial Electricity Authority B.E. 2559 (2016)</h3>	
Report No.....	: 162/63-148
EUT No.....	: SC-63-0122
Laboratory Name	: Electrical and Electronic Products Testing Center
Address	: 141 Thailand Science Park, Innovation Cluster 2 Tower D, Phahonyothin Rd., Khlong Nueng, Khlong Luang, Pathum Thani 12120, Thailand
Applicant's Name	: Shenzhen SOFAR SOLAR Co., Ltd.
Address	: 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China.
Test specification	
Standard	: The requirement on Grid Connection of Provincial Electricity Authority Thailand B.E. 2559 (2016)
Non-standard test method	: -
Test item description	
Trademark	: Solar Grid-tied inverter
Model and/or type reference	:  SOFAR SOLAR
Date of receipt.....	: 3 August 2020
Date of report issue	: 5 August 2020

Prepare by



 Eakkachai Taesanoo
 Engineer

Approved by



 Ruengrit Niniae
 Operation Manager

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

Detail of reference test report	
Test Report No..... :	PVTH200320N031
Total number of pages..... :	51
Testing Laboratory	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China
Testing location..... :	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China
Test specification	IEC 61727:2004, IEC 62116:2008, Deviations for Thailand according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016)
Tested by	Lukes Lin
Reviewed by	-
Approved by	James Huang
Date of report issue..... :	2020-06-24

Test item description	Solar Inverter
Trademark	SOFAR SOLAR
Model and/or type reference	SOFAR 3300TL-G3
Rating	
Input DC MPP voltage range [V]:	50-550
Input DC voltage Max [V]..... :	550
Input DC current [A]..... :	Max.12
Output AC voltage [V]..... :	220Va.c., 50/60Hz
Output AC current [A]..... :	Max. 16
Output power [W]..... :	3300
Firmware Version	V2.30

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

Summary of verification report

Test result of report No. **PVTH200320N031** was result of Photovoltaic Grid-Tied Inverter model **SO FAR 3300TL-G3**. It was verified by Electrical and Electronic Products Testing Center (PTEC) and **compiled** according to Requirements on Grid Connection of Provincial Electricity Authority BE 2559 (2016) as following.


No.	Item	Reference Report No.	Standard Reference	Verdict
1	Active power control	PVTH200320N031	PEA	Pass
2	Reactive power control	-	-	--
2.1	A Fixed Displacement Factor $\cos \theta$	PVTH200320N031	PEA	Pass
2.2	A variable reactive power depending on the voltage Q(U)	No test result	PEA	--
3	Under/over frequency protection	PVTH200320N031	IEC 61727	Pass
4	Voltage fluctuation	PVTH200320N031	IEC 61000-3-11	Pass
5	Harmonics	PVTH200320N031	IEEE 1547.1	Pass
6	DC injection	PVTH200320N031	IEC 61727	Pass
7	Low voltage fault ride through	No test result	PEA	--
8	Under/over voltage protection	PVTH200320N031	IEC 61727	Pass
9	Anti-islanding	PVTH200320N031	IEC 62116	Pass
10	Response to utility recovery	PVTH200320N031	IEC 61727	Pass

This report consists of the following document:


1. Verification Result (10 Page)
2. Attach Document Reference Report No. PVTH200320N031 (54 Page)

Standard Reference;

- **IEEE 1547.1 2005** Interconnecting Distributed Resources with Electric Power Systems
- **IEC 62116:2008**: Utility-interconnected photovoltaic inverters - Test procedure of islanding prevention measures
- **IEC 61727** Photovoltaic (PV) systems - Characteristics of the utility interface
- **IEC 61000-3-11**: Electromagnetic compatibility (EMC) - Part 3-11: Limits - Limitation of voltage fluctuations and flicker in low-voltage power supply systems for equipment with rated current > 75 A
- **PEA**: Thailand according to the grid-connected inverter regulations of the Provincial Electricity Authority (PEA):2016

VERIFICATION REPORT			
Clause	PEA Requirement	Result – Remark	Verdict
8.1.2	<p>Active Power Control</p> <p>The power generating system of VSPP must be capable of reducing electric power from 100 %to zero by decreasing 10 % electric power per one minute .In this regard, if there is any abnormality occurred in the grid system or any incident considered by PEA as an impact affecting safety and stability of the grid system, PEA would inform and/or give an order to the VSPP to reduce electric power as appropriate.</p>	<p>Active Power Control</p> <p>1) Requirement The requirements on Grid Connection of Provincial Electricity Authority</p> <p>2) Test result See Test report no: PVTH200320N031, Page 42</p> <p>3) Verification test result</p> <p>The PV inverter is capable of reducing electric power from 100 %to zero by decreasing 10 % electric power per one minute.</p>  <p>-Maximum active power deviation to set point 6.97%</p>	Pass
8.1.3	<p>Reactive Power Control</p> <p>The power generating system of VSPP must be able to control power factor)PF (or reactive power to maintain voltage level at PCC aligned with PEA’s standards .The power generating system of service applicants must have capacity as stated in Table 1.</p>	<p>Reactive Power Control</p> <p>1) Requirement The requirements on Grid Connection of Provincial Electricity Authority</p> <p>2) Test result See Test report no : PVTH200320N031, <ul style="list-style-type: none"> - Page 38 Reactive power capability - Page 39-40 A Fixed Displacement Factor cos θ test result - No A variable reactive power depending on the voltage Q(U) test result. </p>	Pass

This test report is test results from the EUT only, not the product’s quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

VERIFICATION REPORT																	
Clause	PEA Requirement	Result – Remark	Verdict														
		<p>3) Verification test result 3.1 Reactive power capability</p> 	Pass														
		<p>3.2 A Fixed Displacement Factor $\cos \theta$ (PF 0.90) test</p> <table border="1" data-bbox="804 949 1366 1115"> <thead> <tr> <th rowspan="2">PF. Set point</th> <th colspan="2">PF. Measurement*</th> </tr> <tr> <th>Max</th> <th>Min</th> </tr> </thead> <tbody> <tr> <td>1.0</td> <td>0.999</td> <td>0.978</td> </tr> <tr> <td>0.90 lagging</td> <td>0.906</td> <td>0.866</td> </tr> <tr> <td>0.90 Leading</td> <td>0.900</td> <td>0.883</td> </tr> </tbody> </table> <p>*@Pout =10% to 100%</p>	PF. Set point	PF. Measurement*		Max	Min	1.0	0.999	0.978	0.90 lagging	0.906	0.866	0.90 Leading	0.900	0.883	Pass
PF. Set point	PF. Measurement*																
	Max	Min															
1.0	0.999	0.978															
0.90 lagging	0.906	0.866															
0.90 Leading	0.900	0.883															
		<p>No A variable reactive power depending on the voltage Q(U) test result</p>	--														


This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

VERIFICATION REPORT															
Clause	PEA Requirement	Result – Remark	Verdict												
8.2	<p>Under and Over Frequency Protection The power generating system of VSPP must disconnect itself from the grid system within 0.1 seconds if the frequency at PCC is not in the range of 47 Hz-52 Hz.</p>	<p>Under and Over Frequency Protection 1) Reference Standard IEC 61727 2) Test result See Test report no: PVTH200320N031 Page 28-29 3) Verification test result</p> <table border="1"> <thead> <tr> <th>Frequency at PCC</th> <th>Measured (Sec)</th> <th>Limit (Sec)</th> <th>Result</th> </tr> </thead> <tbody> <tr> <td>f < 47</td> <td>0.082</td> <td><0.1</td> <td>Pass</td> </tr> <tr> <td>f > 52</td> <td>0.076</td> <td><0.1</td> <td>Pass</td> </tr> </tbody> </table>	Frequency at PCC	Measured (Sec)	Limit (Sec)	Result	f < 47	0.082	<0.1	Pass	f > 52	0.076	<0.1	Pass	Pass
Frequency at PCC	Measured (Sec)	Limit (Sec)	Result												
f < 47	0.082	<0.1	Pass												
f > 52	0.076	<0.1	Pass												
8.3	<p>Voltage Fluctuation The power generating system of VSPP must not create voltage fluctuation exceeding the limit based on the PEA's rules concerning the Regulations on Grid Connection B.E.2559. Regulations on Grid Connection B.E.2559. The operation of the inverter should not cause voltage flicker in excess of limits : Short-term Severity Values (Pst) not exceed 1.0 Long-term Severity Values (Plt) not exceed 0.8</p>	<p>Voltage Fluctuation 1) Reference Standard IEC 61000-3-5 2) Test result See Test report no : PVTH200320N031, Page 13 3) Verification test result</p> <table border="1"> <thead> <tr> <th>Test item</th> <th>Limit</th> <th>Result</th> <th>Verdict</th> </tr> </thead> <tbody> <tr> <td>Pst</td> <td>1.0</td> <td>0.09</td> <td>Pass</td> </tr> <tr> <td>Plt</td> <td>0.8</td> <td>0.07</td> <td>Pass</td> </tr> </tbody> </table>	Test item	Limit	Result	Verdict	Pst	1.0	0.09	Pass	Plt	0.8	0.07	Pass	Pass
Test item	Limit	Result	Verdict												
Pst	1.0	0.09	Pass												
Plt	0.8	0.07	Pass												

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

VERIFICATION REPORT																																																																																																																																																																											
Clause	PEA Requirement	Result – Remark	Verdict																																																																																																																																																																								
8.4	<p>Harmonic</p> <p>The power generating system of VSPP must not inject harmonic current to the grid system exceeding the limit based on the PEA's rules concerning the Regulations of Grid Connection B.E.2559.</p> <p>Regulations of Grid Connection B.E.2559.</p> <p>The Inverter output should have low current-distortion and low voltage distortion levels to ensure that no adverse effects are caused to other equipment connected to the utility system .Each individual harmonic shall be limited to the listed in Table 5.1 and Table 5-2 of attach 4.</p> <p style="text-align: center;">ตารางที่ 5-1 ขีดจำกัดกระแสฮาร์มอนิกสำหรับผู้ใช้ไฟฟ้าระบบที่จุดต่อร่วม *</p> <table border="1"> <thead> <tr> <th rowspan="2">ระดับแรงดันไฟฟ้าที่จุดต่อร่วม (kV)</th> <th colspan="18">อันดับฮาร์มอนิกและขีดจำกัดของกระแส (A rms)</th> </tr> <tr> <th>2</th><th>3</th><th>4</th><th>5</th><th>6</th><th>7</th><th>8</th><th>9</th><th>10</th><th>11</th><th>12</th><th>13</th><th>14</th><th>15</th><th>16</th><th>17</th><th>18</th><th>19</th> </tr> </thead> <tbody> <tr> <td>0.400</td> <td>48</td><td>34</td><td>22</td><td>56</td><td>11</td><td>40</td><td>9</td><td>8</td><td>7</td><td>19</td><td>6</td><td>16</td><td>5</td><td>5</td><td>5</td><td>6</td><td>4</td><td>6</td> </tr> <tr> <td>11 and 12</td> <td>13</td><td>8</td><td>6</td><td>10</td><td>4</td><td>8</td><td>3</td><td>3</td><td>3</td><td>7</td><td>2</td><td>6</td><td>2</td><td>2</td><td>2</td><td>2</td><td>1</td><td>1</td> </tr> <tr> <td>22, 24 and 33</td> <td>11</td><td>7</td><td>5</td><td>9</td><td>4</td><td>6</td><td>3</td><td>2</td><td>2</td><td>6</td><td>2</td><td>5</td><td>2</td><td>1</td><td>1</td><td>2</td><td>1</td><td>1</td> </tr> <tr> <td>69</td> <td>8.8</td><td>5.9</td><td>4.3</td><td>7.3</td><td>3.3</td><td>4.9</td><td>2.3</td><td>1.6</td><td>1.6</td><td>4.9</td><td>1.6</td><td>4.3</td><td>1.6</td><td>1</td><td>1</td><td>1.6</td><td>1</td><td>1</td> </tr> <tr> <td>115 and above</td> <td>5</td><td>4</td><td>3</td><td>4</td><td>2</td><td>3</td><td>1</td><td>1</td><td>1</td><td>3</td><td>1</td><td>3</td><td>1</td><td>1</td><td>1</td><td>1</td><td>1</td><td>1</td> </tr> </tbody> </table> <p style="text-align: center;">ตารางที่ 5-2 ขีดจำกัดความถี่ฮาร์มอนิกของแรงดันสำหรับผู้ใช้ไฟฟ้าระบบที่จุดต่อร่วม (รวมทั้งระดับความถี่ที่มีอยู่เดิม)</p> <table border="1"> <thead> <tr> <th rowspan="2">ระดับแรงดันไฟฟ้าที่จุดต่อร่วม (kV)</th> <th rowspan="2">ค่าความถี่ฮาร์มอนิกรวมของแรงดัน (%)</th> <th colspan="2">ค่าความถี่ฮาร์มอนิกของแรงดันแต่ละอันดับ (%)</th> </tr> <tr> <th>อันดับที่</th> <th>อันดับที่</th> </tr> </thead> <tbody> <tr> <td>0.400</td> <td>5</td> <td>4</td> <td>2</td> </tr> <tr> <td>11, 12, 22 and 24</td> <td>4</td> <td>3</td> <td>1.75</td> </tr> <tr> <td>33</td> <td>3</td> <td>2</td> <td>1</td> </tr> <tr> <td>69</td> <td>2.45</td> <td>1.63</td> <td>0.82</td> </tr> <tr> <td>115 and above</td> <td>1.5</td> <td>1</td> <td>0.5</td> </tr> </tbody> </table>	ระดับแรงดันไฟฟ้าที่จุดต่อร่วม (kV)	อันดับฮาร์มอนิกและขีดจำกัดของกระแส (A rms)																		2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	0.400	48	34	22	56	11	40	9	8	7	19	6	16	5	5	5	6	4	6	11 and 12	13	8	6	10	4	8	3	3	3	7	2	6	2	2	2	2	1	1	22, 24 and 33	11	7	5	9	4	6	3	2	2	6	2	5	2	1	1	2	1	1	69	8.8	5.9	4.3	7.3	3.3	4.9	2.3	1.6	1.6	4.9	1.6	4.3	1.6	1	1	1.6	1	1	115 and above	5	4	3	4	2	3	1	1	1	3	1	3	1	1	1	1	1	1	ระดับแรงดันไฟฟ้าที่จุดต่อร่วม (kV)	ค่าความถี่ฮาร์มอนิกรวมของแรงดัน (%)	ค่าความถี่ฮาร์มอนิกของแรงดันแต่ละอันดับ (%)		อันดับที่	อันดับที่	0.400	5	4	2	11, 12, 22 and 24	4	3	1.75	33	3	2	1	69	2.45	1.63	0.82	115 and above	1.5	1	0.5	<p>Harmonics</p> <p>1) Reference Standard IEEE1547.1-2005 Total harmonic current distortion is less than 5 %at rated inverter output Individual harmonics don't exceed the given distortion limit</p> <p>2) Test result See Test report no : PVTH200320N031, Page 15 to 20</p> <p>3) Verification test result</p> <table border="1"> <thead> <tr> <th>Item</th> <th>Verdict</th> </tr> </thead> <tbody> <tr> <td>THDi in each harmonic not exceed in table 5-1</td> <td>Pass</td> </tr> <tr> <td>Total harmonic current distortion less than 5 %</td> <td>Pass</td> </tr> <tr> <td>THDv in each harmonic not exceed in table 5-2</td> <td>Pass</td> </tr> <tr> <td>Total harmonic voltage distortion less than 5 %</td> <td>Pass</td> </tr> </tbody> </table>	Item	Verdict	THDi in each harmonic not exceed in table 5-1	Pass	Total harmonic current distortion less than 5 %	Pass	THDv in each harmonic not exceed in table 5-2	Pass	Total harmonic voltage distortion less than 5 %	Pass	Pass
ระดับแรงดันไฟฟ้าที่จุดต่อร่วม (kV)	อันดับฮาร์มอนิกและขีดจำกัดของกระแส (A rms)																																																																																																																																																																										
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19																																																																																																																																																									
0.400	48	34	22	56	11	40	9	8	7	19	6	16	5	5	5	6	4	6																																																																																																																																																									
11 and 12	13	8	6	10	4	8	3	3	3	7	2	6	2	2	2	2	1	1																																																																																																																																																									
22, 24 and 33	11	7	5	9	4	6	3	2	2	6	2	5	2	1	1	2	1	1																																																																																																																																																									
69	8.8	5.9	4.3	7.3	3.3	4.9	2.3	1.6	1.6	4.9	1.6	4.3	1.6	1	1	1.6	1	1																																																																																																																																																									
115 and above	5	4	3	4	2	3	1	1	1	3	1	3	1	1	1	1	1	1																																																																																																																																																									
ระดับแรงดันไฟฟ้าที่จุดต่อร่วม (kV)	ค่าความถี่ฮาร์มอนิกรวมของแรงดัน (%)	ค่าความถี่ฮาร์มอนิกของแรงดันแต่ละอันดับ (%)																																																																																																																																																																									
		อันดับที่	อันดับที่																																																																																																																																																																								
0.400	5	4	2																																																																																																																																																																								
11, 12, 22 and 24	4	3	1.75																																																																																																																																																																								
33	3	2	1																																																																																																																																																																								
69	2.45	1.63	0.82																																																																																																																																																																								
115 and above	1.5	1	0.5																																																																																																																																																																								
Item	Verdict																																																																																																																																																																										
THDi in each harmonic not exceed in table 5-1	Pass																																																																																																																																																																										
Total harmonic current distortion less than 5 %	Pass																																																																																																																																																																										
THDv in each harmonic not exceed in table 5-2	Pass																																																																																																																																																																										
Total harmonic voltage distortion less than 5 %	Pass																																																																																																																																																																										
8.5	<p>DC Injection</p> <p>The power generating system of VSPP must not supply direct current to the grid system exceeding the limit based on the PEA's regulations concerning the Regulations on Grid Connection B.E.2559.</p> <p>Regulations on Grid Connection B.E.2559.</p> <p>The inverter shall not inject DC current greater than 0.5 % of the rated inverter output current, into the utility AC interface under any operating condition.</p>	<p>DC Injection</p> <p>1) Reference Standard IEC 61727</p> <p>2) Test result See Test report no: PVTH200320N031, Page 14</p> <p>3) Verification test result</p> <table border="1"> <thead> <tr> <th>Output Power</th> <th>Limit [%]</th> <th>Max.DC [%]</th> <th>Verdict</th> </tr> </thead> <tbody> <tr> <td>33%</td> <td>0.5</td> <td>0.11</td> <td>Pass</td> </tr> <tr> <td>66%</td> <td>0.5</td> <td>0.13</td> <td>Pass</td> </tr> <tr> <td>100%</td> <td>0.5</td> <td>0.15</td> <td>Pass</td> </tr> </tbody> </table>	Output Power	Limit [%]	Max.DC [%]	Verdict	33%	0.5	0.11	Pass	66%	0.5	0.13	Pass	100%	0.5	0.15	Pass	Pass																																																																																																																																																								
Output Power	Limit [%]	Max.DC [%]	Verdict																																																																																																																																																																								
33%	0.5	0.11	Pass																																																																																																																																																																								
66%	0.5	0.13	Pass																																																																																																																																																																								
100%	0.5	0.15	Pass																																																																																																																																																																								

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

VERIFICATION REPORT																																																																																																	
Clause	PEA Requirement	Result – Remark	Verdict																																																																																														
12.1	<p>Low Voltage Fault Ride Through The power system of VSPP must not disconnect itself from the grid system within the required period during temporary low voltage of the grid system .The voltage at PCC is determined as shown in Table Fault Ride Through</p> <p>Duration of Low Voltage Fault Ride Through</p> <table border="1"> <thead> <tr> <th>Voltage at PCC</th> <th>Duration Time (Second)</th> </tr> </thead> <tbody> <tr> <td>1) Low voltage 2) Moderate voltage or high voltage (electrical installation not exceeding 500 kilowatt).</td> <td>Not required.</td> </tr> <tr> <td>3) Moderate voltage or high voltage (electrical installation exceeding 500 kilowatt).</td> <td>As shown in Picture 1.</td> </tr> </tbody> </table>  <p>Picture 1. Low Voltage Fault Ride Through</p>	Voltage at PCC	Duration Time (Second)	1) Low voltage 2) Moderate voltage or high voltage (electrical installation not exceeding 500 kilowatt).	Not required.	3) Moderate voltage or high voltage (electrical installation exceeding 500 kilowatt).	As shown in Picture 1.	<p>Low Voltage Fault Ride Through 1) Requirement The requirements on Grid Connection of Provincial Electricity Authority</p> <p>2) Test result See Test report no, N/A Page: N/A</p> <p>3) Verification test result</p> <p>3.1) Output Power >0.9Pn</p> <table border="1"> <thead> <tr> <th>Test List</th> <th>V (V/Vn)</th> <th>Duration (mS)</th> <th>Limit (mS)</th> <th>verdict</th> </tr> </thead> <tbody> <tr> <td rowspan="3">Three-phase faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td rowspan="3">Phase to phase faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td rowspan="3">Phase to ground faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> </tbody> </table> <p>3.2) Output Power 0.3Pn</p> <table border="1"> <thead> <tr> <th>Test List</th> <th>V (V/Vn)</th> <th>Duration (mS)</th> <th>Limit (mS)</th> <th>verdict</th> </tr> </thead> <tbody> <tr> <td rowspan="3">Three-phase faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td rowspan="3">Phase to phase faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td rowspan="3">Phase to ground faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> </tbody> </table>	Test List	V (V/Vn)	Duration (mS)	Limit (mS)	verdict	Three-phase faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Phase to phase faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Phase to ground faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Test List	V (V/Vn)	Duration (mS)	Limit (mS)	verdict	Three-phase faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Phase to phase faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Phase to ground faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		--
Voltage at PCC	Duration Time (Second)																																																																																																
1) Low voltage 2) Moderate voltage or high voltage (electrical installation not exceeding 500 kilowatt).	Not required.																																																																																																
3) Moderate voltage or high voltage (electrical installation exceeding 500 kilowatt).	As shown in Picture 1.																																																																																																
Test List	V (V/Vn)	Duration (mS)	Limit (mS)	verdict																																																																																													
Three-phase faults	0.7-0.8 Vn		>993.75																																																																																														
	0.3-0.5 Vn		>150																																																																																														
	0-0.049Vn		>150																																																																																														
Phase to phase faults	0.7-0.8 Vn		>993.75																																																																																														
	0.3-0.5 Vn		>150																																																																																														
	0-0.049Vn		>150																																																																																														
Phase to ground faults	0.7-0.8 Vn		>993.75																																																																																														
	0.3-0.5 Vn		>150																																																																																														
	0-0.049Vn		>150																																																																																														
Test List	V (V/Vn)	Duration (mS)	Limit (mS)	verdict																																																																																													
Three-phase faults	0.7-0.8 Vn		>993.75																																																																																														
	0.3-0.5 Vn		>150																																																																																														
	0-0.049Vn		>150																																																																																														
Phase to phase faults	0.7-0.8 Vn		>993.75																																																																																														
	0.3-0.5 Vn		>150																																																																																														
	0-0.049Vn		>150																																																																																														
Phase to ground faults	0.7-0.8 Vn		>993.75																																																																																														
	0.3-0.5 Vn		>150																																																																																														
	0-0.049Vn		>150																																																																																														

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

VERIFICATION REPORT																																																	
Clause	PEA Requirement	Result – Remark			Verdict																																												
		3.3) Output Power 0.1Pn <table border="1"> <thead> <tr> <th>Test List</th> <th>V (V/Vn)</th> <th>Duration (mS)</th> <th>Limit (mS)</th> <th>verdict</th> </tr> </thead> <tbody> <tr> <td rowspan="3">Three-phase faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td rowspan="3">Phase to Phase faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td rowspan="3">Phase to ground faults</td> <td>0.7-0.8 Vn</td> <td></td> <td>>993.75</td> <td></td> </tr> <tr> <td>0.3-0.5 Vn</td> <td></td> <td>>150</td> <td></td> </tr> <tr> <td>0-0.049Vn</td> <td></td> <td>>150</td> <td></td> </tr> </tbody> </table>			Test List	V (V/Vn)	Duration (mS)	Limit (mS)	verdict	Three-phase faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Phase to Phase faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		Phase to ground faults	0.7-0.8 Vn		>993.75		0.3-0.5 Vn		>150		0-0.049Vn		>150		--
Test List	V (V/Vn)	Duration (mS)	Limit (mS)	verdict																																													
Three-phase faults	0.7-0.8 Vn		>993.75																																														
	0.3-0.5 Vn		>150																																														
	0-0.049Vn		>150																																														
Phase to Phase faults	0.7-0.8 Vn		>993.75																																														
	0.3-0.5 Vn		>150																																														
	0-0.049Vn		>150																																														
Phase to ground faults	0.7-0.8 Vn		>993.75																																														
	0.3-0.5 Vn		>150																																														
	0-0.049Vn		>150																																														
12.2	<p>Under and Over Voltage Protection</p> <p>The power system of VSPP must disconnect itself from the grid system if voltage level of line to neutral in the utility system is out of ranges as stated in Table 3.</p> <p><small>Table 3. The Disconnect Duration of Falling Voltage Out of Rated Voltage Ranges</small></p> <table border="1"> <thead> <tr> <th>Voltage at PCC</th> <th>Disconnect Duration (Second)</th> </tr> </thead> <tbody> <tr> <td>V < 50%</td> <td>0.3</td> </tr> <tr> <td>50% ≤ V < 90%</td> <td>2.0</td> </tr> <tr> <td>90% ≤ V ≤ 110%</td> <td>continual voltage</td> </tr> <tr> <td>110% < V < 120%</td> <td>1.0</td> </tr> <tr> <td>V ≥ 120%</td> <td>0.16</td> </tr> </tbody> </table>	Voltage at PCC	Disconnect Duration (Second)	V < 50%	0.3	50% ≤ V < 90%	2.0	90% ≤ V ≤ 110%	continual voltage	110% < V < 120%	1.0	V ≥ 120%	0.16	<p>Under and Over Voltage Protection</p> <p>1) Reference Standard IEC 61727</p> <p>2) Test result See Test report no: PVTH200320N031 Page 22-25</p> <p>3) Verification test result</p> <table border="1"> <thead> <tr> <th>Voltage at PCC</th> <th>Max Meas. (Sec)</th> <th>Limit (Sec)</th> <th>Result</th> </tr> </thead> <tbody> <tr> <td>V < 50%</td> <td>0.208</td> <td><0.3</td> <td>Pass</td> </tr> <tr> <td>50% ≤ V < 90%</td> <td>1.820</td> <td><2.0</td> <td>Pass</td> </tr> <tr> <td>90% ≤ V ≤ 110%</td> <td>No trip</td> <td>Cont.</td> <td>Pass</td> </tr> <tr> <td>110% < V < 120%</td> <td>0.660</td> <td><1.0</td> <td>Pass</td> </tr> <tr> <td>V ≥ 120%</td> <td>0.098</td> <td><0.16</td> <td>Pass</td> </tr> </tbody> </table>			Voltage at PCC	Max Meas. (Sec)	Limit (Sec)	Result	V < 50%	0.208	<0.3	Pass	50% ≤ V < 90%	1.820	<2.0	Pass	90% ≤ V ≤ 110%	No trip	Cont.	Pass	110% < V < 120%	0.660	<1.0	Pass	V ≥ 120%	0.098	<0.16	Pass	Pass								
Voltage at PCC	Disconnect Duration (Second)																																																
V < 50%	0.3																																																
50% ≤ V < 90%	2.0																																																
90% ≤ V ≤ 110%	continual voltage																																																
110% < V < 120%	1.0																																																
V ≥ 120%	0.16																																																
Voltage at PCC	Max Meas. (Sec)	Limit (Sec)	Result																																														
V < 50%	0.208	<0.3	Pass																																														
50% ≤ V < 90%	1.820	<2.0	Pass																																														
90% ≤ V ≤ 110%	No trip	Cont.	Pass																																														
110% < V < 120%	0.660	<1.0	Pass																																														
V ≥ 120%	0.098	<0.16	Pass																																														

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.

VERIFICATION REPORT																			
Clause	PEA Requirement	Result – Remark	Verdict																
12.3	<p>Anti-Islanding</p> <p>In order to prevent anti-islanding while there is no electricity in grid system to be supplied to the power system of VSPP, the power generating system of VSPP must disconnect itself from the utility system within 1 seconds.</p>	<p>Anti-Islanding</p> <p>1) Reference Standard IEC 62116</p> <p>2) Test result See Test report no: PVTH200320N031 Page 31-37</p> <p>3) Verification test result</p> <table border="1"> <thead> <tr> <th>% Off P_{Outrating}</th> <th>Maximum Runtime (Sec)</th> <th>Limit (Sec)</th> <th>Result</th> </tr> </thead> <tbody> <tr> <td>100</td> <td>0.646</td> <td>< 1.0</td> <td>Pass</td> </tr> <tr> <td>66</td> <td>0.664</td> <td>< 1.0</td> <td>Pass</td> </tr> <tr> <td>33</td> <td>0.646</td> <td>< 1.0</td> <td>Pass</td> </tr> </tbody> </table>	% Off P _{Outrating}	Maximum Runtime (Sec)	Limit (Sec)	Result	100	0.646	< 1.0	Pass	66	0.664	< 1.0	Pass	33	0.646	< 1.0	Pass	Pass
% Off P _{Outrating}	Maximum Runtime (Sec)	Limit (Sec)	Result																
100	0.646	< 1.0	Pass																
66	0.664	< 1.0	Pass																
33	0.646	< 1.0	Pass																
12.4	<p>Response to Utility Recovery</p> <p>After the power generating system of VSPP disconnect itself from the grid system because of power outage or voltage/frequency is out of the ranges, when the grid system is back to normal, the power system of VSPP must delay the time to reconnect itself to the grid system at a minimum of 20 seconds to 5 minutes.</p>	<p>Response to Utility Recovery</p> <p>1) Reference Standard IEC 61727</p> <p>2) Test result See Test report no: PVTH200320N031 Page 22-23, 26-38, 30</p> <p>3) Verification test result</p> <table border="1"> <thead> <tr> <th>Limit Recovery time (Sec)</th> <th>Max. Measurement Recovery time (Sec)</th> <th>Result</th> </tr> </thead> <tbody> <tr> <td>20 - 300</td> <td>76</td> <td>Pass</td> </tr> </tbody> </table>	Limit Recovery time (Sec)	Max. Measurement Recovery time (Sec)	Result	20 - 300	76	Pass	Pass										
Limit Recovery time (Sec)	Max. Measurement Recovery time (Sec)	Result																	
20 - 300	76	Pass																	

----- END OF REPORT -----

This test report is test results from the EUT only, not the product's quality certificate. It shall not be reproduced except in full without the written approval by PTEC.



**BUREAU
VERITAS**

TEST REPORT

IEC 61727 / IEC 62116

Photovoltaic (PV) systems
Characteristics of the utility interface



Test procedure of islanding prevention measures for
utility-interconnected photovoltaic inverters

Report reference number	PVTH200320N031
Date of issue	2020-06-24
Total number of pages	51
Testing laboratory name	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch
Address	No. 96, Guantai Road (Houjie Section), Houjie Town, Dongguan City, Guangdong Province, 523942, People's Republic of China
Accreditation	 
Applicant's name.....	Shenzhen SOFAR SOLAR Co., Ltd.
Address	401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China.
Test specification	
Standard.....	IEC 61727:2004, IEC 62116:2008, Deviations for Thailand according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016)
Test Report Form No.	IEC61727/IEC62116_PEA VER.2
TRF Originator	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch
Master TRF	Dated 2020-03-20
Test item description	Solar Grid-tied Inverter
Trademark	
Model / Type	SOFAR 3300TL-G3
<p><small>This report is governed by, and incorporates by reference, CPS Conditions of Service as posted at the date of issuance of this report at http://www.bureauveritas.com/home/about-us/our-business/cps/about-us/terms-conditions and is intended for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. The results set forth in this report are not indicative or representative of the quality or characteristics of the lot from which a test sample was taken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. Measurement uncertainty is only provided upon request for accredited tests. You have 60 days from date of issuance of this report to notify us of any material error or omission caused by our negligence or if you require measurement uncertainty; provided, however, that such notice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise such issue within the prescribed time shall constitute your unqualified acceptance of the completeness of this report, the tests conducted and the correctness of the report contents.</small></p>	



Ratings	SOFAR 3300TL-G3
Input DC voltage [V]	550 Max.
MPP DC voltage range [V]	50-550
Input DC current [A]	12 Max.
Isc PV [A].....	15 Max.
Output AC voltage [V]	220Va.c., 50/60Hz
Max. Output AC current [A]	16
Rated Output power [W].....	3300
Max Output power [VA]	3300












Testing Location	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch
Address	No. 96, Guantai Road (Houjie Section), Houjie Town, Dongguan City, Guangdong Province, 523942, People's Republic of China
Tested by (name and signature)	Lukes Lin 
Approved by (name and signature)	James Huang 
Manufacturer's name	Shenzhen SOFAR SOLAR Co., Ltd.
Manufacturer address	401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China.
Factory's name	Dongguan SOFAR SOLAR Co.,Ltd.
Factory address	1F - 6F, Building E, No. 1 JinQi Road, Bihu Industrial Park, Wulian Village, Fenggang Town, Dongguan City

Document History			
Date	Internal reference	Modification / Change / Status	Revision
2020-06-24	Lukes Lin	Initial report was written	0
Supplementary information:			



Test items particulars	
Equipment mobility.....	: Permanent connection
Operating condition.....	: Continuous
Class of equipment.....	: Class I
Protection against ingress of water..	: IP65 according to EN 60529
Test case verdicts	
Test case does not apply to the test object.....	: N/A
Test item does meet the requirement.....	: P(ass)
Test item does not meet the requirement.....	: F(ail)
Testing	
Date of receipt of test item.....	: 2020-03-20
Date(s) of performance of test.....	: 2020-03-20 to 2020-06-23
General remarks:	
<p>The test result presented in this report relate only to the object(s) tested. This report must not be reproduced in part or in full without the written approval of the issuing testing laboratory. "(see Annex #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report. Throughout this report a comma is used as the decimal separator.</p>	
This Test Report consists of the following documents:	
<ol style="list-style-type: none"> 1. Test Results 2. Annex No. 1 – Pictures of the unit 3. Annex No. 2 –Test equipment list 	

Copy of marking plate:

 Solar Grid-tied Inverter	
Model No.	SOFAR 3300TL-G3
Max.DC Input Voltage	550V
Operating MPPT Voltage Range	50~550V
Max. Input Current	12A
Max. PV Isc	15A
Nominal Grid Voltage	L/N/PE,220Vac
Max. Output Current	16A
Nominal Grid Frequency	50/60Hz
Max. Output Power	3300VA
Power Factor	1(adjustable+/-0.8)
Ingress protection	IP65
Operating Temperature Range	-30~+60°C
Topology	Non-isolated
Protective Class	Class I
Manufacturer:Shenzhen SOFARSOLAR Co., Ltd. Address: 401, Building 4, AnTongDa Industrial Park,District 68, XingDong Community, XinAn Street,BaoAn District, Shenzhen, China	
VDE0126-1-1,VDE-AR-N4105,IEC61727, IEC62116,UTE C15-712-1,AS4777	
       	

General product information:

The Grid tied photovoltaic inverter converts DC voltage into AC voltage.

The input and output are protected by Varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high power switching bridge and a two relays. This assures that the opening of the output circuit will also operate in case of one error.

The internal control is redundant built. It consists of Microcontroller Main DSP (UC34) and RCU DSP(U03). The Main DSP(UC34) control the relays by switching signals; measures the PV voltage, PV current, Bus voltage, grid voltage, frequency, AC current with injected DC and the array insulation resistance to ground. In addition it tests the current sensors and the RCMU circuit before each start up.

The RCU DSP (U03) is measures the grid voltage, AC current, grid frequency and residual current, also can switch off the relays independently, and communicate with Main DSP (UC34) each other.

The current is measured by a current sensor. The AC current signal and the injected DC current signal are sent to the Main DSP(UC34). The Main DSP(UC34) tests and calibrates before each start up all current sensors.




Figure 1 – Block diagram

The unit provides two relays in series in all output conductors. When single fault applied to one relay, alarm an error code in display panel, another redundant relay provides basic insulation maintained between the PV array and the mains. All the relays are tested before each start up.

The product was tested on:

Hardware version: V1.00
Software version: V2.30

**Interface protection settings with deviations according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016)
(Thailand PEA)**

Parameter	Max. clearance time*	Trip setting
Over voltage (level 2)	0,16s	220V +20% (264V)
Over voltage (level 1)	1,0s	220V +10% (242V)
Under voltage (level 1)	2,0s	220V -10% (198V)
Under voltage (level 2)	0,3s	220V -50% (110V)
Over frequency	0,1s	50Hz +4% (52,0Hz)
Under frequency	0,1s	50Hz -6% (47,0Hz)
Reconnection time	20s - 5min	
Permanent DC-injection	0,5% of rated inverter output current	
Loss of main IEC 62116:2008	Inverter shall detect and disconnect within 1s	

* Trip time refers to the time between the abnormal condition occurring and the inverter ceasing to energize the utility line. The PV system control circuits shall actually remain connected to the utility to allow sensing of utility electrical conditions for use by the “reconnect” feature.

IEC61727:2004			
Clause	Requirement – Test	Result – Remark	Verdict
SECTION 4: Utility compatibility			
4	<p>General The quality of power provided by the PV system for the on-site AC loads and for power delivered to the utility is governed by practices and standards on voltage, flicker, frequency, harmonics and power factor. Deviation from these standards represents out-of-bounds conditions and may require the PV system to sense the deviation and properly disconnect from the utility system.</p> <p>All power quality parameters (voltage, flicker, frequency, harmonics, and power factor) must be measured at the utility interface/ point of common coupling unless otherwise specified.</p>	Noticed	P
4.1	<p>Voltage, current and frequency The PV system AC voltage, current and frequency shall be compatible with the utility system.</p>	Derived from tests	P
4.2	<p>Normal voltage operating range Utility-interconnected PV systems do not normally regulate voltage; they inject current into the utility. Therefore, the voltage operating range for PV inverters is selected as a protection function that responds to abnormal utility conditions, not as a voltage regulation function.</p>	Derived from tests	P
4.3	<p>Flicker The operation of the PV system should not cause voltage flicker in excess of limits stated in the relevant sections of IEC 61000-3-3 for systems less than 16 A or IEC 61000-3-5 for systems with current of 16 A and above.</p>	See table 4.3	P
4.4	<p>DC injection The PV system shall not inject DC current greater than 1 % of the rated inverter output current, into the utility AC interface under any operating condition.</p>	<p>The following deviations were used: Provincial Electricity Authority (PEA:2016)</p> <p>See table 4.4</p>	P
4.5	<p>Normal frequency operating range The PV system shall operate in synchronism with the utility system, and within the frequency trip limits defined in 5.2.2.</p>	<p>The following deviations were used: Provincial Electricity Authority (PEA:2016)</p> <p>See table 5.2.2</p>	P

IEC61727:2004			
Clause	Requirement – Test	Result – Remark	Verdict
SECTION 4: Utility compatibility			
4.6	<p>Harmonics and waveform distortion Low levels of current and voltage harmonics are desirable; the higher harmonic levels increase the potential for adverse effects on connected equipment. Acceptable levels of harmonic voltage and current depend upon distribution system characteristics, type of service, connected loads/apparatus, and established utility practice. The PV system output should have low current-distortion levels to ensure that no adverse effects are caused to other equipment connected to the utility system. Total harmonic current distortion shall be less than 5 % at rated inverter output. Each individual harmonic shall be limited to the percentages listed in Table 1. Even harmonics in these ranges shall be less than 25 % of the lower odd harmonic limits listed. (see Clause 4.6 Table 1 – Current distortion limits)</p>	<p>The following deviations were used: Provincial Electricity Authority (PEA:2016) See tables 4.6 (1) and 4.6 (2)</p>	P
4.7	<p>Power factor The PV system shall have a lagging power factor greater than 0,9 when the output is greater than 50 % of the rated inverter output power.</p>	See table 3.4	P

IEC61727:2004			
Clause	Requirement – Test	Result – Remark	Verdict
SECTION 5: Personnel safety and equipment protection			
5	General This Clause provides information and considerations for the safe and proper operation of the utility-connected PV systems.	Noticed	P
5.1	Loss of utility voltage To prevent islanding, a utility connected PV system shall cease to energize the utility system from a de-energized distribution line irrespective of connected loads or other generators within specified time limits. A utility distribution line can become de-energized for several reasons. For example, a substation breaker opening due to fault conditions or the distribution line switched out during maintenance. If inverters (single or multiple) have DC SELV input and have accumulated power below 1 kW then no mechanical disconnect (relay) is required.	The following deviations were used: Provincial Electricity Authority (PEA:2016)	P
5.2	Over/under voltage and frequency Abnormal conditions can arise on the utility system that requires a response from the connected photovoltaic system. This response is to ensure the safety of utility maintenance personnel and the general public, as well as to avoid damage to connected equipment, including the photovoltaic system. The abnormal utility conditions of concern are voltage and frequency excursions above or below the values stated in this Clause, and the complete disconnection of the utility, presenting the potential for a distributed resource island.	The following deviations were used: Provincial Electricity Authority (PEA:2016) See table 5.2.1 and 5.2.2	P
5.2.1	Over/under voltage When the interface voltage deviates outside the conditions specified in Table 2, the photovoltaic system shall cease to energize the utility distribution system. This applies to any phase of a multiphase system. All discussions regarding system voltage refer to the local nominal voltage. The system shall sense abnormal voltage and respond. The following conditions should be met, with voltages in RMS and measured at the point of utility connection. (see clause 5.2.1 Table 2 – Response to abnormal voltages) The purpose of the allowed time delay is to ride through short-term disturbances to avoid excessive nuisance tripping. The unit does not have to cease to energize if the voltage returns to the normal utility continuous operation condition within the specified trip time.	The following deviations were used: Provincial Electricity Authority (PEA:2016) See table 5.2.1	P

IEC61727:2004			
Clause	Requirement – Test	Result – Remark	Verdict
SECTION 5: Personnel safety and equipment protection			
5.2.2	<p>Over/under frequency When the utility frequency deviates outside the specified conditions the photovoltaic system shall cease to energize the utility line. The unit does not have to cease to energize if the frequency returns to the normal utility continuous operation condition within the specified trip time.</p> <p>When the utility frequency is outside the range of ± 1 Hz, the system shall cease to energize the utility line within 0,2 s. The purpose of the allowed range and time delay is to allow continued operation for short-term disturbances and to avoid excessive nuisance tripping in weak-utility system conditions.</p>	<p>The following deviations were used: Provincial Electricity Authority (PEA:2016)</p> <p>See table 5.2.2</p>	P
5.3	<p>Islanding protection The PV system must cease to energize the utility line within 2 s of loss of utility.</p>	<p>The following deviations were used: Provincial Electricity Authority (PEA:2016)</p> <p>See table 6.1</p>	P
5.4	<p>Response to utility recovery Following an out-of-range utility condition that has caused the photovoltaic system to cease energizing, the photovoltaic system shall not energize the utility line for 20 s to 5 min after the utility service voltage and frequency have recovered to within the specified ranges.</p>	See table 5.2.1 and 5.2.2	P
5.5	<p>Earthing The utility interface equipment shall be earthed/grounded in accordance with IEC 60364-7-712.</p>	Stated in the manual.	P
5.6	<p>Short circuit protection The photovoltaic system shall have short-circuit protection in accordance with IEC 60364-7-712.</p>	Stated in the manual.	P
5.7	<p>Isolation and switching A method of isolation and switching shall be provided in accordance with IEC 60364-7-712.</p>	Stated in the manual.	P

Test overview:		
IEC 61727:2004		
Clause	Type Test	Result
4	Type test:	
4.3	Voltage Fluctuations and Flicker (see Annex 1 EMC Report)	P
4.4	Monitoring of DC-Injection	P
4.5	Normal frequency operating range (see 5.2.2 below)	P
4.6	Harmonics and waveform distortion	P
4.7	Power factor	P
5.2.1	Voltage monitoring	P
5.2.2	Frequency monitoring	P

IEC 62116:2008		
Clause	Type Test	Result
6.1	Islanding protection according table 6 - Load imbalance (real, reactive load) for test condition A (EUT output = 100%)	P
6.1	Load imbalance (reactive load) for test condition B (EUT output = 50 % – 66 %)	P
6.1	Load imbalance (reactive load) for test condition C (EUT output = 25 % – 33 %)	P

Deviations for Thailand according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016)		
Clause	Type Test	Result
3.4	Reactive power control	
3.4.1, 8.1.2	A fixed displacement factor $\cos\phi$	P
3.4.2, 8.1.2	A variable reactive power depending on the voltage Q(U)	N/A
3.5, 12.1	Active power control	P
3.6, 12.2	Low voltage fault ride through capability	N/A


Test Results

4.3 Voltage fluctuation and flicker 3.2, 8.3 Voltage Fluctuation Regulation (PEA 2016)				P																																																																																											
Test conditions:		Maximum permissible voltage fluctuation (expressed as a percentage of nominal voltage at 100 % power) and flicker as per EN 61000-3-2																																																																																													
	Starting	Stopping	Running																																																																																												
Limit	3,3%	3,3%	P _{st} =1,0	P _{It} =0,65																																																																																											
Test value	*	*	*	*																																																																																											
inverter <16A																																																																																															
Limit	dc% = 3,3		P _{st} =1,0	P _{It} =0,65																																																																																											
Test value	See below																																																																																														
<div style="display: flex; justify-content: space-between;"> Flicker Mode Uover: ■ ■ ■ ■ YOKOGAWA ◆ </div> <div style="display: flex; justify-content: space-between;"> Iover: ■ ■ ■ ■ Flicker: Complete 2:00:00 </div> <div style="margin-top: 10px;"> <p style="text-align: center;">Count ===== 12/12</p> <p style="text-align: center;">Interval ===== 10m00s/10m00s</p> <p>Element 1</p> <p>Volt Range 221V/50Hz Element1 Judgement: Pass</p> <p>Un (U1) 221.358 V Total Judgement: Pass</p> <p>Freq(U1) 49.999 Hz (Element1)</p> </div> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 10px;"> <thead> <tr> <th></th> <th>dc[%]</th> <th>dmax[%]</th> <th>d(t)[ms]</th> <th>Pst</th> <th>PIt</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">Limit</td> <td style="text-align: center;">3.30</td> <td style="text-align: center;">4.00</td> <td style="text-align: center;">500 3.30(%)</td> <td style="text-align: center;">1.00</td> <td style="text-align: center;">0.65 N: 12</td> </tr> <tr> <td style="text-align: center;">No. 1</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0 Pass</td> <td style="text-align: center;">0.07 Pass</td> <td></td> </tr> <tr> <td style="text-align: center;">2</td> <td style="text-align: center;">0.44 Pass</td> <td style="text-align: center;">0.47 Pass</td> <td style="text-align: center;">0 Pass</td> <td style="text-align: center;">0.09 Pass</td> <td></td> </tr> <tr> <td style="text-align: center;">3</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0 Pass</td> <td style="text-align: center;">0.07 Pass</td> <td></td> </tr> <tr> <td style="text-align: center;">4</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0 Pass</td> <td style="text-align: center;">0.07 Pass</td> <td></td> </tr> <tr> <td style="text-align: center;">5</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0 Pass</td> <td style="text-align: center;">0.07 Pass</td> <td></td> </tr> <tr> <td style="text-align: center;">6</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0 Pass</td> <td style="text-align: center;">0.07 Pass</td> <td></td> </tr> <tr> <td style="text-align: center;">7</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0 Pass</td> <td style="text-align: center;">0.07 Pass</td> <td></td> </tr> <tr> <td style="text-align: center;">8</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0 Pass</td> <td style="text-align: center;">0.07 Pass</td> <td></td> </tr> <tr> <td style="text-align: center;">9</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0 Pass</td> <td style="text-align: center;">0.07 Pass</td> <td></td> </tr> <tr> <td style="text-align: center;">10</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0 Pass</td> <td style="text-align: center;">0.07 Pass</td> <td></td> </tr> <tr> <td style="text-align: center;">11</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0.00 Pass</td> <td style="text-align: center;">0 Pass</td> <td style="text-align: center;">0.07 Pass</td> <td></td> </tr> <tr> <td style="text-align: center;">12</td> <td style="text-align: center;">0.05 Pass</td> <td style="text-align: center;">0.18 Pass</td> <td style="text-align: center;">0 Pass</td> <td style="text-align: center;">0.07 Pass</td> <td></td> </tr> <tr> <td style="text-align: center;">Result</td> <td style="text-align: center;">Pass</td> <td style="text-align: center;">Pass</td> <td style="text-align: center;">Pass</td> <td style="text-align: center;">Pass</td> <td style="text-align: center;">0.07 Pass</td> </tr> </tbody> </table>							dc[%]	dmax[%]	d(t)[ms]	Pst	PIt	Limit	3.30	4.00	500 3.30(%)	1.00	0.65 N: 12	No. 1	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass		2	0.44 Pass	0.47 Pass	0 Pass	0.09 Pass		3	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass		4	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass		5	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass		6	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass		7	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass		8	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass		9	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass		10	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass		11	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass		12	0.05 Pass	0.18 Pass	0 Pass	0.07 Pass		Result	Pass	Pass	Pass	Pass	0.07 Pass
	dc[%]	dmax[%]	d(t)[ms]	Pst	PIt																																																																																										
Limit	3.30	4.00	500 3.30(%)	1.00	0.65 N: 12																																																																																										
No. 1	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass																																																																																											
2	0.44 Pass	0.47 Pass	0 Pass	0.09 Pass																																																																																											
3	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass																																																																																											
4	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass																																																																																											
5	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass																																																																																											
6	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass																																																																																											
7	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass																																																																																											
8	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass																																																																																											
9	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass																																																																																											
10	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass																																																																																											
11	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass																																																																																											
12	0.05 Pass	0.18 Pass	0 Pass	0.07 Pass																																																																																											
Result	Pass	Pass	Pass	Pass	0.07 Pass																																																																																										
Update 3600		2020/06/06 10:26:15																																																																																													
<p>Note:</p> <p>*The stationary deviance of dc% is more relevant than the dynamic deviance of d_{max} at starting and stopping.</p> <p>Mains Impedance according EN61000-3-3: R_{max} = 0,24Ω; jX_{max} = 0,15Ω @50Hz (Z_{max} = 0,283 Ω) for single phase inverter use also R_n = 0,16Ω; jX_n = 0,1Ω</p> <p>Calculation of the maximum permissible grid impedance at the point of common coupling based on dc: $Z_{max} = Z_{ref} * 3,3\% / d_c(P_n)$</p> <p>The tests should be based on the limits of the EN 61000-3-2 for less than 16A.</p>																																																																																															

4.4 Monitoring of Permanent DC-Injection 3.3, 8.5 Direct Current Dispatch to the Power Network System (PEA:2016)	P
---	---

PEA Limit:	0,5% of I_{nom} : 75mA		
Output power:	33%	66%	100%
Max. test value (mA):	17	19	22
Mean test value(mA) :	11	11	10

Diagram of permanent DC-injection



Note:

4.6 Harmonic Current Limit Test the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016)				P
33% Output Power				
Watts (kW)		1119		
VA (kVA)		1122		
Vrms (V)		220,19		
Arms (A)		5,098		
PF		0,9972		
Frequency (Hz)		50,00		
THD40 (%)		0,250		
Harmonics	Current Magnitude [A]	% of Rated Current	Phase	Harmonic Current Limits [%]
1st	5,088	33,921	Single Phase	--
2nd	0,013	0,084	Single Phase	1
3rd	0,012	0,080	Single Phase	4
4th	0,006	0,042	Single Phase	1
5th	0,003	0,017	Single Phase	4
6th	0,003	0,023	Single Phase	1
7th	0,002	0,016	Single Phase	4
8th	0,003	0,022	Single Phase	1
9th	0,003	0,019	Single Phase	4
10th	0,003	0,017	Single Phase	1
11th	0,006	0,042	Single Phase	2
12th	0,003	0,017	Single Phase	0,5
13th	0,007	0,046	Single Phase	2
14th	0,002	0,016	Single Phase	0,5
15th	0,007	0,047	Single Phase	2
16th	0,005	0,032	Single Phase	0,5
17th	0,008	0,054	Single Phase	1,5
18th	0,003	0,018	Single Phase	0,375
19th	0,009	0,058	Single Phase	1,5
20th	0,002	0,015	Single Phase	0,375
21th	0,007	0,049	Single Phase	1,5
22th	0,003	0,020	Single Phase	0,375
23th	0,007	0,048	Single Phase	0,6
24th	0,002	0,015	Single Phase	0,15
25th	0,008	0,054	Single Phase	0,6
26th	0,002	0,014	Single Phase	0,15
27th	0,008	0,056	Single Phase	0,6
28th	0,003	0,017	Single Phase	0,15
29th	0,008	0,056	Single Phase	0,6
30th	0,002	0,012	Single Phase	0,15
31th	0,008	0,055	Single Phase	0,6
32th	0,002	0,011	Single Phase	0,15
33th	0,008	0,055	Single Phase	0,6
34th	0,001	0,008	Single Phase	0,15

35th	0,008	0,056	Single Phase	0,3
36th	0,001	0,009	Single Phase	0,075
37th	0,008	0,053	Single Phase	0,3
38th	0,001	0,008	Single Phase	0,075
39th	0,008	0,050	Single Phase	0,3
40th	0,002	0,010	Single Phase	0,075
66% Output Power				
Watts (kW)		2218		
VA (kVA)		2220		
Vrms (V)		220,54		
Arms (A)		10,068		
PF		0,9989		
Frequency (Hz)		50,00		
THD40 (%)		0,253		
Harmonics	Current Magnitude [A]	% of Rated Current	Phase	Harmonic Current Limits [%]
1st	10,063	67,084	Single Phase	--
2nd	0,016	0,106	Single Phase	1
3rd	0,017	0,113	Single Phase	4
4th	0,006	0,037	Single Phase	1
5th	0,007	0,044	Single Phase	4
6th	0,005	0,032	Single Phase	1
7th	0,006	0,040	Single Phase	4
8th	0,004	0,029	Single Phase	1
9th	0,005	0,035	Single Phase	4
10th	0,005	0,030	Single Phase	1
11th	0,006	0,037	Single Phase	2
12th	0,004	0,030	Single Phase	0,5
13th	0,008	0,051	Single Phase	2
14th	0,003	0,020	Single Phase	0,5
15th	0,009	0,059	Single Phase	2
16th	0,005	0,031	Single Phase	0,5
17th	0,005	0,035	Single Phase	1,5
18th	0,004	0,029	Single Phase	0,375
19th	0,007	0,045	Single Phase	1,5
20th	0,003	0,019	Single Phase	0,375
21th	0,006	0,042	Single Phase	1,5
22th	0,004	0,025	Single Phase	0,375
23th	0,006	0,038	Single Phase	0,6
24th	0,002	0,015	Single Phase	0,15
25th	0,006	0,042	Single Phase	0,6
26th	0,002	0,015	Single Phase	0,15
27th	0,006	0,043	Single Phase	0,6
28th	0,002	0,016	Single Phase	0,15
29th	0,006	0,039	Single Phase	0,6
30th	0,002	0,012	Single Phase	0,15
31th	0,006	0,038	Single Phase	0,6
32th	0,002	0,010	Single Phase	0,15

33th	0,005	0,035	Single Phase	0,6
34th	0,001	0,009	Single Phase	0,15
35th	0,006	0,037	Single Phase	0,3
36th	0,001	0,009	Single Phase	0,075
37th	0,005	0,035	Single Phase	0,3
38th	0,001	0,009	Single Phase	0,075
39th	0,005	0,032	Single Phase	0,3
40th	0,002	0,011	Single Phase	0,075
100% Output Power				
Watts (kW)		3,277		
VA (kVA)		3,280		
Vrms (V)		220,86		
Arms (A)		12,852		
PF		0,9990		
Frequency (Hz)		50,00		
THD40 (%)		0,682		
Harmonics	Current Magnitude [A]	% of Rated Current	Phase	Harmonic Current Limits [%]
1st	14,847	98,980	Single Phase	--
2nd	0,022	0,145	Single Phase	1
3rd	0,087	0,582	Single Phase	4
4th	0,013	0,086	Single Phase	1
5th	0,057	0,379	Single Phase	4
6th	0,009	0,058	Single Phase	1
7th	0,041	0,271	Single Phase	4
8th	0,008	0,056	Single Phase	1
9th	0,028	0,188	Single Phase	4
10th	0,003	0,023	Single Phase	1
11th	0,013	0,089	Single Phase	2
12th	0,004	0,029	Single Phase	0,5
13th	0,012	0,083	Single Phase	2
14th	0,002	0,015	Single Phase	0,5
15th	0,010	0,068	Single Phase	2
16th	0,006	0,042	Single Phase	0,5
17th	0,012	0,079	Single Phase	1,5
18th	0,003	0,019	Single Phase	0,375
19th	0,011	0,072	Single Phase	1,5
20th	0,002	0,014	Single Phase	0,375
21th	0,007	0,049	Single Phase	1,5
22th	0,003	0,017	Single Phase	0,375
23th	0,006	0,042	Single Phase	0,6
24th	0,003	0,018	Single Phase	0,15
25th	0,007	0,046	Single Phase	0,6
26th	0,002	0,015	Single Phase	0,15
27th	0,008	0,051	Single Phase	0,6
28th	0,005	0,031	Single Phase	0,15
29th	0,007	0,046	Single Phase	0,6
30th	0,003	0,017	Single Phase	0,15

31th	0,006	0,041	Single Phase	0,6
32th	0,002	0,015	Single Phase	0,15
33th	0,006	0,037	Single Phase	0,6
34th	0,002	0,011	Single Phase	0,15
35th	0,005	0,035	Single Phase	0,3
36th	0,002	0,012	Single Phase	0,075
37th	0,006	0,042	Single Phase	0,3
38th	0,002	0,014	Single Phase	0,075
39th	0,006	0,037	Single Phase	0,3
40th	0,002	0,014	Single Phase	0,075

Note: The harmonics are tested and evaluated according the IEEE1547.1-2005 clause 5.11.1 according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016).

4.6 Harmonic Voltage Limit Test the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016)				P	
Vrms (V)		220,27			
Frequency (Hz)		50,00			
THD50 (%)		0,378			
Harmonics	Voltage Magnitude [V]	% of Rated Voltage	Phase	Limits [%]	
2nd	0,013	0,006	Single Phase	0,2	
3rd	0,453	0,206	Single Phase	4	
4th	0,009	0,004	Single Phase	0,2	
5th	0,397	0,180	Single Phase	4	
6th	0,017	0,008	Single Phase	0,2	
7th	0,332	0,151	Single Phase	4	
8th	0,017	0,008	Single Phase	0,2	
9th	0,265	0,120	Single Phase	2	
10th	0,016	0,007	Single Phase	0,2	
11th	0,218	0,099	Single Phase	0,1	
12th	0,017	0,008	Single Phase	0,1	
13th	0,180	0,082	Single Phase	0,1	
14th	0,018	0,008	Single Phase	0,1	
15th	0,147	0,067	Single Phase	0,1	
16th	0,015	0,007	Single Phase	0,1	
17th	0,112	0,051	Single Phase	0,1	
18th	0,014	0,006	Single Phase	0,1	
19th	0,083	0,038	Single Phase	0,1	
20th	0,016	0,007	Single Phase	0,1	
21th	0,064	0,029	Single Phase	0,1	
22th	0,012	0,006	Single Phase	0,1	
23th	0,052	0,023	Single Phase	0,1	
24th	0,012	0,005	Single Phase	0,1	
25th	0,044	0,020	Single Phase	0,1	
26th	0,012	0,005	Single Phase	0,1	
27th	0,037	0,017	Single Phase	0,1	
28th	0,012	0,005	Single Phase	0,1	
29th	0,034	0,016	Single Phase	0,1	
30th	0,011	0,005	Single Phase	0,1	
31th	0,034	0,015	Single Phase	0,1	
32th	0,011	0,005	Single Phase	0,1	
33th	0,031	0,014	Single Phase	0,1	
34th	0,011	0,005	Single Phase	0,1	
35th	0,035	0,016	Single Phase	0,1	
36th	0,011	0,005	Single Phase	0,1	
37th	0,032	0,015	Single Phase	0,1	
38th	0,011	0,005	Single Phase	0,1	
39th	0,035	0,016	Single Phase	0,1	
40th	0,016	0,007	Single Phase	0,1	
41th	0,030	0,013	Single Phase	N/A	



42th	0,011	0,005	Single Phase	N/A
43th	0,035	0,016	Single Phase	N/A
44th	0,011	0,005	Single Phase	N/A
45th	0,032	0,015	Single Phase	N/A
46th	0,011	0,005	Single Phase	N/A
47th	0,029	0,013	Single Phase	N/A
48th	0,011	0,005	Single Phase	N/A
49th	0,034	0,015	Single Phase	N/A
50th	0,011	0,005	Single Phase	N/A


Note: The harmonics are tested and evaluated according the IEEE1547.1-2005 clause 5.11.1 according the grid-connected inverter regulations of the Provincial Electricity Authority (PEA:2016).

4.7 Power factor(PEA) 3.1, 8.4 Harmonic Regulation (PEA: 2016)						P
Test conditions:						
Output power [kW]	~10%	~25%	~50%	~75%	~100%	
Test AC voltage [V]						
220	--	--	--	--	--	
<p>Note:</p> <p>The PV system shall have a lagging power factor greater than 0,95 when the output is greater than 50% of the rated inverter output power.</p> <p>The letter “i” is short for “inductive” and indicates inductive power factor. In case of capacitive power factor the letter “c” is used instead.</p> <p>Test result refer to table 3.4.1, 8.1.2 1.</p>						


5.2.1 Voltage monitoring 3.7, 12.3 Under and Over Voltage Protection (PEA:2016) 3.10, 12.5 Response to utility recovery (PEA:2016)				P
First Level (Phase to Neutral)				
Test conditions:	Output power: 5KW Frequency: 50Hz			
	Under Voltage		Over Voltage	
		Voltage [V]		Voltage [V]
Set value		198V		242V
Measured trip value		197,6		242,2
		197,6		242,3
		197,6		242,2
Parameter		Time [s]		Time [s]
Limit		<= 2,0s		<= 1,0s
Disconnection time	220V to 203V (4s min) to 193V	1,780	220V to 237V (2s min) to 247V	0,620
		1,820		0,640
		1,780		0,660
Reconnection time	20s - 5min	75s	20s - 5min	74s

Second Level (Phase to Neutral)				
Test conditions:	Output power: 5KW Frequency: 50Hz			
	Under Voltage		Over Voltage	
Parameter		Voltage [V]		Voltage [V]
Set value		110V		264V
Measured trip value		109,6		264,9
		109,6		264,9
		109,6		264,9
Parameter		Time [ms]		Time [ms]
Limit		<= 300ms		<= 160ms
Disconnection time	220V to 203V (0.6s min) to 105V	0,208	220V to 237V (0.32s min) to 269V	0,078
		0,200		0,098
		0,196		0,094
Reconnection time	20s - 5min	76s	20s - 5min	74s
<p>Note: Note: The tests are according PEA 8/9/2556. The voltage settings of the EUT are set for the tests as stated to 198V, 110V for undervoltage and 242V, 264V for overvoltage. Response to utility recovery is according to the appropriate IEEE or IEC standard test methods.</p>				

Under Voltage First Level single phase



Over voltage First Level single phase




Note: CH1: grid voltage(500V/div); CH2: Current of EUT; CH4: trip signal

Under Voltage Second Level single phase




Over voltage Second Level single phase




Note: CH1: grid voltage(500V/div); CH2: Current of EUT; CH4: trip signal

Reconnection after Under Voltage First Level




Reconnection after Over Voltage First Level




Note:

Reconnection after Under Voltage Second Level




Reconnection after Over Voltage Second Level




Note:

5.2.2 Frequency monitoring				P
IEC 61727 8.2 Under and Over Frequency Protection (PEA:2016) 3.10, 12.5 Response to utility recovery (PEA:2016)				
Test conditions:	Any output power level			
	Under frequency		Over frequency	
Parameter		Frequency [Hz]		Frequency [Hz]
Output Voltage		U_N		U_N
Set value		47,00Hz		52,00Hz
Measured trip value(V)		46,99		52,02
		46,99		52,02
		46,99		52,02
		Time [ms]		Time [ms]
Limit		<= 100ms		<= 100ms
Disconnection time(ms)	50,0Hz to 47,2 Hz (0,2s min) to 46,5 Hz	82	50,0 Hz to 51,80 Hz (0,2s min) to 52,5Hz	72
		76		68
		66		76
Reconnection time (Sec)	20s – 5min	72s	20s-5min	76s
Note: The frequency which inverter stops feeding power to electrical system in each test must be in the range of the frequency trip setting +/- 0,1Hz and the time it takes to cut off the power must be within 0.1 second. The tests are performed according the IEEE 1547.1-2005, annex A. Response to utility recovery is according to the appropriate IEEE or IEC standard test methods.				

Under Frequency:




Over Frequency:




Note:

CH1: grid voltage(500V/div); CH2: Current of EUT(20A/div); CH4: trip signal

Reconnection after Under Frequency:



Reconnection after Over Frequency:



Note:


CH1: grid voltage(300V/div); CH2: Current of EUT(15A/div); CH4: trip signal

6.1 Islanding protection
3.9, 12.4 Anti-Islanding (PEA:2016)

Test circuit and parameters

Parameter	Symbol	Units
EUT DC Input		
DC voltage	V_{DC}	V
DC Current	I_{DC}	A
DC Power	P_{DC}	W
EUT AC output		
AC voltage	V_{EUT}	V
AC current	I_{EUT}	A
Real power	P_{EUT}	W
Reactive power	Q_{EUT}	VAR
Test Load		
Resistive load current	I_R	A
Inductive load current	I_L	A
Capacitive load current	I_C	A
AC (utility) power source		
Utility real power	P_{AC}	W
Utility reactive power	Q_{AC}	VAR
Utility current	I_{AC}	A

Block diagram test circuit IEC 62116:2008




IEC 1567/08

Figure 1 – Test circuit for islanding detection function in a power conditioner (inverter)

6.1 Islanding protection according table 6 - Load imbalance (real, reactive load) for test condition A (EUT output = 100%) 3.9, 12.4 Anti-Islanding (PEA:2016)									P
Test conditions			Frequency: 50+/-0,1Hz U _N =220+/-3Vac Distortion factor of chokes < 2% Quality = 1						
Disconnection limit			1s						
No	P _{EUT} ¹⁾ (% of EUT rating)	Reactive load (% of Q _L in 6.1.d) 1)	P _{AC} ²⁾ (% of nominal)	Q _{AC} ³⁾ (% of nominal)	Run on Time (ms)	P _{EUT} (W per phase)	Actual Q _f	V _{DC} (V)	Remarks ⁴⁾
1	100	100	0	0	646	3300	1,001	400	Test A at BL
4	100	100	-5	-5	550	3300	1,027	400	Test A at IB
5	100	100	-5	0	630	3300	1,053	400	Test A at IB
6	100	100	-5	+5	622	3300	1,079	400	Test A at IB
7	100	100	0	-5	502	3300	0,975	400	Test A at IB
8	100	100	0	+5	574	3300	1,025	400	Test A at IB
9	100	100	+5	-5	515	3300	0,929	400	Test A at IB
10	100	100	+5	0	622	3300	0,953	400	Test A at IB
11	100	100	+5	+5	586	3300	0,977	400	Test A at IB
Parameter at 0% per phase			L= 50,82 mH		R= 15,98 Ω		C= 199,37 μF		
IAC fundamental current(A)			140mA						
<p>Note: RLC is adjusted to min. +/-1% of the inverter rated output power 1) P_{EUT}: EUT output power 2) P_{AC}: Real power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value. 3) Q_{AC}: Reactive power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value. 4) BL: Balance condition, IB: Imbalance condition.</p> <p>Condition A: EUT output power P_{EUT} = Maximum ⁵⁾ EUT input voltage ⁶⁾ = >90% of rated input voltage range</p> <p>⁵⁾ Maximum EUT output power condition should be achieved using the maximum allowable input power. Actual output power may exceed nominal rated output. ⁶⁾ Based on EUT rated input operating range. For example, If range is between X volts and Y volts, 90 % of range = X + 0,9 × (Y – X). Y shall not exceed 0,8 × EUT maximum system voltage (i.e., maximum allowable array open circuit voltage). In any case, the EUT should not be operated outside of its allowable input voltage range.</p>									

Disconnection at P_{AC} 0% and Q_{AC} 0% reactive load No. 1

DSO-X 3014A, MY58101647: Tue Jun 09 13:35:14 2020




Attention:

All relays are direct coupled and open directly by receiving the islanding signal from the controller.

Note:

6.1 Islanding protection according Table 7 – Load imbalance (reactive load) for test condition B (EUT output = 50 % – 66 %) 3.9, 12.4 Anti-Islanding (PEA:2016)									P
Test conditions		Frequency: 50+/-0,1Hz U _N =220+/-3Vac Distortion factor of chokes < 2% Quality =1							
Disconnection limit		1s							
No	P _{EUT} ¹⁾ (% of EUT rating)	Reactive load (% of Q _L in 6.1.d) 1)	P _{AC} ²⁾ (% of nominal)	Q _{AC} ³⁾ (% of nominal)	Run on Time (ms)	P _{EUT} (W per phase)	Actual Qf	V _{DC} (V)	Remarks ⁴⁾
1	66	66	0	-5	536	2200	0,975	245	Test B at IB
2	66	66	0	-4	658	2200	0,980	245	Test B at IB
3	66	66	0	-3	632	2200	0,985	245	Test B at IB
4	66	66	0	-2	612	2200	0,990	245	Test B at IB
5	66	66	0	-1	650	2200	0,995	245	Test B at IB
6	66	66	0	0	664	2200	1,000	245	Test B at BL
7	66	66	0	1	574	2200	1,005	245	Test B at IB
8	66	66	0	2	634	2200	1,010	245	Test B at IB
9	66	66	0	3	624	2200	1,015	245	Test B at IB
10	66	66	0	4	560	2200	1,020	245	Test B at IB
11	66	66	0	5	538	2200	1,025	245	Test B at IB
Parameter at 0% per phase			L= 76,19 mH		R= 23,94 Ω		C= 132,98 μF		
IAC fundamental current(A)			140mA						
<p>Note: RLC is adjusted to min. +/-1% of the inverter rated output power 1) P_{EUT}: EUT output power 2) P_{AC}: Real power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value. 3) Q_{AC}: Reactive power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value. 4) BL: Balance condition, IB: Imbalance condition. Condition B: EUT output power P_{EUT} = 50 % – 66 % of maximum EUT input voltage⁵⁾ = 50 % of rated input voltage range, ±10 % 5) Based on EUT rated input operating range. For example, If range is between X volts and Y volts, 50 % of range = X + 0,5 × (Y – X). Y shall not exceed 0,8 × EUT maximum system voltage (i.e., maximum allowable array open circuit voltage). In any case, the EUT should not be operated outside of its allowable input voltage range.</p>									

Disconnection at P_{AC} 0% and Q_{AC} 0% reactive load No. 6



Attention:


All relays are direct coupled and open directly by receiving the islanding signal from the controller.

Note:

6.1 Islanding protection according Table 7 – Load imbalance (reactive load) for test condition C (EUT output = 25 % – 33 %) 3.9, 12.4 Anti-Islanding (PEA:2016)									P
Test conditions		Frequency: 50+/-0,1Hz U _N =220+/-3Vac Distortion factor of chokes < 2% Quality =1							
Disconnection limit		1s							
No	P _{EUT} ¹⁾ (% of EUT rating)	Reactive load (% of Q _L in 6.1.d) 1)	P _{AC} ²⁾ (% of nominal)	Q _{AC} ³⁾ (% of nominal)	Run on Time (ms)	P _{EUT} (W per phase)	Actual Q _f	V _{DC} (V)	Remarks ⁴⁾
1	33	33	0	-5	550	1100	0,975	107	Test C at IB
2	33	33	0	-4	554	1100	0,980	107	Test C at IB
3	33	33	0	-3	554	1100	0,985	107	Test C at IB
4	33	33	0	-2	554	1100	0,990	107	Test C at IB
5	33	33	0	-1	566	1100	0,995	107	Test C at IB
6	33	33	0	0	646	1100	1,000	107	Test C at BL
7	33	33	0	1	588	1100	1,005	107	Test C at IB
8	33	33	0	2	630	1100	1,010	107	Test C at IB
9	33	33	0	3	600	1100	1,015	107	Test C at IB
10	33	33	0	4	582	1100	1,020	107	Test C at IB
11	33	33	0	5	578	1100	1,025	107	Test C at IB
Parameter at 0% per phase			L= 149,01 mH		R= 46,82 Ω		C= 67,99 μF		
IAC fundamental current(A)			140mA						
<p>Note: RLC is adjusted to min. +/-1% of the inverter rated output power 1) P_{EUT}: EUT output power 2) P_{AC}: Real power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value. 3) Q_{AC}: Reactive power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0 % test condition value. 4) BL: Balance condition, IB: Imbalance condition. Condition C: EUT output power P_{EUT} = 25 % – 33 %⁵⁾ of maximum EUT input voltage⁶⁾ = <10 % of rated input voltage range 5) Or minimum allowable EUT output level if greater than 33 %. 6) Based on EUT rated input operating range. For example, If range is between X volts and Y volts, 10 % of range = X + 0,1 × (Y – X). Y shall not exceed 0,8 × EUT maximum system voltage (i.e., maximum allowable array open circuit voltage). In any case, the EUT should not be operated outside of its allowable input voltage range.</p>									

Disconnection at P_{AC} 0% and Q_{AC} 0% reactive load No. 6

DSO-X 3014A, MY58101647: Tue Jun 09 13:35:14 2020



Attention:

All relays are direct coupled and open directly by receiving the islanding signal from the controller.


Note:

PEA:2016 additional test						P
3.4 Reactive power control(PEA:2016)						P
Test conditions:		Output: 220 Vac,50Hz				
P (setting)	P(kW)ind	P(kW)cap	Q(kVar)ind, max	Q(kVar)cap, max	PFind, max	PFcap, max
0%	0,160	0,161	-0,135	0,156	0,7634	0,7182
10%	0,329	0,330	-0,190	0,262	0,8660	0,8831
20%	0,669	0,671	-0,327	0,334	0,8983	0,8950
30%	1,007	1,009	-0,475	0,495	0,9044	0,8978
40%	1,343	1,344	-0,626	0,656	0,9062	0,8986
50%	1,676	1,678	-0,825	0,816	0,8970	0,8993
60%	2,007	2,010	-0,982	0,975	0,8982	0,8998
70%	2,337	2,339	-1,133	1,133	0,8998	0,8999
80%	2,666	2,668	-1,281	1,294	0,9013	0,8998
90%	3,044	2,994	-1,454	1,454	0,9023	0,8994
100%	3,136	3,193	-1,492	1,549	0,9030	0,8996
Note:						

PEA:2016 additional test					P
3.4.1, 8.1.2 1) A fixed displacement factor $\cos\phi$					P
Test conditions:		Output: 220 Vac,50Hz			
P (setting)	PF (setting)	P(kW)	Q(kVar)	PF	
0%	0,90 lagging	0,160	-0,135	0,7634	
10%	0,90 lagging	0,329	-0,190	0,8660	
20%	0,90 lagging	0,669	-0,327	0,8983	
30%	0,90 lagging	1,007	-0,475	0,9044	
40%	0,90 lagging	1,343	-0,626	0,9062	
50%	0,90 lagging	1,676	-0,825	0,8970	
60%	0,90 lagging	2,007	-0,982	0,8982	
70%	0,90 lagging	2,337	-1,133	0,8998	
80%	0,90 lagging	2,666	-1,281	0,9013	
90%	0,90 lagging	3,044	-1,454	0,9023	
100%	0,90 lagging	3,136	-1,492	0,9030	
P (setting)	PF (setting)	P(kW)	Q(kVar)	PF	
0%	0,90 leading	0,161	0,156	0,7182	
10%	0,90 leading	0,330	0,262	0,7831	
20%	0,90 leading	0,671	0,334	0,8950	
30%	0,90 leading	1,009	0,495	0,8978	
40%	0,90 leading	1,344	0,656	0,8986	
50%	0,90 leading	1,678	0,816	0,8993	
60%	0,90 leading	2,010	0,975	0,8998	
70%	0,90 leading	2,339	1,133	0,8999	
80%	0,90 leading	2,668	1,294	0,8998	
90%	0,90 leading	2,994	1,454	0,8994	
100%	0,90 leading	3,193	1,549	0,8996	
P (setting)	PF (setting)	P(kW)	Q(kVar)	PF	
0%	1,00	0,161	0,015	0,9142	
10%	1,00	0,331	0,070	0,9780	
20%	1,00	0,671	0,067	0,9950	
30%	1,00	1,010	0,073	0,9974	




40%	1,00	1,347	0,080	0,9982
50%	1,00	1,683	0,088	0,9986
60%	1,00	2,016	0,097	0,9988
70%	1,00	2,348	0,109	0,9989
80%	1,00	2,679	0,125	0,9989
90%	1,00	3,008	0,142	0,9989
100%	1,00	3,328	0,161	0,9988
Note:				

<p>PEA:2016 additional test</p>	<p>N/A</p>										
<p>3.4.2, 8.1.2 2) A variable reactive power depending on the voltage Q(U) (PEA:2016) (Power generation system is greater than 500kW)</p>	<p>N/A</p>										
<p>The purpose of the test is to ensure that the converter complies with the methods for automatically supplying reactive power according to the standard characteristic curve Q(U) indicated in 1.5.</p> <p>Activation must be at the Distributor's request, when the Operating Regulations are issued. The Distributor shall also specify the values of the parameters that uniquely characterise the curve, i.e.: V1i, V2i, V1s and V1s as well as the lock-in value of active power (default value $P = 0,2 P_n$).</p> <p>The parameters V1i, V2i, V1s and V1s should be set in the range between 0,9 and 1,1 with 0,01 V_n steps. In order to facilitate execution of the type tests, the characterising parameters are conventionally set as follows: $V1s = 1,08 V_n$; $V2s = 1,1 V_n$ $V1i = 0,92 V_n$; $V2i = 0,9 V_n$ and the active power lock-in value (default value $P = 0,2 P_n$).</p> <div style="text-align: center;">  <p>The graph shows a characteristic curve for reactive power Q as a function of voltage V. The vertical axis is labeled Q and has markers for Qmax and -Qmax. The horizontal axis is labeled V and has markers for V2i, V2s, V1s, and V1i. The curve starts at a constant positive Qmax for V < V2i, then decreases linearly to zero at V = V2i. It remains at zero until V = V1s, then decreases linearly to a constant negative value -Qmax at V = V2s, and remains constant at -Qmax for V > V2s. The following table summarizes the key parameters from the graph:</p> <table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> </tr> </thead> <tbody> <tr> <td>V_{2s}</td> <td>$1,1 V_n$</td> </tr> <tr> <td>V_{1s}</td> <td>$1,08 V_n$</td> </tr> <tr> <td>V_{2i}</td> <td>$0,92 V_n$</td> </tr> <tr> <td>V_{1i}</td> <td>$0,9 V_n$</td> </tr> </tbody> </table> </div>		Parameter	Value	V_{2s}	$1,1 V_n$	V_{1s}	$1,08 V_n$	V_{2i}	$0,92 V_n$	V_{1i}	$0,9 V_n$
Parameter	Value										
V_{2s}	$1,1 V_n$										
V_{1s}	$1,08 V_n$										
V_{2i}	$0,92 V_n$										
V_{1i}	$0,9 V_n$										

PEA:2016 additional test			P
3.5, 12.1 Active power control (PEA:2016)			P
Setpoint in power bin [%]	P_{setpoint} [kW]	P₆₀ [kW]	Decrease time (s)
100%	3,300	3,326	9s
90%	2,970	3,001	9s
80%	2,640	2,669	9s
70%	2,310	2,338	9s
60%	1,980	2,007	9s
50%	1,650	1,692	9s
40%	1,320	1,345	9s
30%	0,990	1,014	9s
20%	0,660	0,683	9s
10%	0,330	0,353	9s
0%	0,000	0,179	9s

Graph of the setting accuracy



Note:


PEA:2016 additional test		N/A
3.6, 12.2 Low voltage fault Ride through capability (PEA:2016) (Power generation system is greater than 500kW)		N/A
Test List	V(V/V_n)	Duration time (Sec)
Test P>0,9P_n*		
Three-phase faults	0,7-0,8V _n	---
	0,3-0,5V _n	---
	0-0,05V _n	---
Phase to phase faults		
	0,7-0,8V _n	---
	0,3-0,5V _n	---
	0-0,05V _n	---
Single phase to ground faults		
	0,7-0,8V _n	---
	0,3-0,5V _n	---
	0-0,05V _n	---
Test P=0,3P_n		
Three-phase faults	0,7-0,8V _n	---
	0,3-0,5V _n	---
	0-0,049V _n	---
Phase to phase faults		
	0,7-0,8V _n	---
	0,3-0,5V _n	---
	0-0,049V _n	---
Single phase to ground faults		
	0,7-0,8V _n	---
	0,3-0,5V _n	---
	0-0,049V _n	---
Test P=0,1 P_n		
Three-phase faults	0,7-0,8V _n	---
	0,3-0,5V _n	---
	0-0,049V _n	---
Phase to phase faults		
	0,7-0,8V _n	---
	0,3-0,5V _n	---
	0-0,049V _n	---

Single phase to ground faults	0,7-0,8V _n	---
	0,3-0,5V _n	---
	0-0,049V _n	---

Note:

The PGS must not disconnected from grid while the PCC voltage dip period less than below curve limit.

- a) install and connect the PGS and recommendation of the technical requirements of the equipment manufacturer .
- b) Check all parameters of power supply in normal conditions, the operation of power system equipment .
- c) testing by simulation the voltage . (I try to short-circuit in the power network) in the electricity network to balance the pressure between 70-80%V_n , 30-50%V_n, and less than 5 percent of the normal operating pressure .
- d) Record the maximum time power system can still connect to the electricity network as shown on above table.





Annex 1

Pictures of the unit

Enclosure front view




Enclosure rear view




Terminal side view




Internal view-1




Main power board component side view




Main power board solder side view




Display board component side view




Display board solder side view




RS232 board side view




RS232 board solder side view




Capcitor board solder side view



Display board component side view



Display board solder side view





Annex 2

Test equipment list

Testing Location: Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch
Dates of performance test: 2020-03-20 to 2020-06-23

Equipment	Internal No.	Manufacturer	Type	Serial No.	Last Calibration
Power Analyzer	A4080002DG	YOKOGAWA	WT3000	91M210852	Sep. 12, 2019
AC Source	A7040019DG	Chroma	61512	61512000439	Monitored by Power Analyzer
AC Source	A7040020DG	Chroma	61512	61512000438	
DC Simulation Power Supply	A7040016DG	Chroma	62150H-1000S	62150EF00490	
DC Simulation Power Supply	A7040017DG	Chroma	620028	620028EF00120	
RLC Load	A7150027DG	Qunling	ACLT-3803H	93VOO2869	
Digital Phosphor Oscilloscope	//	KEYSIGHT	DSOX3014T	MY57231269	Jan. 14, 2020
Oscilloscope probel	A1490008DG	YOKOGAWA	701901	//	Sep. 20, 2019
Oscilloscope probel	A1490009DG	YOKOGAWA	701901	//	Sep. 20, 2019
Oscilloscope probel	A1490010DG	YOKOGAWA	701901	//	Sep. 20, 2019
Current transducer	A1060007DG	YOKOGAWA	CT200	1130700012	Sep. 12, 2019
Current transducer	A1060008DG	YOKOGAWA	CT200	1130700017	Sep. 12, 2019
Current transducer	A1060009DG	YOKOGAWA	CT200	1130700019	Sep. 12, 2019