



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA210072

Date of Issue: 15 March 2021

Regulatory Definition: Non-Prescribed
Product Description: Rechargeable Li-ion Battery Module
(With BMS, For use with grid-connected battery storage systems)

Additional Models	Trade Name	Rating/Marking
GTX3000-H5	AMASSTORE	Nominal voltage: 256V 50Ah 12.5kWh IP65, 0°C to +55°C, Li-ion Battery
GTX3000-H6	AMASSTORE	Nominal voltage: 307.2V, 50Ah 15kWh IP65, 0°C to +55°C, Li-ion Battery
GTX3000-H7	AMASSTORE	Nominal voltage: 358.4V 50Ah 17.5kWh IP65, 0°C to +55°C, Li-ion Battery
GTX3000-H8	AMASSTORE	Nominal voltage: 409.6V 50Ah 20kWh IP65, 0°C to +55°C, Li-ion Battery
GTX3000-H9	AMASSTORE	Nominal voltage: 460.8V 50Ah 22.5kWh IP65, 0°C to +55°C, Li-ion Battery
GTX3000-H10	AMASSTORE	Nominal voltage: 512V 50Ah 25kWh IP65, 0°C to +55°C, Li-ion Battery

R. A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 15-03-21 210072/2