

Certificate of Conformity

By the product certificate number:

No. 2621/0055-1-CER/E1

Issued to

License holder: Shenzhen SOFARSOLAR Co., Ltd.
401, Building 4, AnTongDa Industrial Park, District 68,
XingDong Community, XinAn Street, BaoAn District.
Shenzhen City, Guangdong Province, P.R. China

Manufacturer: Dongguan SOFAR SOLAR Co., Ltd.
1F – 6F, Building E, No.1 JinQi Road, Bihu Industrial Park.
Wulian Village, Fenggang Town, Dongguan, P.R. China.



Trademark:



It is certified that the product:

Type of generator AC Coupled Storage Converter

Models:

ME 3000SP

Technical Data: Apparent Power (Charge/Discharge)

3 kVA

Rated Voltage

230 V

Rated Frequency

50 Hz

Firmware version

V2.80

Number of phases

Single phase

Isolation transformer

NO

Complies with the standard:

- **EN 50549-1: 2019** "Requirements for generating plants to be connected in parallel with distribution networks – Part 1: Connection to a LV Distribution Network - Generating Plants up to and including type B".

This certificate just covers PV inverters models certified below above-mentioned references to be installed in PV generating of type plants B to be connected to a LV distribution network (requirements for plants type A).

The above-mentioned product is certified according to the standard EN 50549-1: 2019 and is valid to be installed in PV generating of type plants A to be connected to a LV distribution network. The relation between this European Standard with the relevant Article of COMMISSION REGULATION (EU) 2016/631 (NC RfG) is considered as it is indicated in the annex H of the standard EN 50549-1:2019.

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-53 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate cancels and supersedes the certificate No. 2621/0055-1-CER.

First issued on: 25th of February 2021

This certificate is valid until: 25th of February 2024.

Madrid, 27th April 2021

Daniel Arranz Muñiz
Certification Manager

