




# TEST REPORT



## AS\_NZS 4777.2

Grid connection of energy systems via inverters

Part 2: Inverter requirements

<b>Report reference number</b> .....	<b>PVAU200224N005-2-R1</b>
Date of issue .....	2021-03-23
Total number of pages .....	30
<b>Testing laboratory name</b> .....	<b>Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch</b>
Address .....	No. 96, Guantai Road (Houjie Section), Houjie Town, Dongguan City, Guangdong Province, 523942, People's Republic of China
<b>Applicant's name</b> .....	<b>Shenzhen SOFAR SOLAR Co., Ltd.</b>
Address .....	401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China
<b>Test specification</b>	
Standard .....	Short duration under voltage response test (LVRT capability) - Inverter Conformance Test Procedure For South Australia
Test report form number.....	LVRT For South Australia VER.0
Master TRF originator .....	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch
Matster TRF .....	Dated 2020-08-13
<b>Test item description</b> .....	<b>Solar Grid-tied Inverter</b>
Trademark .....	
Model / Type.....	SOFAR 3300TL-G3, SOFAR 3000TL-G3, SOFAR 2700TL-G3, SOFAR 2200TL-G3, SOFAR 1600TL-G3, SOFAR 1100TL-G3,
<small>This report is governed by, and incorporates by reference, CPS Conditions of Service as posted at the date of issuance of this report at <a href="http://www.bureauveritas.com/home/about-us/our-business/cps/about-us/terms-conditions">http://www.bureauveritas.com/home/about-us/our-business/cps/about-us/terms-conditions</a> and is intended for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. The results set forth in this report are not indicative or representative of the quality or characteristics of the lot from which a test sample was taken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. Measurement uncertainty is only provided upon request for accredited tests. You have 60 days from date of issuance of this report to notify us of any material error or omission caused by our negligence or if you require measurement uncertainty; provided, however, that such notice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise such issue within the prescribed time shall constitute you unqualified acceptance of the completeness of this report, the tests conducted and the correctness of the report contents.</small>	

<b>Ratings</b> .....	SOFAR 1100TL-G3	SOFAR 1600TL-G3	SOFAR 2200TL-G3
Input DC voltage [V] .....	Max. 500V		
MPP DC voltage range [V] .....	50-500V		
Input DC current [A].....	12,0A		
Output AC voltage [V].....	L/N/PE, 230Vac		
Output AC current [A] .....	Max. 5,3A	Max. 7,7A	Max. 10,6A
Initial short-current AC current $I_k$ [A].:	40	40	40
Output power [VA] .....	1100	1600	2200
<b>Ratings</b> .....	SOFAR 2700TL-G3	SOFAR 3000TL-G3	SOFAR 3300TL-G3
Input DC voltage [V] .....	Max. 550V		
MPP DC voltage range [V] .....	50-550V		
Input DC current [A].....	12,0A		
Output AC voltage [V].....	L/N/PE, 230Vac		
Output AC current [A] .....	Max. 13,0A	Max. 14,5A	Max. 16,0A
Initial short-current AC current $I_k$ [A].:	40	40	40
Output power [VA] .....	2700	3000	3300

<b>Testing Location.....:</b>	<b>Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch</b>
Address .....	No. 96, Guantai Road (Houjie Section), Houjie Town, Dongguan City, Guangdong Province, 523942, People's Republic of China
Tested by (name, function and signature) .....	Lukes Lin 
Approved by (name, function and signature) .....	James Huang 
<b>Manufacturer's name .....</b>	<b>Shenzhen SOFAR SOLAR Co., Ltd.</b>
Factory address.....	401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China.
<b>Factory's name .....</b>	<b>Dongguan SOFAR SOLAR Co.,Ltd.</b>
Factory address .....	1F - 6F, Building E, No. 1 JinQi Road, Bihu Industrial Park, Wulian Village, Fenggang Town, Dongguan City

Document History			
Date	Internal reference	Modification / Change / Status	Revision
2020-09-22	Lukes Lin	Initial report was written	0
2021-03-23	Lukes Lin	Updated the test of clause 2.2 and 2.3	R1
Supplementary information:			

<b>Test items particulars</b>	
Equipment mobility .....	Permanent connection
Operating condition .....	Continuous
Class of equipment.....	Class I
Protection against ingress of water ..	IP65 according to EN 60529
Mass of equipment [kg] .....	Approx. 5,5kg (SOFAR 1100TL-G3, SOFAR 1600TL-G3, SOFAR 2200TL-G3)
	Approx. 6,3kg (SOFAR 2700TL-G3, SOFAR 3000TL-G3, SOFAR 3300TL-G3)
<b>Test case verdicts</b>	
Test case does not apply to the test object .....	N/A
Test item does meet the requirement .....	P(ass)
Test item does not meet the requirement .....	F(ail)
<b>Testing</b>	
Date of receipt of test item .....	2020-09-08
Date(s) of performance of test .....	2020-09-08 to 2020-09-15,2021-03-22
<b>General remarks:</b>	
The test result presented in this report relate only to the object(s) tested.	
The report shall state compliance of the tested objects with the requirements of Short Duration Undervoltage Disturbance Ride-Through – Inverter Conformance Test Procedure for South Australia.	
This report must not be reproduced in part or in full without the written approval of the issuing testing laboratory.	
"(see Annex #)" refers to additional information appended to the report.	
"(see appended table)" refers to a table appended to the report.	
Throughout this report a comma is used as the decimal separator.	

Copy of marking plate


**SOFAR SOLAR** Solar Grid-tied Inverter

Model No. SOFAR 1100TL-G3

Max.DC Input Voltage	500V
Operating MPPT Voltage Range	50~500V
Max. Input Current	12A
Max. PV Isc	15A
Nominal Grid Voltage	L/N/PE,230Vac
Max. Output Current	5.3A
Nominal Grid Frequency	50/60Hz
Max. Output Power	1100VA
Power Factor	1(adjustable+/-0.8)
Ingress protection	IP65
Operating Temperature Range	-30~+60°C
Topology	Non-isolated
Protective Class	Class I

Manufacturer:Shenzhen SOFARSOLAR Co., Ltd.  
Address: 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China

VDE0126-1-1, VDE-AR-N4105, IEC61727, IEC62116, UTE C15-712-1, AS4777




**SOFAR SOLAR** Solar Grid-tied Inverter

Model No. SOFAR 1600TL-G3

Max.DC Input Voltage	500V
Operating MPPT Voltage Range	50~500V
Max. Input Current	12A
Max. PV Isc	15A
Nominal Grid Voltage	L/N/PE,230Vac
Max. Output Current	7.7A
Nominal Grid Frequency	50/60Hz
Max. Output Power	1600VA
Power Factor	1(adjustable+/-0.8)
Ingress protection	IP65
Operating Temperature Range	-30~+60°C
Topology	Non-isolated
Protective Class	Class I

Manufacturer:Shenzhen SOFARSOLAR Co., Ltd.  
Address: 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China

VDE0126-1-1, VDE-AR-N4105, IEC61727, IEC62116, UTE C15-712-1, AS4777




**SOFAR SOLAR** Solar Grid-tied Inverter

Model No. SOFAR 2200TL-G3

Max.DC Input Voltage	500V
Operating MPPT Voltage Range	50~500V
Max. Input Current	12A
Max. PV Isc	15A
Nominal Grid Voltage	L/N/PE,230Vac
Max. Output Current	10.6A
Nominal Grid Frequency	50/60Hz
Max. Output Power	2200VA
Power Factor	1(adjustable+/-0.8)
Ingress protection	IP65
Operating Temperature Range	-30~+60°C
Topology	Non-isolated
Protective Class	Class I

Manufacturer:Shenzhen SOFARSOLAR Co., Ltd.  
Address: 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China

VDE0126-1-1, VDE-AR-N4105, IEC61727, IEC62116, UTE C15-712-1, AS4777




**SOFAR SOLAR** Solar Grid-tied Inverter

Model No. SOFAR 2700TL-G3

Max.DC Input Voltage	550V
Operating MPPT Voltage Range	50~550V
Max. Input Current	12A
Max. PV Isc	15A
Nominal Grid Voltage	L/N/PE,230Vac
Max. Output Current	13A
Nominal Grid Frequency	50/60Hz
Max. Output Power	2700VA
Power Factor	1(adjustable+/-0.8)
Ingress protection	IP65
Operating Temperature Range	-30~+60°C
Topology	Non-isolated
Protective Class	Class I

Manufacturer:Shenzhen SOFARSOLAR Co., Ltd.  
Address: 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China

VDE0126-1-1, VDE-AR-N4105, IEC61727, IEC62116, UTE C15-712-1, AS4777



Copy of marking plate

**SOFAR SOLAR** Solar Grid-tied Inverter

Model No. SOFAR 3000TL-G3

Max.DC Input Voltage 550V

Operating MPPT Voltage Range 50~550V

Max. Input Current 12A

Max. PV Isc 15A

Nominal Grid Voltage L/N/PE,230Vac

Max. Output Current 14.5A

Nominal Grid Frequency 50/60Hz

Max. Output Power 3000VA

Power Factor 1(adjustable+/-0.8)

Ingress protection IP65


Operating Temperature Range -30~+60°C

Topology Non-isolated

Protective Class Class I

Manufacturer:Shenzhen SOFARSOLAR Co., Ltd.  
Address: 401, Building 4, AnTongDa Industrial Park,District 68, XingDong Community, XinAn Street,BaoAn District, Shenzhen, China

VDE0126-1-1,VDE-AR-N4105, IEC61727, IEC62116, UTE C15-712-1,AS4777



**SOFAR SOLAR** Solar Grid-tied Inverter

Model No. SOFAR 3300TL-G3

Max.DC Input Voltage 550V

Operating MPPT Voltage Range 50~550V

Max. Input Current 12A

Max. PV Isc 15A

Nominal Grid Voltage L/N/PE,230Vac

Max. Output Current 16A

Nominal Grid Frequency 50/60Hz

Max. Output Power 3300VA

Power Factor 1(adjustable+/-0.8)

Ingress protection IP65


Operating Temperature Range -30~+60°C

Topology Non-isolated

Protective Class Class I

Manufacturer:Shenzhen SOFARSOLAR Co., Ltd.  
Address: 401, Building 4, AnTongDa Industrial Park,District 68, XingDong Community, XinAn Street,BaoAn District, Shenzhen, China

VDE0126-1-1,VDE-AR-N4105, IEC61727, IEC62116, UTE C15-712-1,AS4777



DRM 0	<input checked="" type="checkbox"/>	DRM 1	<input type="checkbox"/>	DRM 2	<input type="checkbox"/>
DRM 3	<input type="checkbox"/>	DRM 4	<input type="checkbox"/>	DRM 5	<input checked="" type="checkbox"/>
DRM 6	<input checked="" type="checkbox"/>	DRM 7	<input checked="" type="checkbox"/>	DRM 8	<input checked="" type="checkbox"/>

**General product information:**

The Solar converter converts DC voltage into AC voltage.

The DC input of Solar converter can be supplied from PV array.

The input and output are protected by Varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high power switching bridge and a two relays. This assures that the opening of the output circuit will also operate in case of one error.

**Description of the electrical circuit: (Figure 1):**

Description of the electrical circuit: (Figure 1):


The internal control is redundant built. It consists of Microcontroller main DSP (U34) and Slave DSP (U03).

The man DSP (U34) control the relays by switching signals; measures the PV voltage, PV current, Bus voltage, grid voltage, frequency, AC current with injected DC and the array insulation resistance to ground. In addition it tests the current sensors and the RCMU circuit before each start up.

The Slave DSP (U03) is measures the grid voltage, grid frequency, DCI and residual current, also can switch off the relays independently, and communicate with the CPU1 (U100) each other.

The current is measured by a current sensor. The AC current signal and the injected DC current signal are sent to the main DSP (U03). The Slave DSP (U03) tests and calibrates before each start up all current sensors.

The unit provides two relays in series in all output conductors. When single fault applied to one relay, alarm an error code in display panel, another redundant relay provides basic insulation maintained between the PV array and the mains. All the relays are tested before each start up.



**Figure 1 – Block diagram**

**Differences of the models in the series:**

The models SOFAR 1100TL-G3, SOFAR 1600TL-G3, SOFAR 2200TL-G3, SOFAR 2700TL-G3, SOFAR 3000TL-G3 and SOFAR 3300TL-G3 are completely identical hardware platform and control system which to each other except the output power derated by software.

**The product was tested on:**

Hardware version: V1.1

Software version: V1.0


# Test Results



<b>1 General test and reporting requirements</b>		
<b>Clause</b>	<b>Requirement – Test</b>	<b>Verdict</b>
1.1	General	<b>P</b>
1.2	Test condition	<b>P</b>
1.3	Inverter setup	<b>P</b>
1.4	Grid source	<b>P</b>
<b>2 Test procedure</b>		
2.1	General	<b>P</b>
2.2	Undervoltage ( $V<$ ) disconnection test in response to event duration exceeding trip delay time	<b>P</b>
2.3	Undervoltage ( $V<$ ) withstand test in response to event duration of less than trip delay time	<b>P</b>

2.2 Under voltage ( $V <$ ) trip setting of disconnection test in response to event duration exceeding trip delay time							P
<b>L1 phase</b>							
<b>Output Current level: 50+/-5% of rated current</b>							
Test	Voltage (V)			Time to disconnect (s) (Trip delay 1s)			Time to reconnection (s)
<b>Limit</b>	--			<b><math>\leq 2s</math></b>			<b><math>\geq 60s</math></b>
Grid source voltage 230V down to 177,5 V (2,5 V below 180 V)	177,5			2			--
Measured value	177,8	177,9	177,9	1,240	1,226	1,238	--
Return the voltage (177.5 V) to the grid test voltage (230V)	230			--			--
Measured value	230,9			--			64,0
<b>Test procedure:</b>							
<p>The disconnection time for the protective function undervoltage (180 V) for a voltage step shall be confirmed. The procedure shall be as follows:</p> <p>(a) Set the grid source equal to the grid test voltage. The energy source shall be varied until the a.c. output of the device under test equals <math>50 \pm 5 \%</math> of its rated current output.</p> <p>NOTE: For three-phase inverters or inverter combinations, the required inverter output is based on the per phase inverter current rating.</p> <p>(b) The grid source voltage shall be stepped to 177.5 V (2.5 V below 180 V) with the step change completed within 2 ms and occurring at the zero crossing of the grid source voltage. The time interval between the start of the voltage step and the device under test disconnecting from the grid source shall be recorded.</p> <p>(c) Adjust the grid source to return the voltage to the grid test voltage. The reconnection time (the time taken for the device under test to reconnect to the grid source) shall be recorded.</p>							
<b>Note:</b>							
<p>The Voltage required to trip is the setting 177.5V (180V minus 2.5V). The time delay can be measured at a larger deviation than the minimum required to operate the protection. It has to be in the range of <u><math>\pm 2,3V</math></u> of the grid test voltage.</p>							

Diagram of under-voltage protection:



**2.3 Undervoltage (V<) withstand test in response to event duration of less than trip delay time** **P**

**Test procedure**




Figure 1 – Test circuit of voltage limits

The trip delay requirement for the protective function undervoltage 1 (V <) of 180 V for a voltage step shall be confirmed. The procedure shall be as follows:

(d) Set the grid source equal to the grid test voltage. Vary the energy source until the a.c. output of the device under test equals  $50 \pm 5\%$  of its rated current output.

NOTE: For three-phase inverters or inverter combinations, the required inverter output is based on the per phase inverter current rating.





(e) Record the stabilised active power output.










(f) Step the grid source voltage down to 50 V with the step change completed within 2 ms and occurring at the zero crossing of the grid source voltage, remain at 50 V for 220 ms. Increase the grid source voltage to the grid test voltage with the step change completed within 2 ms and occurring at the zero crossing of the grid source voltage. Record the time interval between each voltage step passing through 180 V (i.e. the duration for which voltage lies below 180 V).

NOTE: For three phase systems, the test shall be conducted at the zero-crossing for each phase individually, and additionally for all three phases stepped together at the zero-crossing for one of the phases.

(g) After 1 second, record the active power output, and confirm it is equal to that recorded at Step (e)  $\pm 4\%$ .

NOTE: There is no defined behaviour of the inverter during the simulated fault. Monitor and recording at this stage is to better understand the anticipated inverter response.

List of tests	Residual amplitude of phase-to-neutral voltage V	Tolerance	Duration [ms]	Form (*)
<b>Type for single phase inverter</b>				
test 1 one-phase symmetrical fault	50V	$\pm 0,01U_n$	220	
<b>Type for three phase inverter</b>				
test 1 a) one-phase: L1 symmetrical fault	50V	$\pm 0,01U_n$	220	
test 1 b) one-phase: L1 symmetrical fault	50V	$\pm 0,01U_n$	220	
test 1 c) one-phase: L1 symmetrical fault	50V	$\pm 0,01U_n$	220	

test 2 a) one-phase: L2 symmetrical fault	50V	$\pm 0,01U_n$	220	
test 2 b) one-phase: L2 symmetrical fault	50V	$\pm 0,01U_n$	220	
test 2 c) one-phase: L2 symmetrical fault	50V	$\pm 0,01U_n$	220	
test 3 a) one-phase: L3 symmetrical fault	50V	$\pm 0,01U_n$	220	
test 3 b) one-phase: L3 symmetrical fault	50V	$\pm 0,01U_n$	220	
test 3 c) one-phase: L3 symmetrical fault	50V	$\pm 0,01U_n$	220	
test 4 a) all-phase: L1, L2, L3 symmetrical fault	50V	$\pm 0,01U_n$	220	
test 4 b) all-phase: L1, L2, L3 symmetrical fault	50V	$\pm 0,01U_n$	220	
test 4 c) all-phase: L1, L2, L3 symmetrical fault	50V	$\pm 0,01U_n$	220	

Criteria for acceptance

- a. The device under test shall remain connected for the duration of test step (f).
- b. At Step (g) the device under test shall have recovered its active power output to that recorded at Step (e)  $\pm 4$  % within 1 second.


**Graph of LVRT testing**

Output Current level: 50+/-5% of rated current				
List of tests	Residual amplitude of phase-to-phase voltage (V)	Duration limit of Voltage dips [ms]	Measured duration [ms]	Measured Power recover times (ms)
<b>L1 phase</b>				
Test 1 a) – one-phase symmetrical fault	50	220	229	33
Test 1 b) – one-phase symmetrical fault	50	220	230	39
Test 1 c) one-phase symmetrical fault	50	220	229	40
Test voltage	Voltage 230V +/- 1%			
Before test - Active power output (kW)	1,656	1,660	1,651	
After test - Active power output(kW) after 1s	1,701	1,693	1,711	
Limit(%)	+/- 4 %	+/- 4 %	+/- 4 %	
<b>L2 phase</b>				
Test 2 a) – one-phase symmetrical fault	50	220	N/A	N/A
Test 2 b) – one-phase symmetrical fault	50	220	N/A	N/A
Test 2 c) one-phase symmetrical fault	50	220	N/A	N/A
Test voltage	Voltage 230V +/- 1%			
Before test - Active power output (W)	N/A	N/A		N/A
After test - Active power output(W) after 1s	N/A	N/A		N/A
Limit(%)	+/- 4 %	+/- 4 %	+/- 4 %	
<b>L3 phase</b>				
Test 3 a) – one-phase symmetrical fault	50	220	N/A	N/A
Test 3 b) – one-phase symmetrical fault	50	220	N/A	N/A
Test 3 c) one-phase symmetrical fault	50	220	N/A	N/A
Test voltage	Voltage 230V +/- 1%			
Before test - Active power output (W)	N/A	N/A		N/A


**Graph of LVRT testing**

After test - Active power output(W) after 1s	N/A	N/A	N/A
Limit(%)	+/- 4 %	+/- 4 %	+/- 4 %
<b>All (L1,L2,L3) phase</b>			
Test 4 a) – All-phase symmetrical fault (P = 0,5)	50	220	N/A
Test 4 a) – All-phase symmetrical fault	50	220	N/A
Test 4 a) – All-phase symmetrical fault	50	220	N/A
Test voltage	Voltage 230V +/- 1%		
Before test - Active power output (W)	N/A	N/A	N/A
After test - Active power output(W) after 1s	N/A	N/A	N/A
Lmit(%)	+/- 4 %	+/- 4 %	+/- 4 %
<b>Test conditions:</b>			
Voltage simulator fall and rise time: < 2ms			
The test conditions are performed as 50% ± 5% of In conditions. The inverter feeds maximal active and reactive power during the complete test.			
<b>Note:</b>			

### Test 1 a) – one-phase symmetrical fault




### Test 1 b) – one-phase symmetrical fault






Test 1 c) – one-phase symmetrical fault




# Annex No. 1

## Pictures of the unit

**Enclosure front view  
(SOFAR 2700TL-G3, SOFAR 3000TL-G3, SOFAR 3300TL-G3)**




**Enclosure rear view  
(SOFAR 2700TL-G3, SOFAR 3000TL-G3, SOFAR 3300TL-G3)**



**Enclosure front view**  
**(SOFAR 1100TL-G3, SOFAR 1600TL-G3, SOFAR 2200TL-G3)**




**Enclosure rear view**  
**(SOFAR 2700TL-G3, SOFAR 3000TL-G3, SOFAR 3300TL-G3)**




**Enclosure side view  
(SOFAR 2700TL-G3, SOFAR 3000TL-G3, SOFAR 3300TL-G3)**




**Enclosure side view  
(SOFAR 1100TL-G3, SOFAR 1600TL-G3, SOFAR 2200TL-G3)**




**Internal view – 1**  
**(SOFAR 2700TL-G3, SOFAR 3000TL-G3, SOFAR 3300TL-G3)**




**Internal view – 1**  
**(SOFAR 1100TL-G3, SOFAR 1600TL-G3, SOFAR 2200TL-G3)**




**Main board view – 1**  
**(SOFAR 2700TL-G3, SOFAR 3000TL-G3, SOFAR 3300TL-G3)**




**Main board view – 2**  
**(SOFAR 2700TL-G3, SOFAR 3000TL-G3, SOFAR 3300TL-G3)**



**Main board view – 1**  
**(SOFAR 1100TL-G3, SOFAR 1600TL-G3, SOFAR 2200TL-G3)**




**Main board view – 2**  
**(SOFAR 1100TL-G3, SOFAR 1600TL-G3, SOFAR 2200TL-G3)**







Control board view – 1




Control board view – 2



Communication board (RS 232)view – 1



Communication board (RS 232)view – 2



### Connection interface view



### Grounding view



# Annex No. 2

## Test Equipment list

Date(s) of performance test: 2020-09-08 to 2020-09-15

Equipment	Internal No.	Manufacturer	Type	Serial No.	Next Calibration date
Power Analyser	A4080002DG	YOKOGAWA	WT3000	91M210852	Jun. 16, 2021
AC Source	A7040019DG	Chroma	61512	61512000439	Monitored by Power Analyser
	A7040020DG	Chroma	61512	61512000438	
DC Simulation Power Supply	A7040015DG	Chroma	62150H-1000S	62150EF00488	
	A7040016DG	Chroma	62150H-1000S	62150EF00490	
	A7040017DG	Chroma	620028	620028EF00120	
RLC Load	A7150027DG	Qunling	ACLT-3803H	93VOO2869	
Power Analyser	//	ZLG	PA5000H	C820290908200 2110001	Mar. 02, 2021
Oscilloscope	//	KEYSIGHT	DSX3014T	MY57231269	Jan. 13, 2021
Oscilloscope	//	Agilent	DS05014A	MY50070288	Jan. 13, 2021
Oscilloscope current probe	//	CYBERTEK	CP1000A	C181000922	Jan. 13, 2021
	//	CYBERTEK	CP1000A	C181000925	Jan. 13, 2021
	//	CYBERTEK	CP1000A	C181000929	Jan. 13, 2021
	//	CYBERTEK	CP1000A	C181000931	Jan. 13, 2021
Oscilloscope probe	//	SANHUA	SI-9110	152627	Jan. 13, 2021
	//	SIALENT	DS5034X	SDS5XEAC3R0 011	Jan. 13, 2021
	//	AGILENT	N2863B	YF0139	Jan. 13, 2021

# End of Test Report