





# TEST REPORT

## DIN VDE V 0124-100

**Test requirements for generation units to be connected and operated parallel with the low voltage distribution networks**

<b>Report reference number</b> .....	<b>PVDE180712N013</b>
<b>Date of issue</b> .....	2019-04-24
<b>Total number of pages</b> .....	109
<b>Testing laboratory name</b> .....	<b>Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch</b>
<b>Address</b> .....	No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China
	 
<b>Applicant's name</b> .....	<b>Shenzhen SOFAR SOLAR Co., Ltd.</b>
<b>Address</b> .....	401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China.
<b>Test specification</b>	
<b>Standard</b> .....	DIN VDE V 0124-100:2012-07
<b>Zertifikate</b> .....	<b>Certificate of compliance</b>
<b>Test report form number</b> .....	DIN VDE V 0124-100
<b>Master TRF</b> .....	Bureau Veritas Consumer Products Services Germany GmbH
<b>Test item description</b> .....	<b>Solar Grid-tied Inverter</b>
<b>Trademark</b> .....	
<b>Model / Type</b> .....	SOFAR 20000TL-G2, SOFAR 25000TL-G2, SOFAR 30000TL-G2, SOFAR 33000TL-G2
<small>This report is governed by, and incorporates by reference, CPS Conditions of Service as posted at the date of issuance of this report at <a href="http://www.bureauveritas.com/home/about-us/our-business/cps/about-us/terms-conditions">http://www.bureauveritas.com/home/about-us/our-business/cps/about-us/terms-conditions</a> and is intended for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. The results set forth in this report are not indicative or representative of the quality or characteristics of the lot from which a test sample was taken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. Measurement uncertainty is only provided upon request for accredited tests. You have 60 days from date of issuance of this report to notify us of any material error or omission caused by our negligence or if you require measurement uncertainty; provided, however, that such notice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise such issue within the prescribed time shall constitute your unqualified acceptance of the completeness of this report, the tests conducted and the correctness of the report contents.</small>	

<b>Ratings</b> .....	SOFAR 20000TL-G2	SOFAR 25000TL-G2	SOFAR 30000TL-G2	SOFAR 33000TL-G2
Input DC voltage range [V] .....	230-1100			
Full load MPPT DC voltage range [V]:	480-850	460-850	520-850	580-850
Input DC current [A] .....	24/24	28/28	30/30	30/30
Output AC voltage [V] .....	400V, 3/N/PE, 50Hz			
Output AC current [A].....	Max. 32	Max. 40	Max. 48	Max. 53
Output power [VA].....	22000	27500	33000	36300

<b>Testing Location</b> .....	<b>Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch</b>		
Address .....	No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China		
Tested by (name and signature).....	Dora Zhang		
Approved by (name and signature).....	James Huang		
<b>Manufacturer's name</b> .....	<b>Shenzhen SOFAR SOLAR Co., Ltd.</b>		
Manufacturer address .....	401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China.		
<b>Factory's name</b> .....	<b>Dongguan SOFAR SOLAR Co.,Ltd.</b>		
Factory address .....	1F - 6F, Building E, No. 1 JinQi Road, Bihu Industrial Park, Wulian Village, Fenggang Town, Dongguan City		

<b>Document History</b>			
<b>Date</b>	<b>Internal reference</b>	<b>Modification / Change / Status</b>	<b>Revision</b>
2019-04-24	Dora Zhang	Initial report was written	0
Supplementary information:			

<b>Test items particulars</b>	
Equipment mobility.....	: Permanent connection
Operating condition.....	: Continuous
Class of equipment .....	: Class I
Protection against ingress of water..	: IP65 according to EN 60529
Mass of equipment [kg].....	: Approx. 37
<b>Test case verdicts</b>	
Test case does not apply to the test object.....	: N/A
Test item does meet the requirement.....	: P(ass)
Test item does not meet the requirement.....	: F(ail)
<b>Testing</b>	
Date of receipt of test item .....	: 2018-07-12
Date(s) of performance of test.....	: 2018-07-12 to 2019-04-20
<b>General remarks:</b>	
<p>The test result presented in this report relate only to the object(s) tested. The report shall state compliance of the tested objects with the requirements of DIN VDE V 0124-100. This report shall not be reproduced, except in full, without the written approval of the applicant.</p> <p>"(see Annex #)" refers to additional information appended to the report.</p> <p>"(see appended table)" refers to a table appended to the report.</p> <p>Throughout this report a comma is used as the decimal separator.</p>	
<b>This Test Report consists of the following documents:</b>	
<ol style="list-style-type: none"> <li>1. Test Report <ol style="list-style-type: none"> <li>5.1. Verification of permissible system perturbations</li> <li>5.2. Verification of the symmetry characteristics of three-phase inverter modules</li> <li>5.3. Verification of the characteristics of the power generation unit on the network</li> <li>5.4. Testing of NS protection</li> <li>5.5. Testing of connecting conditions and synchronisation</li> </ol> </li> <li>2. Pictures of the unit – Annex No. 1</li> <li>3. Test equipment list – Annex No. 2</li> </ol>	


Copy of marking plate

**SOFAR SOLAR** Solar Grid-tied Inverter

Model No:	SOFAR 20000TL-G2
Max.DC Input Voltage	1100V
Operating MPPT Voltage Range	230~960V
Max. Input Current	24A/24A
Max. PV Isc	30A/30A
Nominal Grid Voltage	3/N/PE,400Vac
Max.Output Current	3x32A
Nominal Grid Frequency	50/60Hz
Nominal Output Power	20000W
Max.Output Power	22000VA
Power Factor	>0.99(adjustable+/-0.8)
Ingress Protection	IP65
Operating Temperature Range	-25°C~+60°C
Protective Calss	Class I

Made in China

Manufacturer : Shenzhen SOFAR SOLAR Co.,Ltd.  
Address : 401, Building 4, AnTongDa Industrial Park,  
District 68, XingDong Community,XinAn Street,  
BaoAn District, Shenzhen, China  
VDE0126-1-1,VDE-AR-N4105,G59/3,IEC61727,  
IEC62116,C10/11,RD1699,UTE C15-712-1,AS4777




**SOFAR SOLAR** Solar Grid-tied Inverter

Model No:	SOFAR 25000TL-G2
Max.DC Input Voltage	1100V
Operating MPPT Voltage Range	230~960V
Max. Input Current	28A/28A
Max. PV Isc	35A/35A
Nominal Grid Voltage	3/N/PE,400Vac
Max.Output Current	3x40A
Nominal Grid Frequency	50/60Hz
Nominal Output Power	25000W
Max.Output Power	27500VA
Power Factor	>0.99(adjustable+/-0.8)
Ingress Protection	IP65
Operating Temperature Range	-25°C~+60°C
Protective Calss	Class I

Made in China

Manufacturer : Shenzhen SOFAR SOLAR Co.,Ltd.  
Address : 401, Building 4, AnTongDa Industrial Park,  
District 68, XingDong Community,XinAn Street,  
BaoAn District, Shenzhen, China  
VDE0126-1-1,VDE-AR-N4105,G59/3,IEC61727,  
IEC62116,C10/11,RD1699,UTE C15-712-1,AS4777



**SOFAR** Solar Grid-tied Inverter  
SOLAR

Model No:	SOFAR 30000TL-G2
Max.DC Input Voltage	1100V
Operating MPPT Voltage Range	230~960V
Max. Input Current	30A/30A
Max. PV Isc	37.5A/37.5A
Nominal Grid Voltage	3/N/PE,400Vac
Max.Output Current	3x48A
Nominal Grid Frequency	50/60Hz
Nominal Output Power	30000W
Max. Output Power	33000VA
Power Factor	>0.99(adjustable+/-0.8)
Ingress Protection	IP65
Operating Temperature Range	-25°C~+60°C
Protective Calss	Class I

Made in China

Manufacturer : Shenzhen SOFAR SOLAR Co.,Ltd.  
Address : 401, Building 4, AnTongDa Industrial Park,  
District 68, XingDong Community,XinAn Street,  
BaoAn District, Shenzhen, China  
VDE0126-1-1,VDE-AR-N4105,G59/3,IEC61727,  
IEC62116,C10/11,RD1699,UTE C15-712-1,AS4777



**SOFAR** Solar Grid-tied Inverter  
SOLAR

Model No:	SOFAR 33000TL-G2
Max.DC Input Voltage	1100V
Operating MPPT Voltage Range	230~960V
Max. Input Current	30A/30A
Max. PV Isc	37.5A/37.5A
Nominal Grid Voltage	3/N/PE,400Vac
Max.Output Current	3x53A
Nominal Grid Frequency	50/60Hz
Nominal Output Power	33000W
Max. Output Power	36300VA
Power Factor	>0.99(adjustable+/-0.8)
Ingress Protection	IP65
Operating Temperature Range	-25°C~+60°C
Protective Calss	Class I

Made in China

Manufacturer : Shenzhen SOFAR SOLAR Co.,Ltd.  
Address : 401, Building 4, AnTongDa Industrial Park,  
District 68, XingDong Community,XinAn Street,  
BaoAn District, Shenzhen, China  
VDE0126-1-1,VDE-AR-N4105,G59/3,IEC61727,  
IEC62116,C10/11,RD1699,UTE C15-712-1,AS4777



**General product information:**

The Photovoltaic grid-interactive inverter converts DC voltage, generated by photovoltaic modules, into AC voltage.

The units are three-phases inverter.

**Description of the power circuit (Figure 1):**


The input and output are protected by Varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformer). The output is switched off redundant by the high power switching bridge and a two relays. This assures that the opening of the output circuit will also operate in case of one error.

The internal control is redundant built. It consists of Main DSP(UC20) and slave DSP(UC73).

The Main DSP(UC20) can control the relays, measures voltage, and frequency, AC current with injected DC, insulation resistance and residual current, In addition it tests the array insulation resistance and the RCMU circuit before each start up.

The slave DSP(UC73) is using for detect residual current, also can open the relays independently and communicate with Main DSP(UC20).

The unit provides two relays in series on Line conductors. When single-fault applied to one relay, alarm an error code in display panel, another redundant relay provides basic insulation maintained between the PV array and the mains. All the relays are tested before start up. Both controllers(Main DSP(UC20), Slave DSP(UC73) can open the relays.



**Figure 1 – Block diagram**

The unit provides two relays in series in all output conductors. When single fault applied to one relay, alarm an error code in display panel, another redundant relay provides basic insulation maintained between the PV array and the mains. All the relays are tested before each start up.

### Differences of the models

The models SOFAR 20000TL-G2, SOFAR 25000TL-G2, SOFAR 30000TL-G2 and SOFAR 33000TL-G2 are almost identical in hardware except the shown in the following table and the output power derated by software.

The difference in hardware			
Item	SOFAR 20000TL-G2	SOFAR 25000TL-G2	SOFAR 30000TL-G2 / SOFAR 33000TL-G2
Number of PV terminal	2+2	3+3	
Number of BUS capacitance	8 capacitors: 550V/110 $\mu$ F 2 capacitors: 1100V/40 $\mu$ F		10 capacitors: 550V/110 $\mu$ F 24 capacitors: 1100V/40 $\mu$ F
INV inductance	785 $\mu$ H	735 $\mu$ H	
BUS board	Not the board	Have the board	
External fan	Not the board	2	3
Relay of output board	6pcs T9VV1K15-12S		3pcs AZSR250-2AE-12D

### The product was tested on

Hardware version: V1.00

Software version: V1.40





Figure 4-11 RS485 Connecting Communications Cables(1)





Figure 4-12 RS485 Connecting Communications Cables(2)




Step 4 Crystal plug with RJ45 crimping tool.

Step 5 Insert the plug into the RS485 port on the sof ar 20~33KTL-G2.

Step 6 Insert sealing plug into housing, and tighten the screw nut.

Figure 4-13 RS485 Connecting Communications Cables(3)




### WiFi/GPRS communication

Monitor the inverter via WiFi/GPRS module.

Procedure:


Step 1 Remove waterproof cover using screwdriver.

Figure 4-13 WIFI Connecting Communications Cables(1)




Step 2 Connect WiFi/GPRS module.

Figure 4-14 WIFI Connecting Communications Cables(2)



Step 3 Fix the WiFi/GPRS module using two screws.

Figure 4-15 WIFI Connecting Communications Cables(3)



Note: Follow the WiFi/GPRS manual to start monitoring your inverter.

### Communications Port Description

This topic describes the functions of the RS485 and WIFI ports.

#### RS485

By RS485 interface, transfer the inverter power output information, alarm information, operation state to the PC terminal or local data acquisition device, then uploaded to the server (such as S-WE01S).

1. USB-RS485




2. S-WE01S



Set the match resistor by the SWT2, the corresponding list as follows (0 OFF, 1 ON).


SWT2_1	SWT2_2	State
0	Reserve	No connect
1	Reserve	Connect

If only one Sofar 20~33KTL-G2 is used, use a communication cable with waterproof RJ45 connectors, and choose either of the two RS485 ports.



If multiple Sofar 20~33KTL-G2 are used, connect all Sofar 20~33KTL-G2 in daisy chain mode over the RS485 communication cable. Set different Modbus address(1~31) for each inverter in LCD display and set SWT2(match resistance) at the first and last inverter.

Figure 4-18 Multi Sofar 20~33KTL-G2 connecting Communications




Register remote monitoring of Sofar 20~33KTL-G2 at its relevant website or APP according to monitoring device SN.


#### Wifi

By the WIFI interface, transfer the inverter power output information, alarm information, operation state to the PC terminal or local data acquisition device , then uploaded to the server (such as S-WE01S). Register remote monitoring of Sofar 20~33KTL-G2 at its relevant website or APP according to monitoring device SN.

Figure 4-19 Connect multiple Wifi to wireless router



**Description of the connection to the ripple control receiver:**



**Figure 2 – Connection of the ripple control receiver in an installation**

### General remarks:

The test results presented in this report relate only to the object(s) tested.

This document may be published or passed on in full only. Extraction of parts needs the written permission of Bureau Veritas Consumer Products Services GmbH.

"(see Annex #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.

The following suffixes are used for variables in tables and figures:

- "P<sub>N</sub>" for the nominal active power:  
 $P_n = U_n \times I_n \times \cos \varphi_n$  (single-Phase);  $P_n = \sqrt{3} U_n \times I_n \times \cos \varphi_n$  (three-Phase)
- "\_E0,2" for gliding average values over 200 milliseconds
- "\_E60" for gliding average values over 60 seconds.
- "\_E600" for gliding average values over 10 minutes.
- "(c)" for over-excited
- "(i)" for under-excited


### Acronyms:

PGU: power generating unit


PGS: power generating system

The regarded system of the voltage and current vectors is the load view (Figure 3):

- If the inverter feeds to the grid the active power is measured with negative sign. For the sake of reading the document the measured active infeed power has a positive sign



- If the inverter consumes inductive reactive power the reactive power is marked "inductive" or has a positive sign.
- If the inverter consumes capacitive reactive power the reactive power is marked "capacitive" or has a negative sign.



**Figure 3**

**5 Prüfungen**  
**DIN VDE V 0124-100:2012-07**

<b>Clause</b>	<b>Test</b>	<b>Result</b>
5.1	Verification of permissible system perturbations	<b>P</b>
5.2	Verification of the symmetry characteristics of three-phase inverter modules	<b>P</b>
5.3	Verification of the characteristics of the power generation unit on the network	<b>P</b>
5.4	Testing of NS protection	<b>P</b>
5.5	Testing of connecting conditions and synchronisation	<b>P</b>

**5.1 Verification of permissible system perturbations  
DIN VDE V 0124-100:2012-07**

Clause	Test	Result
5.1.1	General	P
5.1.2	Rapid voltage changes	P
	5.1.2.1 Tests	P
	5.1.2.2 Documentation of tests	P
5.1.3	Flicker	P
	5.1.3.1 Tests	P
	5.1.3.2 Documentation of tests	P
5.1.4	Harmonics and interharmonics	P
	5.1.4.1 Tests	P
	5.1.4.2 Additional tests	P
	5.1.4.3 Documentation of tests	P

**5.1.1 General**

These tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 5.4 are met.

**P**

The electrical equipment of the customer system has been planned and built, and will be operated, such that system perturbations affecting the network of the network operator and the installations of other customers are limited to a permissible level on a permanent basis.

System perturbations are defined as:

- Rapid voltage changes
- Flicker
- Harmonics, interharmonics and higher frequencies (up to 9 kHz)


**Note:**



<b>5.1.2 Rapid voltage changes</b> These tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 5.4.2 are met.		<b>P</b>	
<p>The purpose of the test is to determine <math>k_i</math> and <math>k_{imax}</math>.</p> <p>The following three cases must be tested to VDE-AR-N 4105, Annex F.3 (where applicable).</p> <ul style="list-style-type: none"> <li>- Switch-on for any capacity</li> <li>- Unfavourable case when switching the generator step</li> <li>- Switch-on for nominal capacity</li> </ul>			
<p><b>Test conditions:</b>          Frequency: 50 Hz <math>\pm</math> 0,5%          THD of the voltage supply: <math>\leq</math> 3 %          Voltage rise of the PGU at 100 <math>P_{Emax}</math> %: <math>\leq</math> 3 %</p>			
<b>L1 phase</b>			
<b>Switch-on for any capacity (10% <math>P_{Emax}</math>)</b>			
Single period effective values of the current [A]	3,613	3,628	3,392
Single period effective values of the voltage [V]	229,97	229,97	229,97
$k_i$ value	0,076	0,076	0,071
$k_{imax}$ value	0,076		
<b>Unfavourable case when switching the generator step</b>			
Single period effective values of the current [A]	N/A	N/A	N/A
Single period effective values of the voltage [V]	N/A	N/A	N/A
$k_i$ value	N/A	N/A	N/A
$k_{imax}$ value	N/A		
<b>Switch-on for nominal capacity</b>			
Single period effective values of the current [A]	9,646	7,102	6,772
Single period effective values of the voltage [V]	229,90	229,92	230,02
$k_i$ value	0,202	0,148	0,142
$k_{imax}$ value	0,202		
<b>L2 phase</b>			
<b>Switch-on for any capacity (10% <math>P_{Emax}</math>)</b>			
Single period effective values of the current [A]	3,820	3,822	3,561
Single period effective values of the voltage [V]	229,78	229,72	229,79
$k_i$ value	0,080	0,080	0,074
$k_{imax}$ value	0,080		
<b>Unfavourable case when switching the generator step</b>			

Single period effective values of the current [A]	N/A	N/A	N/A
Single period effective values of the voltage [V]	N/A	N/A	N/A
$k_f$ value	N/A	N/A	N/A
$k_{imax}$ value	N/A		
<b>Switch-on for nominal capacity</b>			
Single period effective values of the current [A]	10,080	7,436	7,062
Single period effective values of the voltage [V]	229,71	229,72	229,67
$k_f$ value	0,211	0,155	0,148
$k_{imax}$ value	0,211		
<b>L3 phase</b>			
<b>Switch-on for any capacity (10% <math>P_{Emax}</math>)</b>			
Single period effective values of the current [A]	3,778	3,789	3,535
Single period effective values of the voltage [V]	229,97	229,97	229,98
$k_f$ value	0,079	0,079	0,074
$k_{imax}$ value	0,079		
<b>Unfavourable case when switching the generator step</b>			
Single period effective values of the current [A]	N/A	N/A	N/A
Single period effective values of the voltage [V]	N/A	N/A	N/A
$k_f$ value	N/A	N/A	N/A
$k_{imax}$ value	N/A		
<b>Switch-on for nominal capacity</b>			
Single period effective values of the current [A]	9,940	7,336	6,973
Single period effective values of the voltage [V]	229,94	229,95	229,95
$k_f$ value	0,208	0,153	0,146
$k_{imax}$ value	0,208		
<b>Highest <math>k_{imax}</math> value for all switching operations</b>			
0,211			
<b>Note:</b>			
The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.			

### Switch-on for any capacity (10% $P_{Emax}$ )



### Switch-on for nominal capacity



### 5.1.3 Flicker

These tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 5.4.3 are met.

The purpose of the test is to determine long-term flicker strength  $P_{lt}$ .

For power generation systems with rated currents  $\leq 75$  A, system perturbations are deemed sufficiently limited when the generation units adhere to the thresholds in norms DIN EN 61000-3-3 (VDE 0838-3) and DIN EN 61000-3-11 (VDE 0838-11).

#### Test conditions:

Voltage: 86%  $U_n$  to 109%  $U_n$

Frequency: 50 Hz  $\pm$  0,5%

THD of the voltage supply:  $\leq 3$  %

Voltage rise of the PGU at 100  $P_{Emax}$  %:  $\leq 3$  %

#### Flicker to DIN EN 61000-3-3 (VDE 0838-3) or DIN EN 61000-3-11 (VDE 0838-11) for generator units $\leq 75$ A

Flicker to:	Result:		
	$P_{lt}$	$P_{st}$	dc%
DIN EN 61000-3-11 (SOFAR 33000TL-G2)	0,33	0,34	0,30
DIN EN 61000-3-11 (SOFAR 20000TL-G2)	0,29	0,29	0,17

#### Assessment criterion:

Long-term flicker strength  $P_{lt}$  to DIN EN 61000-3-3 (VDE 0838-3) or DIN EN 61000-3-11 must be  $\leq 0,5$ .

Determination of the flicker coefficient:

$$c_{\psi k} = P_{st} \times (S_k / P_n)$$

where  $S_k$  is the short-circuit power of the network standby element (during the determination of the appropriate  $P_{st}$  values)

The following applies according to DIN EN 61000-3-3 ( $\leq 16$  A) for the network standby element:  $S_k = 339199$   
The value for the network standby element must be determined separately with measurements for rated currents  $> 75$  A.

Flicker to DIN EN 61400-21 (VDE 0127-21) (or FGW TR3)	
SOFAR 33000TL-G2	
Grid impedance angle $\psi_k$	32°
Flicker coefficient $c(\psi_k)$	5,78
Short-term flicker $P_{st}$	0,34
SOFAR 20000TL-G2	
Grid impedance angle $\psi_k$	32°
Flicker coefficient $c(\psi_k)$	8,13
Short-term flicker $P_{st}$	0,29
<b>Assessment criterion:</b>	
Long-term flicker strength: $P_{lt} \leq 0,5$	
<b>Note:</b>	
The tests had been performed on the SOFAR 33000TL-G2 and SOFAR 20000TL-G2 are valid for the SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.	

#### 5.1.4 Harmonics and interharmonics

These tests are designed to provide evidence that the requirements of VDE-AR-N 4015, 5.4.4 are met.

**P**

Adherence to the thresholds for harmonic currents must be verified as followed:

- For nominal currents  $\leq 16$  A per conductor to DIN EN 61000-3-2 (VDE 0838-2)
- For nominal currents  $> 16$  A and  $\leq 75$  A per conductor to DIN EN 61000-3-12 (VDE 0838-12)
- For PGUs intended for PGSs with nominal currents  $> 75$  A, the measurements must be conducted as in 5.1.4.2.

#### Test conditions:

Voltage:  $86\% U_n$  to  $109\% U_n$

Frequency:  $50 \text{ Hz} \pm 0,5\%$

THD of the voltage supply:  $\leq 3 \%$

Voltage rise of the PGU at  $100 P_{Emax} \%$ :  $\leq 3 \%$

5.1.4.1 Tests												P
<b>Note:</b>												
The tests should be based on the limits of the EN61000-3-2 for less than 16A.												
Covered by EMC Report 13.7.6.8												
<b>Maximum permissible harmonic current as per EN 61000-3-12</b>												
Harmonic	2 <sup>nd</sup>	3 <sup>rd</sup>	4 <sup>th</sup>	5 <sup>th</sup>	6 <sup>th</sup>	7 <sup>th</sup>	8 <sup>th</sup>	9 <sup>th</sup>	10 <sup>th</sup>	11 <sup>th</sup>	12 <sup>th</sup>	13 <sup>th</sup>
Limit [%] 3phasig	8,00	N/A	4,00	10,70	2,67	7,20	2,00	N/A	1,60	3,10	1,33	2,00
Test value [%]	See below											
	THD						PWHD					
Limit [%] 3-phase	13						22					
Test value [%]	See below											
	Order	Measure[%]	Limit[%]	Margin[%]	Order	Measure[%]	Limit[%]	Margin[%]	Order	Measure[%]	Limit[%]	Margin[%]
	2	0.1630	8.0000	98.0	2	0.1599	8.0000	98.0	2	0.1599	8.0000	98.0
	3	0.2320	21.9800	98.9	3	0.1053	21.9800	99.5	3	0.1053	21.9800	99.5
	4	0.1577	4.0000	96.1	4	0.0990	4.0000	97.5	4	0.0990	4.0000	97.5
	5	0.2393	11.3200	97.9	5	0.1275	11.3200	98.9	5	0.1275	11.3200	98.9
	6	0.1395	2.6667	94.8	6	0.1078	2.6667	96.0	6	0.1078	2.6667	96.0
	7	0.2206	7.3250	97.0	7	0.2286	7.3250	96.9	7	0.2286	7.3250	96.9
	8	0.1227	2.0000	93.9	8	0.0958	2.0000	95.2	8	0.0958	2.0000	95.2
	9	0.1026	3.8250	97.3	9	0.1055	3.8250	97.2	9	0.1055	3.8250	97.2
	10	0.0917	1.6000	94.3	10	0.0928	1.6000	94.2	10	0.0928	1.6000	94.2
	11	0.2270	3.1600	92.8	11	0.2560	3.1600	91.9	11	0.2560	3.1600	91.9
	12	0.0915	1.3333	93.1	12	0.0892	1.3333	93.3	12	0.0892	1.3333	93.3
	13	0.1915	2.0600	90.7	13	0.1899	2.0600	90.8	13	0.1899	2.0600	90.8
	THD	0.7808	23.4750	96.7	THD	0.7180	23.4750	96.9	THD	0.7180	23.4750	96.9
	PWHD	2.5497	23.4750	89.1	PWHD	2.5510	23.4750	89.1	PWHD	2.5510	23.4750	89.1
	SOFAR 20000TL-G2: L1 phase						SOFAR 20000TL-G2: L2 phase					

Order	Measure[%]	Limit[%]	Margin[%]	Order	Measure[%]	Limit[%]	Margin[%]
2	0.2493	8.0000	96.9	2	0.0544	8.0000	99.3
3	0.1531	21.9800	99.3	3	0.1374	21.9800	99.4
4	0.2172	4.0000	94.6	4	0.0587	4.0000	98.5
5	0.1309	11.3200	98.8	5	0.2702	11.3200	97.6
6	0.1072	2.6667	96.0	6	0.0377	2.6667	98.6
7	0.1019	7.3250	98.6	7	0.2179	7.3250	97.0
8	0.1077	2.0000	94.6	8	0.0455	2.0000	97.7
9	0.1794	3.8250	95.3	9	0.2077	3.8250	94.6
10	0.1135	1.6000	92.9	10	0.0409	1.6000	97.4
11	0.2053	3.1600	93.5	11	0.0964	3.1600	97.0
12	0.0968	1.3333	92.7	12	0.0318	1.3333	97.6
13	0.1942	2.0600	90.6	13	0.1734	2.0600	91.6
THD	0.7614	23.4750	96.8	THD	0.5264	23.4750	97.8
PWHD	2.5960	23.4750	88.9	PWHD	0.9824	23.4750	95.8

SOFAR 2000TL-G2: L3 phase

SOFAR 2500TL-G2: L1 phase

Order	Measure[%]	Limit[%]	Margin[%]	Order	Measure[%]	Limit[%]	Margin[%]
2	0.0575	8.0000	99.3	2	0.0364	8.0000	99.5
3	0.1467	21.9800	99.3	3	0.2544	21.9800	98.8
4	0.0470	4.0000	98.8	4	0.0587	4.0000	98.5
5	0.1691	11.3200	98.5	5	0.2819	11.3200	97.5
6	0.0353	2.6667	98.7	6	0.0420	2.6667	98.4
7	0.3284	7.3250	95.5	7	0.2690	7.3250	96.3
8	0.0506	2.0000	97.5	8	0.0500	2.0000	97.5
9	0.1283	3.8250	96.6	9	0.1135	3.8250	97.0
10	0.0452	1.6000	97.2	10	0.0523	1.6000	96.7
11	0.2357	3.1600	92.5	11	0.2909	3.1600	90.8
12	0.0235	1.3333	98.2	12	0.0212	1.3333	98.4
13	0.0667	2.0600	96.8	13	0.1748	2.0600	91.5
THD	0.5426	23.4750	97.7	THD	0.6778	23.4750	97.1
PWHD	1.0347	23.4750	95.6	PWHD	1.5002	23.4750	93.6

SOFAR 2500TL-G2: L2 phase

SOFAR 2500TL-G2: L3 phase



Order	Measure[%]	Limit[%]	Margin[%]	Order	Measure[%]	Limit[%]	Margin[%]
2	0.0641	8.0000	99.2	2	0.0624	8.0000	99.2
3	0.1295	21.9800	99.4	3	0.1529	21.9800	99.3
4	0.0331	4.0000	99.2	4	0.0384	4.0000	99.0
5	0.2264	11.3200	98.0	5	0.1758	11.3200	98.4
6	0.0384	2.6667	98.6	6	0.0354	2.6667	98.7
7	0.2437	7.3250	96.7	7	0.3455	7.3250	95.3
8	0.0540	2.0000	97.3	8	0.0531	2.0000	97.4
9	0.2007	3.8250	94.8	9	0.1550	3.8250	96.0
10	0.0443	1.6000	97.2	10	0.0492	1.6000	96.9
11	0.1019	3.1600	96.8	11	0.2369	3.1600	92.5
12	0.0249	1.3333	98.1	12	0.0208	1.3333	98.4
13	0.1583	2.0600	92.3	13	0.0678	2.0600	96.7
THD	0.4929	23.4750	97.9	THD	0.5527	23.4750	97.6
PWHD	0.7877	23.4750	96.6	PWHD	0.8843	23.4750	96.2

SOFAR 30000TL-G2: L1 phase

SOFAR 30000TL-G2: L2 phase

Order	Measure[%]	Limit[%]	Margin[%]
2	0.0407	8.0000	99.5
3	0.2057	21.9800	99.1
4	0.0435	4.0000	98.9
5	0.2279	11.3200	98.0
6	0.0414	2.6667	98.5
7	0.2385	7.3250	96.7
8	0.0597	2.0000	97.0
9	0.0880	3.8250	97.7
10	0.0554	1.6000	96.5
11	0.2736	3.1600	91.3
12	0.0188	1.3333	98.6
13	0.1557	2.0600	92.4
THD	0.5765	23.4750	97.5
PWHD	1.1667	23.4750	95.0

Order	Measure[%]	Limit[%]	Margin[%]
2	0.2570	8.0000	96.8
3	0.0518	21.9800	99.8
4	0.1849	4.0000	95.4
5	0.1308	11.3200	98.8
6	0.0863	2.6667	96.8
7	0.3153	7.3250	95.7
8	0.1084	2.0000	94.6
9	0.1846	3.8250	95.2
10	0.0742	1.6000	95.4
11	0.1031	3.1600	96.7
12	0.0486	1.3333	96.4
13	0.1369	2.0600	93.4
THD	0.5800	23.4750	97.5
PWHD	0.7631	23.4750	96.7

SOFAR 30000TL-G2: L3 phase

SOFAR 33000TL-G2: L1 phase

Order	Measure[%]	Limit[%]	Margin[%]	Order	Measure[%]	Limit[%]	Margin[%]
2	0.0864	8.0000	98.9	2	0.1077	8.0000	98.7
3	0.0877	21.9800	99.6	3	0.1146	21.9800	99.5
4	0.1054	4.0000	97.4	4	0.2133	4.0000	94.7
5	0.1255	11.3200	98.9	5	0.0882	11.3200	99.2
6	0.0705	2.6667	97.4	6	0.1126	2.6667	95.8
7	0.3614	7.3250	95.1	7	0.1645	7.3250	97.8
8	0.0729	2.0000	96.4	8	0.1328	2.0000	93.4
9	0.1751	3.8250	95.4	9	0.0669	3.8250	98.3
10	0.0584	1.6000	96.4	10	0.0851	1.6000	94.7
11	0.2082	3.1600	93.4	11	0.2197	3.1600	93.1
12	0.0636	1.3333	95.2	12	0.0565	1.3333	95.8
13	0.0903	2.0600	95.6	13	0.1198	2.0600	94.2
THD	0.6196	23.4750	97.4	THD	0.5754	23.4750	97.5
PWHD	1.6734	23.4750	92.9	PWHD	1.7267	23.4750	92.6
SOFAR 33000TL-G2: L2 phase				SOFAR 33000TL-G2: L3 phase			

**Note:**

The tests should be based on the limits of the EN 61000-3-12 for more than 16A.  
Covered by EMC Report 13.7.6.8

**5.1.4.2 Additional measurements for PGUs intended for PGSs with nominal currents > 75 A**

**P**

The currents of the interharmonics to 2 kHz must be measured in accordance with DIN EN 61000-4-7 (VDE 0817-4-7), Annex A. The measurements of higher-frequency harmonic currents between 2 kHz and 9 kHz must be conducted in line with DIN EN 61000-4-7 (VDE 0847-4-7), Annex B.

**Test: SOFAR 33000TL-G2**

P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1	2,949	9,590	19,208	30,528	42,973	48,038	60,882	67,202	76,749	86,500	96,031
2	0,081	0,086	0,096	0,101	0,109	0,111	0,117	0,120	0,126	0,135	0,285
3	0,142	0,114	0,110	0,127	0,163	0,176	0,199	0,208	0,212	0,214	0,197
4	0,062	0,075	0,087	0,097	0,099	0,102	0,105	0,108	0,108	0,109	0,169
5	0,247	0,143	0,089	0,137	0,170	0,173	0,192	0,202	0,224	0,227	0,176
6	0,047	0,064	0,080	0,092	0,093	0,092	0,092	0,091	0,090	0,089	0,110
7	0,241	0,129	0,081	0,106	0,129	0,142	0,168	0,184	0,218	0,254	0,360
8	0,038	0,041	0,054	0,062	0,065	0,065	0,069	0,071	0,078	0,079	0,128
9	0,099	0,066	0,060	0,055	0,071	0,083	0,102	0,113	0,126	0,146	0,170
10	0,037	0,035	0,038	0,037	0,037	0,038	0,039	0,042	0,048	0,051	0,068
11	0,237	0,140	0,072	0,086	0,107	0,122	0,165	0,186	0,203	0,214	0,236
12	0,035	0,029	0,027	0,029	0,032	0,034	0,034	0,035	0,034	0,034	0,049
13	0,120	0,078	0,055	0,068	0,088	0,097	0,116	0,121	0,126	0,138	0,134
14	0,035	0,029	0,028	0,028	0,028	0,028	0,028	0,027	0,028	0,028	0,038
15	0,032	0,030	0,033	0,052	0,059	0,064	0,076	0,083	0,084	0,082	0,066
16	0,031	0,028	0,027	0,029	0,029	0,029	0,030	0,030	0,029	0,028	0,034
17	0,097	0,089	0,054	0,039	0,068	0,079	0,097	0,103	0,108	0,107	0,097
18	0,031	0,031	0,029	0,028	0,026	0,026	0,026	0,025	0,025	0,025	0,028
19	0,045	0,059	0,041	0,034	0,057	0,066	0,084	0,092	0,098	0,106	0,105
20	0,031	0,032	0,032	0,032	0,030	0,028	0,028	0,025	0,025	0,024	0,024
21	0,040	0,038	0,030	0,042	0,049	0,053	0,054	0,056	0,057	0,052	0,052
22	0,026	0,025	0,026	0,026	0,025	0,026	0,026	0,023	0,022	0,021	0,022
23	0,056	0,052	0,043	0,030	0,049	0,057	0,064	0,071	0,078	0,084	0,083
24	0,026	0,026	0,025	0,025	0,023	0,023	0,024	0,024	0,023	0,024	0,023
25	0,053	0,049	0,043	0,028	0,044	0,050	0,056	0,060	0,064	0,070	0,067
26	0,024	0,024	0,024	0,026	0,024	0,024	0,025	0,023	0,022	0,022	0,022
27	0,028	0,027	0,027	0,030	0,034	0,038	0,043	0,044	0,045	0,042	0,035
28	0,026	0,026	0,027	0,026	0,025	0,024	0,023	0,022	0,022	0,021	0,022
29	0,057	0,048	0,041	0,030	0,036	0,043	0,046	0,049	0,051	0,053	0,053
30	0,025	0,025	0,023	0,024	0,023	0,022	0,022	0,021	0,021	0,020	0,020
31	0,047	0,042	0,035	0,025	0,034	0,040	0,047	0,052	0,056	0,061	0,058
32	0,024	0,025	0,025	0,025	0,025	0,025	0,025	0,023	0,023	0,022	0,021
33	0,027	0,026	0,027	0,028	0,031	0,033	0,034	0,035	0,034	0,031	0,028
34	0,024	0,024	0,025	0,025	0,024	0,025	0,025	0,022	0,022	0,022	0,021
35	0,035	0,043	0,034	0,031	0,031	0,036	0,045	0,051	0,055	0,056	0,056
36	0,025	0,024	0,023	0,022	0,021	0,021	0,023	0,023	0,022	0,021	0,020
37	0,042	0,043	0,031	0,029	0,030	0,033	0,035	0,038	0,039	0,040	0,040
38	0,024	0,025	0,026	0,027	0,026	0,026	0,025	0,023	0,023	0,024	0,023

39	0,024	0,026	0,024	0,025	0,025	0,027	0,027	0,028	0,027	0,026	0,024
40	0,025	0,026	0,027	0,027	0,025	0,025	0,024	0,023	0,022	0,022	0,022
<b>Interharmonics : SOFAR 33000TL-G2</b>											
P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
F [Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
75	0,174	0,225	0,262	0,301	0,321	0,323	0,349	0,365	0,388	0,413	0,443
125	0,129	0,225	0,271	0,288	0,287	0,288	0,291	0,297	0,299	0,298	0,301
175	0,104	0,192	0,262	0,275	0,279	0,286	0,288	0,290	0,295	0,304	0,314
225	0,084	0,156	0,212	0,239	0,246	0,259	0,267	0,273	0,273	0,270	0,273
275	0,064	0,118	0,153	0,164	0,177	0,174	0,178	0,185	0,201	0,222	0,236
325	0,059	0,084	0,115	0,115	0,121	0,124	0,142	0,152	0,166	0,175	0,184
375	0,049	0,064	0,091	0,080	0,081	0,075	0,074	0,077	0,088	0,104	0,118
425	0,045	0,057	0,069	0,061	0,060	0,061	0,066	0,075	0,087	0,099	0,112
475	0,042	0,049	0,049	0,046	0,048	0,050	0,051	0,052	0,056	0,066	0,075
525	0,048	0,045	0,043	0,043	0,047	0,049	0,054	0,058	0,065	0,077	0,092
575	0,052	0,043	0,040	0,042	0,045	0,044	0,045	0,042	0,043	0,043	0,043
625	0,042	0,038	0,035	0,038	0,038	0,037	0,038	0,037	0,037	0,036	0,036
675	0,043	0,036	0,037	0,038	0,037	0,036	0,036	0,036	0,037	0,037	0,037
725	0,037	0,034	0,037	0,037	0,035	0,034	0,034	0,033	0,034	0,034	0,033
775	0,036	0,036	0,038	0,036	0,034	0,034	0,034	0,033	0,033	0,033	0,030
825	0,033	0,034	0,036	0,033	0,032	0,032	0,032	0,032	0,032	0,030	0,030
875	0,035	0,035	0,034	0,035	0,034	0,033	0,033	0,033	0,033	0,033	0,034
925	0,033	0,033	0,033	0,032	0,033	0,033	0,033	0,032	0,031	0,031	0,031
975	0,034	0,034	0,032	0,033	0,034	0,033	0,033	0,032	0,032	0,031	0,031
1025	0,036	0,037	0,034	0,035	0,034	0,033	0,031	0,032	0,032	0,030	0,031
1075	0,035	0,036	0,036	0,038	0,034	0,033	0,032	0,031	0,030	0,029	0,029
1125	0,032	0,032	0,031	0,032	0,030	0,028	0,029	0,030	0,029	0,029	0,027
1175	0,034	0,033	0,034	0,033	0,032	0,031	0,030	0,030	0,031	0,033	0,033
1225	0,031	0,030	0,032	0,031	0,030	0,030	0,030	0,030	0,030	0,030	0,028
1275	0,031	0,031	0,031	0,032	0,035	0,037	0,041	0,040	0,044	0,047	0,044
1325	0,032	0,030	0,032	0,032	0,032	0,031	0,031	0,030	0,030	0,030	0,030
1375	0,033	0,033	0,033	0,033	0,032	0,032	0,031	0,029	0,030	0,030	0,029
1425	0,032	0,032	0,032	0,032	0,031	0,028	0,029	0,029	0,029	0,028	0,028
1475	0,031	0,031	0,031	0,031	0,030	0,029	0,029	0,029	0,029	0,029	0,028
1525	0,030	0,030	0,030	0,031	0,029	0,029	0,028	0,027	0,027	0,026	0,026
1575	0,031	0,031	0,032	0,031	0,030	0,030	0,031	0,030	0,029	0,029	0,029
1625	0,030	0,032	0,031	0,031	0,032	0,031	0,031	0,031	0,029	0,028	0,028
1675	0,032	0,033	0,033	0,034	0,032	0,033	0,031	0,030	0,030	0,029	0,027
1725	0,031	0,032	0,031	0,032	0,031	0,031	0,031	0,030	0,029	0,027	0,026
1775	0,032	0,032	0,031	0,031	0,029	0,029	0,029	0,029	0,029	0,029	0,027
1825	0,030	0,030	0,030	0,030	0,030	0,030	0,031	0,029	0,028	0,027	0,027
1875	0,032	0,033	0,033	0,033	0,031	0,030	0,030	0,030	0,030	0,031	0,029
1925	0,029	0,029	0,030	0,031	0,031	0,030	0,030	0,029	0,029	0,028	0,027
1975	0,031	0,031	0,032	0,032	0,032	0,031	0,032	0,032	0,032	0,030	0,029

**Higher Frequencies : SOFAR 33000TL-G2**

P/Pn [%]	0	10	20	30	40	50	60	70	80	90	100
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2,1	0,042	0,045	0,034	0,026	0,028	0,034	0,039	0,044	0,048	0,052	0,051
2,3	0,022	0,031	0,027	0,022	0,026	0,031	0,037	0,041	0,044	0,045	0,046
2,5	0,020	0,035	0,026	0,021	0,019	0,022	0,027	0,031	0,033	0,035	0,035
2,7	0,031	0,040	0,033	0,029	0,025	0,028	0,034	0,038	0,040	0,044	0,044
2,9	0,028	0,057	0,042	0,028	0,020	0,025	0,032	0,037	0,038	0,039	0,039
3,1	0,021	0,037	0,029	0,028	0,042	0,033	0,025	0,026	0,026	0,027	0,027
3,3	0,024	0,029	0,022	0,016	0,033	0,043	0,051	0,043	0,040	0,041	0,041
3,5	0,018	0,019	0,018	0,014	0,023	0,033	0,050	0,050	0,047	0,043	0,041
3,7	0,011	0,012	0,011	0,011	0,014	0,019	0,039	0,046	0,037	0,028	0,026
3,9	0,015	0,015	0,011	0,009	0,011	0,013	0,027	0,043	0,074	0,071	0,059
4,1	0,012	0,012	0,009	0,009	0,009	0,010	0,017	0,026	0,076	0,077	0,064
4,3	0,011	0,011	0,010	0,008	0,008	0,008	0,011	0,015	0,027	0,045	0,050
4,5	0,014	0,011	0,010	0,008	0,009	0,009	0,010	0,012	0,016	0,031	0,058
4,7	0,010	0,013	0,011	0,008	0,008	0,008	0,008	0,009	0,012	0,021	0,045
4,9	0,010	0,010	0,009	0,008	0,008	0,008	0,008	0,010	0,010	0,012	0,014
5,1	0,012	0,016	0,011	0,010	0,009	0,008	0,008	0,010	0,010	0,012	0,012
5,3	0,008	0,011	0,010	0,008	0,008	0,007	0,008	0,008	0,009	0,011	0,013
5,5	0,009	0,009	0,009	0,009	0,008	0,007	0,007	0,008	0,009	0,011	0,010
5,7	0,012	0,011	0,010	0,010	0,010	0,008	0,008	0,008	0,009	0,011	0,011
5,9	0,009	0,011	0,010	0,009	0,009	0,007	0,008	0,008	0,009	0,011	0,011
6,1	0,009	0,010	0,010	0,009	0,009	0,008	0,007	0,008	0,009	0,010	0,010
6,3	0,011	0,014	0,012	0,008	0,010	0,009	0,008	0,008	0,010	0,011	0,011
6,5	0,011	0,014	0,012	0,012	0,015	0,009	0,008	0,007	0,009	0,011	0,011
6,7	0,011	0,013	0,012	0,008	0,014	0,018	0,015	0,008	0,010	0,010	0,010
6,9	0,013	0,019	0,015	0,010	0,011	0,011	0,019	0,018	0,017	0,013	0,011
7,1	0,016	0,020	0,016	0,011	0,012	0,009	0,010	0,015	0,019	0,020	0,018
7,3	0,018	0,020	0,017	0,011	0,011	0,009	0,008	0,008	0,012	0,019	0,018
7,5	0,020	0,025	0,021	0,015	0,017	0,013	0,012	0,011	0,012	0,012	0,014
7,7	0,041	0,038	0,032	0,021	0,020	0,016	0,013	0,011	0,012	0,011	0,010
7,9	0,067	0,063	0,047	0,026	0,025	0,018	0,015	0,011	0,012	0,012	0,011
8,1	0,057	0,073	0,060	0,039	0,041	0,028	0,022	0,018	0,018	0,017	0,014
8,3	0,086	0,081	0,062	0,050	0,048	0,036	0,027	0,021	0,020	0,019	0,016
8,5	0,060	0,074	0,064	0,050	0,054	0,047	0,037	0,027	0,025	0,022	0,018
8,7	0,038	0,052	0,051	0,040	0,042	0,042	0,041	0,039	0,036	0,031	0,024
8,9	0,027	0,034	0,032	0,039	0,028	0,025	0,033	0,037	0,035	0,032	0,027

**Note:**

The normalization current is 47,82A for SOFAR 33000TL-G2  
The stated harmonics are maximum values of all 3 phases.

Test: SOFAR 3000TL-G2											
P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1	2,924	10,901	19,129	30,207	38,389	48,022	62,066	67,240	79,170	90,476	96,181
2	0,090	0,093	0,104	0,110	0,112	0,120	0,127	0,130	0,138	0,147	0,152
3	0,166	0,143	0,113	0,129	0,156	0,184	0,209	0,221	0,238	0,237	0,233
4	0,061	0,087	0,096	0,106	0,107	0,112	0,117	0,118	0,125	0,126	0,123
5	0,237	0,194	0,095	0,134	0,166	0,184	0,199	0,208	0,241	0,253	0,254
6	0,057	0,072	0,088	0,101	0,105	0,105	0,101	0,099	0,099	0,099	0,099
7	0,228	0,177	0,093	0,105	0,139	0,149	0,166	0,180	0,215	0,264	0,309
8	0,049	0,045	0,057	0,064	0,071	0,071	0,073	0,076	0,082	0,086	0,086
9	0,118	0,080	0,067	0,064	0,066	0,083	0,098	0,106	0,127	0,148	0,165
10	0,042	0,040	0,040	0,040	0,039	0,041	0,042	0,043	0,048	0,054	0,055
11	0,202	0,154	0,043	0,085	0,106	0,118	0,161	0,178	0,214	0,232	0,243
12	0,041	0,038	0,029	0,029	0,032	0,033	0,036	0,037	0,038	0,039	0,039
13	0,064	0,107	0,043	0,064	0,086	0,102	0,118	0,128	0,139	0,149	0,161
14	0,038	0,035	0,030	0,030	0,031	0,032	0,031	0,029	0,028	0,030	0,031
15	0,036	0,038	0,036	0,055	0,058	0,066	0,079	0,086	0,093	0,091	0,086
16	0,033	0,031	0,030	0,030	0,031	0,031	0,031	0,030	0,031	0,030	0,030
17	0,118	0,102	0,045	0,035	0,056	0,077	0,098	0,104	0,114	0,119	0,113
18	0,033	0,033	0,032	0,033	0,031	0,030	0,029	0,027	0,027	0,026	0,026
19	0,058	0,075	0,041	0,034	0,046	0,068	0,084	0,093	0,107	0,112	0,119
20	0,034	0,036	0,034	0,034	0,032	0,032	0,032	0,029	0,027	0,026	0,025
21	0,054	0,048	0,032	0,040	0,051	0,056	0,059	0,062	0,063	0,061	0,060
22	0,030	0,029	0,028	0,027	0,027	0,028	0,028	0,027	0,026	0,024	0,022
23	0,086	0,064	0,047	0,037	0,039	0,057	0,067	0,070	0,081	0,090	0,094
24	0,031	0,030	0,027	0,028	0,026	0,026	0,025	0,024	0,023	0,023	0,024
25	0,061	0,061	0,042	0,032	0,035	0,050	0,059	0,061	0,069	0,073	0,079
26	0,026	0,026	0,025	0,026	0,026	0,026	0,025	0,025	0,025	0,023	0,022
27	0,032	0,030	0,029	0,031	0,034	0,039	0,046	0,048	0,047	0,048	0,042
28	0,029	0,028	0,028	0,028	0,027	0,027	0,027	0,026	0,025	0,023	0,021
29	0,041	0,060	0,038	0,035	0,029	0,045	0,050	0,053	0,054	0,059	0,059
30	0,028	0,028	0,026	0,026	0,025	0,025	0,025	0,023	0,021	0,021	0,020
31	0,028	0,058	0,031	0,029	0,027	0,041	0,048	0,053	0,059	0,064	0,067
32	0,027	0,027	0,026	0,025	0,025	0,027	0,026	0,026	0,025	0,024	0,023
33	0,030	0,029	0,029	0,028	0,031	0,036	0,037	0,037	0,038	0,036	0,031
34	0,028	0,027	0,026	0,026	0,026	0,026	0,025	0,025	0,024	0,022	0,022
35	0,061	0,058	0,037	0,035	0,029	0,036	0,044	0,048	0,059	0,062	0,064
36	0,029	0,028	0,026	0,027	0,024	0,024	0,023	0,022	0,022	0,023	0,023
37	0,060	0,051	0,032	0,032	0,028	0,033	0,037	0,037	0,042	0,043	0,043
38	0,027	0,027	0,027	0,028	0,028	0,029	0,028	0,026	0,026	0,024	0,025
39	0,027	0,029	0,027	0,026	0,027	0,028	0,029	0,028	0,029	0,029	0,026
40	0,030	0,029	0,029	0,030	0,029	0,028	0,027	0,025	0,025	0,024	0,023

Interharmonics : SOFAR 3000TL-G2											
P/Pn [%]	0	10	20	30	40	50	60	70	80	90	100
f [Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
75	0,183	0,250	0,281	0,314	0,325	0,345	0,377	0,382	0,414	0,443	0,453
125	0,136	0,245	0,290	0,309	0,314	0,317	0,317	0,318	0,326	0,328	0,324
175	0,110	0,210	0,276	0,299	0,302	0,311	0,315	0,315	0,321	0,330	0,333
225	0,090	0,172	0,221	0,259	0,262	0,275	0,290	0,293	0,300	0,301	0,299
275	0,073	0,127	0,164	0,174	0,188	0,196	0,194	0,197	0,213	0,235	0,243
325	0,067	0,091	0,124	0,125	0,127	0,133	0,146	0,153	0,170	0,186	0,192
375	0,051	0,068	0,100	0,091	0,086	0,086	0,083	0,082	0,090	0,105	0,114
425	0,050	0,062	0,078	0,068	0,065	0,065	0,070	0,073	0,086	0,102	0,109
475	0,045	0,053	0,056	0,051	0,049	0,053	0,055	0,055	0,058	0,067	0,071
525	0,048	0,050	0,045	0,043	0,046	0,050	0,057	0,059	0,067	0,078	0,085
575	0,054	0,048	0,044	0,046	0,047	0,048	0,047	0,046	0,046	0,046	0,047
625	0,043	0,042	0,037	0,040	0,040	0,041	0,040	0,040	0,041	0,039	0,038
675	0,046	0,043	0,039	0,041	0,040	0,040	0,039	0,037	0,037	0,038	0,038
725	0,040	0,039	0,039	0,039	0,038	0,037	0,037	0,036	0,036	0,036	0,036
775	0,039	0,039	0,041	0,039	0,037	0,036	0,036	0,035	0,036	0,034	0,033
825	0,037	0,038	0,038	0,035	0,034	0,034	0,033	0,033	0,033	0,032	0,031
875	0,039	0,040	0,039	0,038	0,038	0,037	0,037	0,033	0,035	0,035	0,036
925	0,037	0,037	0,036	0,034	0,035	0,035	0,035	0,035	0,035	0,034	0,033
975	0,040	0,039	0,035	0,036	0,037	0,036	0,035	0,033	0,033	0,033	0,032
1025	0,042	0,042	0,039	0,039	0,038	0,037	0,037	0,034	0,033	0,033	0,031
1075	0,041	0,040	0,039	0,039	0,039	0,038	0,036	0,034	0,033	0,031	0,030
1125	0,037	0,036	0,035	0,034	0,032	0,032	0,032	0,030	0,030	0,029	0,029
1175	0,037	0,038	0,036	0,036	0,035	0,034	0,034	0,032	0,033	0,032	0,033
1225	0,035	0,035	0,034	0,034	0,033	0,033	0,032	0,030	0,031	0,032	0,031
1275	0,034	0,035	0,033	0,032	0,034	0,037	0,043	0,040	0,041	0,039	0,038
1325	0,036	0,035	0,034	0,033	0,034	0,033	0,033	0,032	0,031	0,031	0,030
1375	0,038	0,038	0,036	0,036	0,035	0,035	0,035	0,033	0,032	0,031	0,029
1425	0,036	0,036	0,035	0,035	0,034	0,033	0,031	0,030	0,029	0,029	0,029
1475	0,036	0,036	0,034	0,033	0,032	0,032	0,031	0,030	0,029	0,029	0,029
1525	0,034	0,033	0,032	0,032	0,031	0,032	0,031	0,031	0,030	0,028	0,028
1575	0,035	0,035	0,033	0,033	0,032	0,033	0,033	0,032	0,032	0,030	0,029
1625	0,033	0,033	0,033	0,032	0,033	0,034	0,033	0,034	0,033	0,031	0,029
1675	0,036	0,036	0,035	0,036	0,036	0,036	0,035	0,033	0,032	0,029	0,028
1725	0,035	0,036	0,034	0,033	0,033	0,032	0,031	0,030	0,031	0,030	0,029
1775	0,036	0,035	0,034	0,034	0,033	0,032	0,033	0,032	0,030	0,029	0,029
1825	0,034	0,034	0,032	0,032	0,032	0,031	0,031	0,030	0,030	0,029	0,029
1875	0,036	0,036	0,035	0,035	0,034	0,033	0,034	0,032	0,032	0,031	0,030
1925	0,033	0,033	0,031	0,032	0,031	0,032	0,032	0,031	0,031	0,029	0,028
1975	0,036	0,036	0,035	0,035	0,034	0,034	0,034	0,033	0,034	0,033	0,032

Higher Frequencies : SOFAR 3000TL-G2											
P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2,1	0,025	0,059	0,032	0,030	0,023	0,033	0,039	0,043	0,051	0,054	0,056
2,3	0,037	0,043	0,026	0,027	0,021	0,030	0,039	0,041	0,046	0,048	0,049
2,5	0,035	0,042	0,018	0,022	0,017	0,023	0,027	0,029	0,035	0,036	0,037
2,7	0,027	0,039	0,021	0,033	0,023	0,030	0,034	0,039	0,044	0,045	0,048
2,9	0,033	0,058	0,027	0,034	0,019	0,022	0,033	0,037	0,041	0,042	0,043
3,1	0,027	0,034	0,024	0,026	0,044	0,043	0,035	0,026	0,029	0,028	0,029
3,3	0,014	0,026	0,017	0,017	0,024	0,038	0,053	0,053	0,048	0,043	0,046
3,5	0,017	0,017	0,017	0,016	0,016	0,023	0,055	0,058	0,054	0,047	0,045
3,7	0,015	0,012	0,011	0,013	0,012	0,016	0,035	0,046	0,045	0,030	0,029
3,9	0,013	0,014	0,009	0,012	0,009	0,012	0,024	0,031	0,059	0,089	0,075
4,1	0,017	0,014	0,011	0,010	0,009	0,011	0,014	0,017	0,049	0,091	0,082
4,3	0,015	0,014	0,012	0,010	0,008	0,009	0,011	0,012	0,022	0,038	0,049
4,5	0,013	0,015	0,011	0,010	0,009	0,010	0,010	0,011	0,014	0,024	0,033
4,7	0,012	0,011	0,013	0,010	0,009	0,009	0,009	0,010	0,012	0,018	0,023
4,9	0,009	0,010	0,010	0,010	0,009	0,008	0,008	0,010	0,011	0,011	0,012
5,1	0,011	0,012	0,014	0,011	0,011	0,010	0,009	0,010	0,010	0,011	0,012
5,3	0,009	0,012	0,014	0,011	0,009	0,009	0,008	0,009	0,009	0,010	0,012
5,5	0,010	0,011	0,013	0,011	0,010	0,008	0,008	0,008	0,009	0,010	0,011
5,7	0,012	0,014	0,013	0,010	0,011	0,010	0,008	0,009	0,009	0,010	0,011
5,9	0,009	0,014	0,011	0,009	0,010	0,009	0,008	0,009	0,009	0,010	0,011
6,1	0,011	0,014	0,011	0,010	0,010	0,009	0,008	0,008	0,009	0,010	0,011
6,3	0,014	0,019	0,014	0,011	0,010	0,010	0,009	0,009	0,009	0,011	0,012
6,5	0,011	0,014	0,013	0,012	0,013	0,011	0,009	0,008	0,009	0,010	0,011
6,7	0,013	0,015	0,013	0,010	0,010	0,017	0,017	0,009	0,009	0,010	0,011
6,9	0,015	0,019	0,014	0,011	0,011	0,011	0,019	0,020	0,020	0,019	0,019
7,1	0,017	0,021	0,015	0,014	0,012	0,012	0,011	0,014	0,017	0,020	0,021
7,3	0,020	0,022	0,016	0,013	0,012	0,011	0,010	0,009	0,010	0,012	0,014
7,5	0,020	0,027	0,020	0,018	0,017	0,016	0,014	0,013	0,012	0,013	0,012
7,7	0,047	0,045	0,034	0,028	0,021	0,021	0,017	0,013	0,012	0,013	0,012
7,9	0,075	0,075	0,045	0,035	0,027	0,024	0,020	0,014	0,013	0,013	0,013
8,1	0,064	0,072	0,064	0,053	0,046	0,040	0,031	0,021	0,020	0,019	0,016
8,3	0,095	0,094	0,063	0,056	0,051	0,050	0,039	0,025	0,024	0,021	0,019
8,5	0,068	0,080	0,061	0,051	0,055	0,058	0,051	0,032	0,030	0,025	0,022
8,7	0,041	0,057	0,058	0,050	0,042	0,049	0,047	0,044	0,043	0,035	0,029
8,9	0,029	0,034	0,036	0,040	0,036	0,027	0,033	0,039	0,038	0,037	0,033

**Note:**

The normalization current is 43,48A for SOFAR 3000TL-G2  
 The stated harmonics are maximum values of all 3 phases.



Test: SOFAR 25000TL-G2											
P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1	2,906	9,588	19,213	28,625	38,287	47,927	57,540	69,516	76,733	86,283	95,840
2	0,097	0,105	0,121	0,127	0,133	0,138	0,144	0,152	0,154	0,159	0,165
3	0,227	0,159	0,138	0,143	0,160	0,192	0,223	0,248	0,262	0,279	0,289
4	0,060	0,100	0,111	0,120	0,129	0,131	0,135	0,142	0,143	0,145	0,148
5	0,276	0,176	0,118	0,120	0,168	0,208	0,227	0,239	0,253	0,269	0,293
6	0,068	0,077	0,096	0,115	0,124	0,126	0,124	0,121	0,118	0,120	0,118
7	0,222	0,154	0,103	0,106	0,137	0,154	0,177	0,206	0,240	0,251	0,288
8	0,048	0,050	0,063	0,076	0,081	0,086	0,085	0,087	0,090	0,094	0,098
9	0,089	0,092	0,083	0,071	0,073	0,073	0,093	0,117	0,131	0,147	0,164
10	0,045	0,044	0,046	0,048	0,048	0,048	0,049	0,051	0,051	0,053	0,058
11	0,129	0,204	0,099	0,069	0,108	0,127	0,140	0,183	0,208	0,244	0,267
12	0,051	0,039	0,036	0,035	0,036	0,038	0,040	0,041	0,042	0,044	0,046
13	0,143	0,162	0,080	0,053	0,085	0,102	0,121	0,140	0,155	0,165	0,176
14	0,041	0,038	0,037	0,036	0,037	0,038	0,038	0,036	0,035	0,034	0,034
15	0,072	0,044	0,042	0,052	0,068	0,069	0,078	0,089	0,096	0,109	0,111
16	0,037	0,038	0,035	0,035	0,036	0,037	0,036	0,035	0,036	0,036	0,037
17	0,116	0,140	0,081	0,052	0,048	0,070	0,091	0,114	0,124	0,135	0,141
18	0,041	0,041	0,039	0,039	0,038	0,037	0,036	0,036	0,035	0,031	0,030
19	0,089	0,109	0,065	0,046	0,040	0,060	0,081	0,097	0,106	0,119	0,135
20	0,042	0,043	0,041	0,041	0,041	0,040	0,039	0,038	0,035	0,034	0,032
21	0,056	0,044	0,039	0,039	0,052	0,062	0,065	0,072	0,074	0,074	0,076
22	0,035	0,034	0,034	0,033	0,032	0,032	0,033	0,032	0,032	0,031	0,031
23	0,087	0,080	0,057	0,050	0,040	0,050	0,067	0,078	0,081	0,093	0,099
24	0,036	0,036	0,036	0,034	0,033	0,033	0,030	0,030	0,029	0,028	0,027
25	0,055	0,083	0,050	0,046	0,039	0,043	0,059	0,069	0,072	0,077	0,085
26	0,030	0,031	0,031	0,031	0,032	0,031	0,031	0,030	0,029	0,029	0,029
27	0,040	0,037	0,037	0,035	0,038	0,040	0,046	0,052	0,055	0,058	0,058
28	0,033	0,034	0,033	0,034	0,033	0,032	0,031	0,032	0,032	0,031	0,029
29	0,075	0,095	0,056	0,047	0,041	0,038	0,052	0,059	0,061	0,064	0,066
30	0,032	0,032	0,032	0,030	0,030	0,030	0,030	0,030	0,028	0,027	0,025
31	0,079	0,099	0,053	0,043	0,034	0,035	0,048	0,056	0,060	0,068	0,071
32	0,032	0,031	0,031	0,030	0,031	0,031	0,032	0,032	0,030	0,031	0,029
33	0,034	0,035	0,034	0,035	0,034	0,038	0,041	0,044	0,044	0,044	0,044
34	0,033	0,032	0,031	0,031	0,031	0,030	0,030	0,031	0,030	0,030	0,028
35	0,043	0,088	0,054	0,045	0,040	0,036	0,044	0,050	0,055	0,067	0,074
36	0,036	0,035	0,032	0,030	0,029	0,029	0,028	0,027	0,026	0,025	0,027
37	0,040	0,073	0,043	0,037	0,039	0,034	0,040	0,043	0,044	0,048	0,051
38	0,032	0,033	0,033	0,034	0,034	0,033	0,034	0,033	0,033	0,032	0,031
39	0,035	0,033	0,031	0,031	0,032	0,032	0,032	0,034	0,033	0,034	0,035
40	0,034	0,035	0,035	0,035	0,034	0,034	0,033	0,032	0,032	0,031	0,029

Interharmonics : SOFAR 20000TL-G2											
P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
f [Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
75	0,214	0,280	0,324	0,356	0,382	0,393	0,415	0,440	0,453	0,473	0,496
125	0,152	0,270	0,336	0,361	0,373	0,377	0,378	0,380	0,382	0,385	0,390
175	0,113	0,219	0,307	0,348	0,358	0,362	0,374	0,379	0,379	0,382	0,387
225	0,089	0,185	0,244	0,292	0,311	0,315	0,330	0,348	0,354	0,359	0,363
275	0,082	0,127	0,182	0,202	0,210	0,227	0,236	0,232	0,233	0,242	0,254
325	0,081	0,090	0,137	0,151	0,150	0,154	0,159	0,168	0,180	0,191	0,205
375	0,062	0,065	0,117	0,112	0,105	0,103	0,102	0,100	0,094	0,099	0,108
425	0,060	0,066	0,092	0,086	0,077	0,076	0,078	0,080	0,085	0,093	0,104
475	0,052	0,061	0,069	0,064	0,058	0,060	0,063	0,066	0,066	0,067	0,069
525	0,051	0,059	0,058	0,054	0,054	0,056	0,060	0,066	0,070	0,074	0,079
575	0,055	0,052	0,050	0,052	0,055	0,057	0,058	0,057	0,055	0,056	0,054
625	0,055	0,053	0,046	0,046	0,047	0,048	0,047	0,048	0,048	0,049	0,049
675	0,052	0,049	0,044	0,049	0,048	0,047	0,046	0,046	0,045	0,045	0,045
725	0,047	0,047	0,045	0,050	0,048	0,046	0,045	0,044	0,044	0,044	0,044
775	0,047	0,049	0,048	0,048	0,046	0,043	0,043	0,043	0,042	0,042	0,042
825	0,046	0,046	0,045	0,046	0,041	0,041	0,040	0,040	0,039	0,040	0,040
875	0,049	0,047	0,047	0,045	0,044	0,044	0,044	0,042	0,042	0,041	0,040
925	0,047	0,044	0,044	0,043	0,041	0,042	0,042	0,041	0,041	0,041	0,040
975	0,048	0,046	0,043	0,042	0,043	0,042	0,043	0,041	0,040	0,040	0,039
1025	0,050	0,049	0,047	0,046	0,046	0,046	0,044	0,043	0,042	0,041	0,039
1075	0,047	0,048	0,047	0,048	0,047	0,046	0,044	0,043	0,042	0,041	0,038
1125	0,044	0,043	0,041	0,041	0,040	0,039	0,038	0,037	0,036	0,036	0,035
1175	0,045	0,045	0,043	0,044	0,042	0,042	0,041	0,040	0,039	0,039	0,038
1225	0,042	0,042	0,041	0,041	0,039	0,039	0,038	0,038	0,036	0,037	0,037
1275	0,044	0,042	0,040	0,039	0,039	0,040	0,042	0,049	0,048	0,046	0,044
1325	0,043	0,042	0,041	0,040	0,040	0,040	0,040	0,039	0,039	0,038	0,037
1375	0,047	0,046	0,045	0,043	0,044	0,042	0,042	0,041	0,040	0,040	0,038
1425	0,043	0,042	0,042	0,042	0,041	0,040	0,039	0,038	0,036	0,036	0,035
1475	0,042	0,043	0,041	0,040	0,039	0,039	0,037	0,037	0,036	0,036	0,036
1525	0,042	0,040	0,039	0,039	0,039	0,038	0,037	0,036	0,036	0,035	0,035
1575	0,041	0,041	0,040	0,039	0,040	0,039	0,038	0,039	0,038	0,038	0,037
1625	0,039	0,039	0,040	0,041	0,039	0,040	0,041	0,040	0,040	0,039	0,037
1675	0,042	0,045	0,044	0,043	0,043	0,042	0,041	0,041	0,040	0,038	0,035
1725	0,042	0,042	0,040	0,039	0,039	0,038	0,038	0,039	0,037	0,037	0,038
1775	0,043	0,042	0,042	0,041	0,041	0,040	0,039	0,039	0,039	0,037	0,036
1825	0,041	0,041	0,039	0,039	0,038	0,037	0,037	0,037	0,036	0,037	0,036
1875	0,043	0,043	0,043	0,042	0,041	0,040	0,040	0,040	0,040	0,039	0,038
1925	0,039	0,039	0,038	0,038	0,038	0,038	0,038	0,038	0,037	0,037	0,037
1975	0,042	0,043	0,043	0,042	0,041	0,041	0,041	0,041	0,041	0,041	0,040

**Higher Frequencies : SOFAR 2000TL-G2**

P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2,1	1,270	1,032	0,754	0,743	0,712	0,795	0,840	0,812	0,678	0,621	0,533
2,3	4,399	5,220	3,547	2,936	2,688	2,304	2,042	2,088	2,133	2,121	2,081
2,5	1,969	2,346	3,575	3,153	2,797	2,756	2,562	2,268	1,540	1,408	1,210
2,7	3,050	2,126	1,802	1,814	1,473	1,252	1,207	1,127	0,830	0,744	0,613
2,9	6,549	7,872	6,148	9,851	7,721	4,732	2,820	2,635	2,525	2,438	2,234
3,1	4,360	7,335	8,719	6,728	8,558	11,654	8,612	5,824	1,982	1,698	1,284
3,3	1,698	1,836	1,796	1,802	2,047	3,240	4,534	4,212	2,259	1,809	1,151
3,5	3,197	3,682	3,156	4,303	4,096	3,724	4,684	9,131	9,483	7,558	4,620
3,7	1,478	0,984	1,989	1,339	1,013	1,886	2,703	3,356	3,724	5,037	4,220
3,9	1,005	0,847	0,840	0,692	0,598	0,610	0,829	1,250	1,433	1,993	3,068
4,1	2,579	1,554	2,138	1,711	1,208	0,959	0,810	1,417	2,235	3,663	6,471
4,3	1,239	1,520	1,293	0,840	0,647	0,976	1,076	1,013	0,863	1,063	1,534
4,5	1,081	0,913	0,789	0,569	0,421	0,429	0,424	0,502	0,534	0,636	0,808
4,7	1,647	1,933	1,930	1,458	0,946	0,653	0,476	0,694	0,960	1,229	1,524
4,9	0,805	1,800	1,479	0,922	0,534	0,770	0,753	0,670	0,470	0,533	0,679
5,1	0,473	0,665	0,887	0,734	0,464	0,397	0,340	0,342	0,350	0,394	0,475
5,3	0,382	1,022	1,806	1,419	1,032	0,736	0,405	0,483	0,671	0,785	0,873
5,5	0,266	0,320	0,611	0,601	0,691	0,812	0,723	0,601	0,375	0,409	0,517
5,7	0,227	0,201	0,262	0,382	0,533	0,498	0,351	0,321	0,312	0,330	0,394
5,9	0,252	0,222	0,307	0,359	0,737	0,747	0,492	0,423	0,563	0,611	0,634
6,1	0,121	0,257	0,248	0,339	0,506	0,696	0,794	0,679	0,413	0,416	0,500
6,3	0,603	0,749	0,944	0,614	0,269	0,367	0,461	0,405	0,432	0,424	0,458
6,5	0,112	0,210	0,274	1,227	1,556	1,404	0,814	0,669	0,549	0,599	0,604
6,7	0,082	0,110	0,117	0,135	0,243	1,881	2,560	2,836	1,287	1,189	1,224
6,9	0,070	0,083	0,097	0,095	0,132	0,187	0,336	1,233	2,870	3,072	2,980
7,1	0,052	0,083	0,116	0,106	0,120	0,178	0,195	0,343	0,424	0,478	0,828
7,3	0,055	0,086	0,099	0,087	0,084	0,152	0,198	0,234	0,241	0,224	0,273
7,5	0,319	0,323	0,324	0,323	0,326	0,330	0,337	0,343	0,371	0,386	0,396
7,7	0,066	0,108	0,098	0,090	0,086	0,110	0,118	0,127	0,159	0,168	0,182
7,9	0,118	0,129	0,127	0,116	0,108	0,131	0,153	0,151	0,147	0,156	0,174
8,1	0,323	0,325	0,329	0,324	0,325	0,328	0,331	0,329	0,334	0,337	0,338
8,3	0,114	0,115	0,094	0,073	0,065	0,087	0,100	0,094	0,101	0,095	0,109
8,5	0,072	0,110	0,099	0,080	0,068	0,068	0,074	0,084	0,082	0,077	0,091
8,7	0,046	0,061	0,076	0,069	0,057	0,065	0,059	0,059	0,070	0,073	0,081
8,9	0,041	0,045	0,045	0,042	0,051	0,061	0,053	0,048	0,055	0,054	0,068

**Note:**

The normalization current is 36,23A for SOFAR 25000TL-G2  
The stated harmonics are maximum values of all 3 phases.

Test: SOFAR 20000TL-G2											
P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1	3,010	9,631	19,145	28,884	38,271	47,958	57,623	69,618	76,895	86,516	96,135
2	0,118	0,132	0,145	0,155	0,161	0,165	0,172	0,180	0,183	0,189	0,196
3	0,341	0,235	0,188	0,174	0,181	0,203	0,234	0,275	0,292	0,312	0,336
4	0,077	0,114	0,131	0,142	0,152	0,158	0,162	0,167	0,172	0,177	0,181
5	0,440	0,283	0,189	0,142	0,161	0,212	0,249	0,291	0,295	0,313	0,328
6	0,073	0,092	0,111	0,128	0,144	0,155	0,156	0,155	0,154	0,151	0,150
7	0,292	0,225	0,151	0,138	0,138	0,173	0,198	0,224	0,237	0,271	0,319
8	0,059	0,059	0,077	0,086	0,095	0,102	0,105	0,106	0,108	0,109	0,110
9	0,140	0,124	0,111	0,106	0,092	0,089	0,095	0,116	0,133	0,154	0,173
10	0,054	0,055	0,057	0,056	0,059	0,060	0,059	0,062	0,063	0,063	0,062
11	0,257	0,294	0,200	0,085	0,096	0,137	0,157	0,178	0,197	0,236	0,269
12	0,054	0,048	0,057	0,050	0,049	0,048	0,048	0,050	0,053	0,052	0,052
13	0,220	0,235	0,167	0,075	0,075	0,107	0,128	0,150	0,164	0,180	0,205
14	0,046	0,045	0,046	0,042	0,043	0,046	0,046	0,047	0,048	0,046	0,044
15	0,070	0,066	0,056	0,055	0,073	0,084	0,087	0,096	0,107	0,114	0,124
16	0,046	0,050	0,048	0,047	0,044	0,045	0,046	0,046	0,046	0,044	0,044
17	0,087	0,210	0,156	0,078	0,055	0,059	0,082	0,111	0,125	0,145	0,160
18	0,050	0,052	0,045	0,044	0,046	0,047	0,045	0,047	0,046	0,046	0,043
19	0,126	0,166	0,124	0,065	0,055	0,051	0,069	0,096	0,109	0,121	0,137
20	0,051	0,052	0,049	0,048	0,050	0,050	0,049	0,050	0,050	0,048	0,045
21	0,073	0,058	0,049	0,045	0,051	0,065	0,076	0,081	0,086	0,090	0,093
22	0,043	0,043	0,044	0,041	0,041	0,041	0,040	0,044	0,041	0,041	0,040
23	0,072	0,133	0,091	0,068	0,058	0,045	0,058	0,079	0,093	0,100	0,103
24	0,043	0,041	0,039	0,039	0,038	0,040	0,040	0,040	0,040	0,040	0,037
25	0,119	0,130	0,092	0,063	0,056	0,044	0,052	0,070	0,081	0,087	0,093
26	0,043	0,041	0,041	0,039	0,040	0,039	0,040	0,039	0,039	0,038	0,038
27	0,048	0,048	0,043	0,044	0,042	0,048	0,050	0,055	0,061	0,066	0,068
28	0,044	0,044	0,041	0,040	0,041	0,041	0,040	0,041	0,039	0,040	0,039
29	0,094	0,137	0,097	0,059	0,056	0,049	0,045	0,061	0,070	0,072	0,079
30	0,039	0,040	0,037	0,035	0,036	0,037	0,036	0,037	0,037	0,037	0,036
31	0,055	0,137	0,094	0,050	0,050	0,040	0,040	0,056	0,065	0,070	0,076
32	0,042	0,040	0,042	0,041	0,040	0,039	0,040	0,039	0,039	0,038	0,038
33	0,044	0,044	0,040	0,044	0,043	0,043	0,045	0,051	0,054	0,056	0,055
34	0,039	0,039	0,039	0,040	0,039	0,039	0,039	0,039	0,038	0,037	0,038
35	0,080	0,114	0,082	0,058	0,055	0,051	0,044	0,050	0,057	0,063	0,070
36	0,036	0,037	0,036	0,036	0,036	0,036	0,036	0,035	0,037	0,037	0,034
37	0,082	0,084	0,065	0,049	0,046	0,049	0,043	0,049	0,053	0,054	0,055
38	0,043	0,042	0,042	0,042	0,042	0,043	0,042	0,042	0,042	0,041	0,041
39	0,042	0,041	0,040	0,041	0,038	0,040	0,041	0,041	0,042	0,043	0,042
40	0,043	0,043	0,041	0,041	0,043	0,043	0,042	0,042	0,041	0,042	0,040

Interharmonics : SOFAR 20000TL-G2											
P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
f [Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
75	0,265	0,329	0,384	0,421	0,448	0,468	0,485	0,519	0,528	0,544	0,566
125	0,181	0,304	0,394	0,433	0,456	0,466	0,470	0,476	0,472	0,473	0,478
175	0,137	0,244	0,343	0,413	0,439	0,448	0,451	0,462	0,472	0,474	0,477
225	0,104	0,210	0,276	0,330	0,373	0,388	0,394	0,409	0,421	0,435	0,443
275	0,096	0,144	0,207	0,246	0,254	0,264	0,280	0,294	0,291	0,285	0,289
325	0,081	0,096	0,156	0,183	0,189	0,186	0,191	0,197	0,203	0,210	0,226
375	0,073	0,073	0,130	0,147	0,139	0,128	0,128	0,131	0,126	0,121	0,119
425	0,076	0,075	0,107	0,113	0,106	0,096	0,093	0,098	0,099	0,100	0,105
475	0,064	0,074	0,083	0,082	0,075	0,071	0,073	0,077	0,081	0,083	0,082
525	0,064	0,078	0,074	0,070	0,067	0,068	0,071	0,075	0,079	0,082	0,086
575	0,063	0,067	0,065	0,065	0,067	0,069	0,070	0,072	0,070	0,069	0,070
625	0,065	0,072	0,062	0,057	0,059	0,061	0,060	0,060	0,059	0,058	0,061
675	0,065	0,065	0,061	0,059	0,061	0,061	0,060	0,059	0,058	0,057	0,056
725	0,063	0,065	0,060	0,060	0,060	0,057	0,058	0,057	0,056	0,054	0,054
775	0,063	0,062	0,061	0,062	0,062	0,057	0,057	0,056	0,054	0,054	0,052
825	0,058	0,059	0,057	0,057	0,055	0,052	0,051	0,051	0,050	0,050	0,050
875	0,061	0,061	0,058	0,055	0,055	0,055	0,055	0,056	0,055	0,054	0,052
925	0,056	0,056	0,057	0,056	0,054	0,052	0,053	0,054	0,054	0,051	0,052
975	0,055	0,057	0,057	0,052	0,052	0,053	0,055	0,053	0,052	0,052	0,050
1025	0,058	0,061	0,056	0,054	0,055	0,056	0,057	0,055	0,054	0,053	0,053
1075	0,060	0,061	0,058	0,057	0,058	0,058	0,059	0,056	0,054	0,054	0,053
1125	0,052	0,053	0,053	0,050	0,050	0,049	0,049	0,048	0,048	0,049	0,046
1175	0,057	0,056	0,053	0,052	0,053	0,053	0,051	0,051	0,050	0,050	0,049
1225	0,053	0,052	0,051	0,052	0,051	0,049	0,049	0,048	0,048	0,048	0,047
1275	0,056	0,054	0,054	0,052	0,052	0,051	0,051	0,053	0,057	0,061	0,060
1325	0,054	0,053	0,051	0,051	0,051	0,050	0,051	0,050	0,050	0,049	0,049
1375	0,054	0,055	0,053	0,052	0,051	0,054	0,053	0,053	0,052	0,053	0,050
1425	0,054	0,055	0,051	0,051	0,050	0,051	0,050	0,050	0,048	0,047	0,046
1475	0,052	0,053	0,052	0,053	0,050	0,049	0,047	0,047	0,047	0,046	0,046
1525	0,051	0,051	0,048	0,049	0,050	0,048	0,047	0,047	0,046	0,045	0,044
1575	0,053	0,052	0,050	0,049	0,050	0,049	0,050	0,049	0,049	0,048	0,048
1625	0,050	0,051	0,051	0,050	0,050	0,049	0,051	0,051	0,050	0,050	0,050
1675	0,054	0,055	0,051	0,051	0,053	0,054	0,053	0,053	0,052	0,051	0,050
1725	0,052	0,052	0,053	0,052	0,050	0,050	0,049	0,049	0,049	0,047	0,046
1775	0,050	0,052	0,052	0,049	0,048	0,049	0,049	0,049	0,050	0,049	0,047
1825	0,050	0,050	0,051	0,050	0,049	0,048	0,048	0,047	0,047	0,046	0,046
1875	0,055	0,053	0,051	0,051	0,051	0,051	0,051	0,051	0,051	0,050	0,050
1925	0,051	0,051	0,052	0,051	0,051	0,049	0,048	0,048	0,048	0,046	0,046
1975	0,053	0,053	0,052	0,052	0,051	0,051	0,051	0,052	0,051	0,051	0,052

**Higher Frequencies : SOFAR 20000TL-G2**

P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2,1	1,389	1,247	1,021	0,808	0,849	0,871	0,991	1,050	1,059	0,989	0,890
2,3	6,276	4,943	3,352	4,522	4,036	3,260	2,892	2,573	2,568	2,606	2,665
2,5	3,181	7,201	6,998	4,324	3,371	3,479	3,438	3,353	2,954	2,590	2,130
2,7	4,119	3,395	2,963	2,553	2,285	1,633	1,530	1,540	1,456	1,324	1,134
2,9	6,339	17,759	16,249	11,891	10,893	8,338	6,015	3,736	3,323	3,211	3,173
3,1	4,813	5,049	11,937	8,047	7,130	10,725	14,325	12,772	7,759	5,386	3,213
3,3	1,783	2,326	2,566	2,301	2,410	2,541	3,605	5,352	5,620	4,871	3,542
3,5	3,896	3,163	6,856	4,937	5,634	5,067	4,657	5,435	7,615	12,526	12,103
3,7	1,707	3,022	2,587	2,079	1,355	1,249	2,103	3,165	3,659	4,146	4,629
3,9	1,133	1,190	1,148	0,872	0,713	0,724	0,754	0,954	1,218	1,587	1,789
4,1	2,168	3,661	3,614	2,103	1,611	1,470	1,206	0,986	1,148	1,711	2,821
4,3	1,649	1,578	1,661	1,290	0,843	0,786	1,140	1,314	1,300	1,182	1,097
4,5	1,203	1,182	0,987	0,746	0,593	0,506	0,555	0,529	0,574	0,630	0,658
4,7	2,501	2,222	1,870	1,496	1,298	1,087	0,800	0,574	0,639	0,857	1,209
4,9	0,863	2,210	2,198	1,489	0,827	0,648	0,920	0,964	0,868	0,744	0,628
5,1	0,572	0,786	0,917	0,913	0,726	0,481	0,507	0,433	0,425	0,429	0,422
5,3	0,557	1,087	1,277	2,282	1,805	1,238	0,887	0,550	0,484	0,590	0,852
5,5	0,348	0,620	0,965	1,186	0,975	0,823	0,969	0,966	0,787	0,635	0,523
5,7	0,251	0,343	0,349	0,496	0,600	0,667	0,622	0,479	0,421	0,386	0,369
5,9	0,233	0,413	0,453	0,568	0,564	1,007	0,985	0,745	0,498	0,504	0,720
6,1	0,154	0,310	0,339	0,383	0,466	0,690	0,890	0,957	0,896	0,745	0,629
6,3	0,791	0,902	1,084	1,362	0,426	0,390	0,489	0,578	0,655	0,558	0,472
6,5	0,145	0,229	0,275	1,133	1,800	2,237	2,582	1,494	1,361	1,180	0,986
6,7	0,104	0,166	0,172	0,163	0,188	0,343	0,607	3,241	3,785	3,869	3,939
6,9	0,076	0,111	0,117	0,106	0,128	0,167	0,215	0,352	0,459	0,513	1,098
7,1	0,074	0,173	0,154	0,123	0,117	0,153	0,228	0,251	0,265	0,446	0,441
7,3	0,070	0,108	0,133	0,109	0,102	0,111	0,158	0,256	0,282	0,322	0,343
7,5	0,410	0,412	0,418	0,417	0,416	0,417	0,418	0,422	0,424	0,424	0,431
7,7	0,074	0,124	0,134	0,115	0,103	0,104	0,140	0,157	0,154	0,167	0,203
7,9	0,160	0,161	0,169	0,158	0,149	0,145	0,163	0,190	0,197	0,196	0,203
8,1	0,417	0,417	0,423	0,426	0,417	0,414	0,414	0,421	0,415	0,414	0,411
8,3	0,142	0,142	0,131	0,104	0,083	0,079	0,104	0,127	0,124	0,122	0,122
8,5	0,082	0,116	0,114	0,097	0,083	0,085	0,084	0,095	0,101	0,111	0,102
8,7	0,060	0,074	0,077	0,087	0,082	0,067	0,081	0,079	0,071	0,077	0,077
8,9	0,049	0,078	0,080	0,059	0,054	0,063	0,078	0,074	0,061	0,063	0,063

**Note:**

The normalization current is 28,99A for SOFAR 20000TL-G2  
The stated harmonics are maximum values of all 3 phases.

**5.2 Verification of the symmetry characteristics of three-phase inverter modules  
DIN VDE V 0124-100:2012-07**

<b>Clause</b>	<b>Test</b>	<b>Result</b>
5.2.1	General	<b>P</b>
5.2.2	Test in the test laboratory:	<b>P</b>
	5.2.2.1 Calculation of asymmetry	<b>P</b>
	5.2.2 Additional tests for communicatively coupled inverter modules	<b>N/A</b>
	5.2.2.1 Failure of individual inverter modules	<b>N/A</b>
	5.2.2.2 Power drop of individual inverter modules	<b>N/A</b>
5.2.3	Tests in the field	<b>N/A</b>

<b>5.2.1 General</b>	<b>P</b>
<p>These tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 5.5 and 5.6 are met.</p>	
<p>The phase angles are specified by the distribution network and so only the power symmetry is discussed.</p>	
<p><b>Note:</b></p>	

<b>5.2.2 Test in the test laboratory</b>	<b>P</b>
<p>Test Condition:</p>	<p>The measurements were performed in the testing laboratory. at the grid-simulator: <math>U_N =</math> between 86 % <math>U_n</math> and 109% <math>U_n</math> until the test Frequency: 50 Hz +/- 0,5%</p>
<p><b>Note:</b> If an examination is required for any other requirements, these apply to this test.</p>	



5.2.2.1 Calculation of asymmetry						P
Setting values	cos $\varphi$ = 1:			1,00		
	cos $\varphi$ over-excited:			0,80		
	cos $\varphi$ under-excited:			0,80		
<b>Test:</b>						
1-min mean value	L1	L2	L3	L1 – L2	L2 – L3	L3 – L1
a) cos $\varphi$ = 1 at 100 % $P_n \pm 5\% P_{E_{max}}$						
$S_{E60}$ [kVA]:	4,902	4,934	4,901	-0,032	0,033	0,000
	4,900	4,933	4,900	-0,033	0,033	0,000
	4,901	4,933	4,900	-0,032	0,033	-0,001
	4,900	4,933	4,900	-0,033	0,033	0,000
	4,900	4,932	4,900	-0,032	0,033	-0,001
COS $\varphi_{E60}$ :	0,995					
max. asymmetry [kVA]:	-0,033					
b) maximum under-excited (i) at 100 % $P_n \pm 5\% P_{E_{max}}$						
$S_{E60}$ [kVA]:	5,391	5,361	5,337	0,030	0,025	-0,055
	5,390	5,360	5,336	0,030	0,025	-0,054
	5,390	5,360	5,335	0,030	0,024	-0,054
	5,392	5,361	5,337	0,030	0,024	-0,054
	5,390	5,360	5,335	0,030	0,024	-0,054
	COS $\varphi_{E60}$ :	0,794				
max. asymmetry [kVA]:	-0,055					
c) maximum over-excited (c) at 100 % $P_n \pm 5\% P_{E_{max}}$						
$S_{E60}$ [kVA]:	5,452	5,484	5,485	-0,032	0,000	0,033
	5,451	5,483	5,484	-0,033	-0,001	0,033
	5,451	5,484	5,485	-0,033	-0,001	0,034
	5,452	5,485	5,486	-0,033	-0,001	0,034
	5,452	5,485	5,486	-0,033	-0,001	0,034
	COS $\varphi_{E60}$ :	0,796				
max. asymmetry [kVA]:	0,034					
d) cos $\varphi$ = 1 at 50 % $P_n \pm 5\% P_{E_{max}}$						
$S_{E60}$ [kVA]:	2,480	2,515	2,480	-0,035	0,035	0,000
	2,480	2,515	2,480	-0,035	0,035	0,000
	2,480	2,516	2,480	-0,036	0,036	0,000
	2,480	2,516	2,480	-0,036	0,036	0,000
	2,480	2,514	2,480	-0,034	0,034	0,000
	COS $\varphi_{E60}$ :	0,999				
max. asymmetry [kVA]:	0,036					

e) maximum under-excited (i) at 50 % P <sub>n</sub> ± 5 % P <sub>E<sub>max</sub></sub>						
S <sub>E60</sub> [kVA]:	3,107	3,146	3,107	-0,039	0,039	0,000
	3,105	3,144	3,105	-0,039	0,039	0,000
	3,106	3,145	3,106	-0,039	0,039	0,000
	3,106	3,144	3,106	-0,039	0,039	0,000
	3,105	3,145	3,105	-0,040	0,040	0,000
COS φ <sub>E60</sub> :	0,791					
max. asymmetry [kVA]:	0,040					
f) maximum over-excited (c) at 50 % P <sub>n</sub> ± 5 % P <sub>E<sub>max</sub></sub>						
S <sub>E60</sub> [kVA]:	3,050	3,092	3,050	-0,042	0,042	0,000
	3,047	3,089	3,047	-0,042	0,042	0,000
	3,047	3,089	3,047	-0,042	0,042	0,000
	3,046	3,089	3,046	-0,042	0,042	0,000
	3,046	3,088	3,046	-0,042	0,042	0,000
COS φ <sub>E60</sub> :	0,808					
max. asymmetry [kVA]:	0,042					
<b>Limit [kVA]:</b>	<b>≤ 5 % S<sub>E<sub>max</sub></sub> and 4,6 kVA</b>					
<b>Test:</b> The maximum absolute difference between the apparent powers of the three phases is determined for each of the five measurements (1-min means) in the respective operating point. The maximum of these five values is again determined.						
<b>Assessment criterion:</b> The test is passed if the maximum value from the above measurements does not exceed 5 % S <sub>E<sub>max</sub></sub> and 4,6 kVA.						
<b>Note:</b> The maximum inductive and capacitive values are specified by the manufacturer.  The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.						

### 5.3 Verification of the characteristics of the power generation unit on the network DIN VDE V 0124-100:2012-07

Clause	Test	Result
5.3.1	General	P
5.3.2	Measurement of the active reactive power range	P
5.3.3	Active power reduction by specifying setpoints	P
	5.3.3.1 Setpoint control	P
	5.3.3.2 Measurement of setting accuracy	P
	5.3.3.3 Measurement of setting time	P
5.3.4	Active power feed-in for overfrequency	P
	5.3.4.1.1 Test cycle for adjustable/conditionally adjustable PGUs	P
	5.3.4.1.2 Test cycle for all PGUs (adjustable, conditionally adjustable and non-adjustable PGUs)	P
5.3.5	Active power feed-in for underfrequency	P
5.3.6	Reactive power output	P
	5.3.6.1 Tests of the $\cos \varphi$ setting accuracy	P
	5.3.6.4 Test for a displacement factor/ active power characteristic curve $\cos \varphi$ (P)	P

<b>5.3.1 General</b> (these tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 5.7 are met)		<b>P</b>
Test Condition:	The measurements were performed in the testing laboratory. at the grid-simulator: $U_N = \text{between } 86 \% U_n \text{ and } 109\% U_n \text{ until the test}$ Frequency: 50 Hz +/- 0,5%	
<b>Note:</b> If an examination is required for any other requirements, these apply to this test.		

5.3.2 Measurement of the active power and reactive power range (these tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 5.7.5 are met)		P
Setting values	cos $\varphi = 1$ :	1,00
	cos $\varphi$ max. over-excited:	0,80
	cos $\varphi$ max. under-excited:	0,80
<b>Test: SOFAR 33000TL-G2</b>		
600 s mean value	$U_n$	$1,09 U_n$
a) cos $\varphi$ 1 at 100% $P_{E_{max}}$		
U [V]:	230,14	250,82
$P_{E_{max}600 \text{ a)}$ [kW]	33,060	33,010
$S_{E_{max}600 \text{ a)}$ [kVa]	33,066	33,016
cos $\varphi_{E_{max}600}$	0,999	0,999
b) maximum under-excited (i) at 100% $P_{E_{max}}$		
U [V]:	229,95	250,78
$P_{E_{max}600 \text{ b)}$ [kW]	29,763	29,715
$S_{E_{max}600 \text{ b)}$ [kVa]	36,933	36,863
cos $\varphi_{E_{max}600\text{-under-excited}}$	0,806	0,806
c) maximum over-excited (c) at 100% $P_{E_{max}}$		
U [V]:	229,95	250,71
$P_{E_{max}600 \text{ c)}$ [kW]	29,763	29,080
$S_{E_{max}600 \text{ c)}$ [kVa]	36,933	36,179
cos $\varphi_{E_{max}600\text{-over-excited}}$	0,806	0,804
d) maximum under-excited (i) at 20-30% $P_{E_{max}}$		
U [V]:	230,04	250,72
$P_{E_{max}60 \text{ d)}$ [kW]	8,243	8,265
$S_{E_{max}60 \text{ d)}$ [kVa]	10,252	10,289
cos $\varphi_{E_{max}60\text{-over-excited}}$	0,804	0,803
e) maximum over-excited (c) at 20-30% $P_{E_{max}}$		
U [V]:	229,61	250,72
$P_{E_{max}60 \text{ e)}$ [kW]	8,254	8,262
$S_{E_{max}60 \text{ e)}$ [kVa]	10,207	10,203
cos $\varphi_{E_{max}60\text{-over-excited}}$	0,809	0,809
$S_{E_{max}600}$ and $P_{E_{max}600}$		
$S_{E_{max}600} = \max(S_{E_{max}600 \text{ a)}, S_{E_{max}600 \text{ b)}, S_{E_{max}600 \text{ c)})$ [kVa]		36,933
$P_{E_{max}600} = \max(P_{E_{max}600 \text{ a)}, P_{E_{max}600 \text{ b)}, P_{E_{max}600 \text{ c)})$ [kW]		33,060

<b>Test: SOFAR 3000TL-G2</b>		
600 s mean value	$U_n$	1,09 $U_n$
<b>a) <math>\cos \varphi</math> 1 at 100% <math>P_{E_{max}}</math></b>		
U [V]:	229,90	250,75
$P_{E_{max}600 \text{ a)}$ [kW]	33,029	30,076
$S_{E_{max}600 \text{ a)}$ [kVa]	33,039	30,086
$\cos \varphi_{E_{max}600}$	0,999	0,999
<b>b) maximum under-excited (i) at 100% <math>P_{E_{max}}</math></b>		
U [V]:	230,27	250,72
$P_{E_{max}600 \text{ b)}$ [kW]	29,496	29,137
$S_{E_{max}600 \text{ b)}$ [kVa]	36,858	36,239
$\cos \varphi_{E_{max}600\text{-under-excited}}$	0,800	0,804
<b>c) maximum over-excited (c) at 100% <math>P_{E_{max}}</math></b>		
U [V]:	230,01	250,80
$P_{E_{max}600 \text{ c)}$ [kW]	29,253	29,406
$S_{E_{max}600 \text{ c)}$ [kVa]	36,393	36,735
$\cos \varphi_{E_{max}600\text{-over-excited}}$	0,804	0,801
<b>d) maximum under-excited (i) at 20-30% <math>P_{E_{max}}</math></b>		
U [V]:	230,12	250,87
$P_{E_{max}60 \text{ d)}$ [kW]	7,476	7,490
$S_{E_{max}60 \text{ d)}$ [kVa]	9,375	9,403
$\cos \varphi_{E_{max}60\text{-over-excited}}$	0,797	0,797
<b>e) maximum over-excited (c) at 20-30% <math>P_{E_{max}}</math></b>		
U [V]:	229,76	250,72
$P_{E_{max}60 \text{ e)}$ [kW]	7,505	7,516
$S_{E_{max}60 \text{ e)}$ [kVa]	9,272	9,427
$\cos \varphi_{E_{max}60\text{-over-excited}}$	0,809	0,797
<b><math>S_{E_{max}600}</math> and <math>P_{E_{max}600}</math></b>		
$S_{E_{max}600} = \max(S_{E_{max}600 \text{ a)}, S_{E_{max}600 \text{ b)}, S_{E_{max}600 \text{ c)})}$ [kVa]		36,858
$P_{E_{max}600} = \max(P_{E_{max}600 \text{ a)}, P_{E_{max}600 \text{ b)}, P_{E_{max}600 \text{ c)})}$ [kW]		30,076

<b>Test: SOFAR 25000TL-G2</b>		
600 s mean value	$U_n$	1,09 $U_n$
<b>a) <math>\cos \varphi</math> 1 at 100% <math>P_{E_{max}}</math></b>		
U [V]:	229,91	250,80
$P_{E_{max}600 \text{ a)}$ [kW]	25,020	25,045
$S_{E_{max}600 \text{ a)}$ [kVa]	25,030	25,057
$\cos \varphi_{E_{max}600}$	0,999	0,999
<b>b) maximum under-excited (i) at 100% <math>P_{E_{max}}</math></b>		
U [V]:	230,21	250,86
$P_{E_{max}600 \text{ b)}$ [kW]	25,022	24,977
$S_{E_{max}600 \text{ b)}$ [kVa]	31,256	31,204
$\cos \varphi_{E_{max}600\text{-under-excited}}$	0,801	0,800
<b>c) maximum over-excited (c) at 100% <math>P_{E_{max}}</math></b>		
U [V]:	229,66	250,74
$P_{E_{max}600 \text{ c)}$ [kW]	25,069	25,027
$S_{E_{max}600 \text{ c)}$ [kVa]	31,190	31,099
$\cos \varphi_{E_{max}600\text{-over-excited}}$	0,804	0,805
<b>d) maximum under-excited (i) at 20-30% <math>P_{E_{max}}</math></b>		
U [V]:	230,11	250,77
$P_{E_{max}60 \text{ d)}$ [kW]	6,259	6,244
$S_{E_{max}60 \text{ d)}$ [kVa]	7,859	7,853
$\cos \varphi_{E_{max}60\text{-over-excited}}$	0,796	0,795
<b>e) maximum over-excited (c) at 20-30% <math>P_{E_{max}}</math></b>		
U [V]:	230,00	250,72
$P_{E_{max}60 \text{ e)}$ [kW]	6,246	6,249
$S_{E_{max}60 \text{ e)}$ [kVa]	7,828	7,821
$\cos \varphi_{E_{max}60\text{-over-excited}}$	0,798	0,799
<b><math>S_{E_{max}600}</math> and <math>P_{E_{max}600}</math></b>		
$S_{E_{max}600} = \max(S_{E_{max}600 \text{ a)}, S_{E_{max}600 \text{ b)}, S_{E_{max}600 \text{ c)})$ [kVa]		31,256
$P_{E_{max}600} = \max(P_{E_{max}600 \text{ a)}, P_{E_{max}600 \text{ b)}, P_{E_{max}600 \text{ c)})$ [kW]		25,045

<b>Test: SOFAR 20000TL-G2</b>		
600 s mean value	$U_n$	1,09 $U_n$
<b>a) <math>\cos \varphi</math> 1 at 100% <math>P_{E_{max}}</math></b>		
U [V]:	230,09	250,78
$P_{E_{max}600 \text{ a)}$ [kW]	20,020	20,045
$S_{E_{max}600 \text{ a)}$ [kVa]	20,025	20,050
$\cos \varphi_{E_{max}600}$	1,000	1,000
<b>b) maximum under-excited (i) at 100% <math>P_{E_{max}}</math></b>		
U [V]:	230,06	250,76
$P_{E_{max}600 \text{ b)}$ [kW]	17,864	17,831
$S_{E_{max}600 \text{ b)}$ [kVa]	22,345	22,305
$\cos \varphi_{E_{max}600\text{-under-excited}}$	0,799	0,799
<b>c) maximum over-excited (c) at 100% <math>P_{E_{max}}</math></b>		
U [V]:	230,08	250,79
$P_{E_{max}600 \text{ c)}$ [kW]	17,784	17,764
$S_{E_{max}600 \text{ c)}$ [kVa]	22,069	22,036
$\cos \varphi_{E_{max}600\text{-over-excited}}$	0,806	0,806
<b>d) maximum under-excited (i) at 20-30% <math>P_{E_{max}}</math></b>		
U [V]:	230,03	250,72
$P_{E_{max}60 \text{ d)}$ [kW]	4,987	4,999
$S_{E_{max}60 \text{ d)}$ [kVa]	6,270	6,296
$\cos \varphi_{E_{max}60\text{-over-excited}}$	0,795	0,794
<b>e) maximum over-excited (c) at 20-30% <math>P_{E_{max}}</math></b>		
U [V]:	230,01	250,71
$P_{E_{max}60 \text{ e)}$ [kW]	5,026	5,026
$S_{E_{max}60 \text{ e)}$ [kVa]	6,291	6,288
$\cos \varphi_{E_{max}60\text{-over-excited}}$	0,799	0,799
<b><math>S_{E_{max}600}</math> and <math>P_{E_{max}600}</math></b>		
$S_{E_{max}600} = \max(S_{E_{max}600 \text{ a)}, S_{E_{max}600 \text{ b)}, S_{E_{max}600 \text{ c)})}$ [kVa]		22,345
$P_{E_{max}600} = \max(P_{E_{max}600 \text{ a)}, P_{E_{max}600 \text{ b)}, P_{E_{max}600 \text{ c)})}$ [kW]		20,045



**Test:**

The PGU is operated in all of the following, possible operating points. Every operating point must be retained for at least 600s after the transient effect has faded. During the measurements, there may be no power limitation by the primary energy source.

- a) For  $\cos \varphi$ , the maximum active power possible in this range is set.
- b) For maximum under-excited operation, the maximum active power possible in this operating point is set
- c) For maximum over-excited operation, the maximum active power possible in this operating point is set.
- d) For maximum under-excited operation, the power set to 20-30%  $P_{E_{max}}$ .
- e) For maximum over-excited operation, the power set to 20-30%  $P_{E_{max}}$ .

The operating points d) and e) must be retained for at least 60 s.

**Assessment criterion:**

$S_{E_{max600}}$  and  $P_{E_{max600}}$  are determined by the highest value measured.

$$S_{E_{max600}} = \max(S_{E_{max600a)}, S_{E_{max600b)}, S_{E_{max600c)})$$

$$P_{E_{max600}} = \max(P_{E_{max600a)}, P_{E_{max600b)}, P_{E_{max600c)})$$

**Note:**

The maximum settable  $\cos \varphi$  must be set.

No specification:	PGU $\leq 3,68$ kVA not in PGS $> 3,68$ kVA
$\varphi 0,95$ (i) and (c):	PGU $> 3,68$ kVA and $\leq 13,8$ kVA not in PGS $> 13,8$ kVA and for PGU $\leq 3,68$ kVA also in PGS $\leq 13,8$ kVA
$\varphi 0,90$ (i) and (c):	PGU $> 13,8$ kVA and for PGU $\leq 13,8$ kVA also in PGS $> 13,8$ kVA

### 5.3.3 Active power reduction by specifying setpoints

P

The following tests apply for PGUs >100 kW and PGSs that, according to the manufacturers, can participate in feed-in management / network security management.

**Note:**

The EEC also stipulates this test for PGUs with lower power ratings.

#### 5.3.3.1 Setpoint control

P

The following procedure must be used for the setpoint control test for the active power:

- a) The test must be conducted with a chronologically coherent test procedure;
- b) The available active power output must be at least 90%  $P_{Emax}$  during the entire duration of the test
- c) The active power must be measured at the three-phase/AC current connector of the PGU
- d) If the PGU has several different interfaces for setpoint specification, the interface returning the most unfavourable results must be tested.

### Communications Port Description

This topic describes the functions of the RS485 and WIFI ports.

#### RS485

By RS485 interface, transfer the inverter power output information, alarm information, operation state to the PC terminal or local data acquisition device, then uploaded to the server (such as S-WE01S).

**1. USB-RS485**



**2. S-WE01S**




Set the match resistor by the SWT2, the corresponding list as follows (0 OFF, 1 ON).

SWT2_1	SWT2_2	State
0	Reserve	No connect
1	Reserve	Connect


If only one Sofar 20~33KTL-G2 is used, use a communication cable with waterproof RJ45 connectors, and choose either of the two RS485 ports.

Figure 4-16 A single Sofar 20~33KTL-G2 connecting Communications



If multiple Sofar 20~33KTL-G2 are used, connect all Sofar 20~33KTL-G2 in daisy chain mode over the RS485 communication cable. Set different Modbus address(1~31) for each inverter in LCD display and set SWT2(match resistance) at the first and last inverter.

Figure 4-18 Multi Sofar 20~33KTL-G2 connecting Communications




Register remote monitoring of Sofar 20~33KTL-G2 at its relevant website or APP according to monitoring device SN.

### WIFI

By the WIFI interface, transfer the inverter power output information, alarm information, operation state to the PC terminal or local data acquisition device, then uploaded to the server (such as S-WE015).

Register remote monitoring of Sofar 20~33KTL-G2 at its relevant website or APP according to monitoring device SN.

Figure 4-19 Connect multiple Wifi to wireless router




### Note:

See 5.3.3.2 for measurements.

### 5.3.3.2 Measurement of setting accuracy

P

#### Graph of the setting accuracy:



#### Test:

1-min mean value / P <sub>n</sub> /P [%]	100	90	80	70	60	50	40	30	20	10
P <sub>Setpoint</sub> [kW]:	33,000	29,700	26,400	23,100	19,800	16,500	13,200	9,900	6,600	3,300
P <sub>E60</sub> [kW]:	32,987	29,554	26,346	22,623	19,695	15,799	12,224	9,064	6,051	3,298
ΔP <sub>E60</sub> /P <sub>Setpoint</sub> [%]:	-0,040	-0,442	-0,164	-1,446	-0,318	-2,123	-2,957	-2,534	-1,665	-0,006
Limit ΔP <sub>E60</sub> /P <sub>Setpoint</sub> :	+ 5 % of P <sub>Emax</sub>									

#### Test:

The setpoint signal must be reduced from 100% to 10% P<sub>Emax</sub>:

- for adjustable PGUs in increments of 10% P<sub>Emax</sub>. 1 minute must elapse after every change to the setpoint setting so that the PGU can settle at the new setpoint. Then the active power of the PGU must be measured as a 1-min mean value.
- For all other PGUs, in line with their adjustable steps. 5 minutes must elapse after the setpoint setting is changed so that the PGU can settle at the new setpoint. Then the active power of the PGU must be measured as a 1-min mean value.

**Assessment criterion:**

a) for adjustable PGUs:

- no network disconnection
- the active power value does not exceed the setpoint by more than 5%  $P_{E_{max}}$
- the setting time determined this way is  $\leq 1$ min

b) For all other PGUs:

- the active power value does not exceed the setpoint by more than 5%  $P_{E_{max}}$  or
- the setpoint is fallen below within 5 minutes or the PGU has switched off

**Note:**


The setting time is  $\leq 1$ min. See below "Graph of the setting accuracy".

The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.

### 5.3.3.3 Measurement of setting time

P

#### Graph of the adjustment time:



#### Test:

1-min mean value	100% of $P_{E_{max}}$	30% of $P_{E_{max}}$
$P_{Setpoint}$ [kW]:	33,000	9,900
$P_{E60}$ [kW]:	33,042	9,907
$\Delta P_{E60}/P_{Setpoint}$ [%]:	0,127	0,021
<b>Limit <math>\Delta P_{E60}/P_{Setpoint}</math>:</b>	+ 5 % of $P_{E_{max}}$	
$T_0$ [s]:	2s	
<b>Limit <math>T_0</math>:</b>	$\leq 60$ s	

#### Test:

The setting time is measured with a setpoint change from 100% to 30% of nominal active power  $P_{E_{max}}$  at time  $t_0$ . The setting time of the PGU must be determined in this test.

#### Assessment criterion:

a) for adjustable PGUs:

- no network disconnection
- the active power value does not exceed the setpoint by more than 5%  $P_{E_{max}}$
- the setting time determined this way is  $\leq 1$ min

b) For all other PGUs:

- the active power value does not exceed the setpoint by more than 5%  $P_{E_{max}}$  or
- the setpoint is fallen below within 5 minutes or the PGU has switched off

#### Note:

The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.

### 5.3.4 Active power feed-in for overfrequency

(these tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 5.7.3.3 are met)

#### 5.3.4.1.1 Test cycle for adjustable/conditionally adjustable PGUs

P

#### Test:

1-min mean value    a) 50,00 Hz    b) 50,25 Hz    c) 50,70 Hz    d) 51,15 Hz    e) 50,70 Hz    f) 50,25 Hz    g) 50,00 Hz

1. Measurement a) to g): Active power output > 80% P<sub>E<sub>max</sub></sub>


Frequency [Hz]:	50,00	50,25	50,70	51,15	50,70	50,25	50,00
P <sub>setpoint</sub> [kW]:	N/A	32,355	26,412	20,502	26,407	32,355	N/A
P <sub>E60</sub> [kW]:	33,013	32,602	26,629	20,698	26,599	32,599	33,015
$\Delta P_{E60}/P_{Setpoint}$ [%]:	N/A	0,749	0,659	0,594	0,580	0,742	N/A

2. Measurement a) to g): Active power output 40% and 60% after freezing > 80% P<sub>E<sub>max</sub></sub>


Frequency [Hz]:	50,00	50,25	50,70	51,15	50,70	50,25	N/A
P <sub>setpoint</sub> [kW]:	N/A	16,216	13,235	10,258	13,234	16,215	N/A
P <sub>E60</sub> [kW]:	16,545	16,312	13,325	10,361	13,329	16,325	N/A
$\Delta P_{E60}/P_{Setpoint}$ [%]:	N/A	0,293	0,274	0,314	0,286	0,332	N/A

Limit  $\Delta P_{E60}/P_{Setpoint}$ : + 10 % of P<sub>E<sub>max</sub></sub>


#### Graph of Measurement 1.: Active power output > 80% P<sub>E<sub>max</sub></sub>



**Graph of Measurement 2.:Active power output 40% and 60% after freezing > 80% P<sub>E</sub>max**



**Graph of power gradient:**





**Test:**

The test is conducted for two powers. First, the test must start at a power  $> 80\% P_{E_{max}}$  ("Measurement 1"), and in a second test, for a power between  $40\%$  to  $60\% P_{E_{max}}$  ("Measurement 2"). In the second test, after freezing of the PM, the available active power output must be increased to a value  $> 80\% P_{E_{max}}$ , and after the network frequency of  $50,2$  Hz is fallen below, the rise of the active power gradient must be recorded.

Point g) must be held until the PGU is again feeding in with the active power output available.

**Assessment criterion:**

For  $f=50,2$  Hz, the value of the PM active power currently being generated is "frozen".

a) For adjustable PGUs when:

- 1) the active power reduces between measuring points b) and f) given above with a gradient of  $40\%$  PM per Hz for a decreasing frequency (or rises for a frequency decreasing again).
- 2) the maximum active power gradient occurring in point g) is lower than  $10\%$  of maximum active power  $P_{E_{max}}$  every minute, and
- 3) the reaction value of the setpoint determined by the gradient characteristic curve does not differ from  $P_{E_{max}}$  by more than  $\pm 10\%$ .

b) For conditionally adjustable PGUs

- 1) when they behave as in a) within their adjustment range, and
- 2) when, outside the adjustable range, the power fed in on leaving the adjustment range remains constant until shutdown. Shutdown must be no later than at  $51,5$  Hz.

The PGU must have disconnected from the network no later than  $200\text{ms}$  after frequency h) is reached.


**Note:**

The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.

5.3.4.1.2 Test cycle for all PGUs (adjustable, conditionally adjustable and non-adjustable)

P

Graph of frequency g) to j):



Test:

1-min mean value	g) $50,00 \pm 0,01$ Hz	h) $51,65 \pm 0,05$ Hz	i) $50,06$ Hz $\pm 0,01$ Hz	j) $50,00$ Hz $\pm 0,01$ Hz
------------------	------------------------	------------------------	-----------------------------	-----------------------------

1) g)  $50,00 \pm 0,01$  Hz to h)  $51,65 \pm 0,05$  Hz

Disconnection time [ms]:	156	Limit [ms]:	200
--------------------------	-----	-------------	-----

Test:

Following tests a) to g), frequency h)  $51,65$  Hz  $\pm 0,05$  Hz must be set for at least 200ms. Afterwards, frequency i)  $50,06$  Hz  $\pm 0,01$  Hz is enabled and kept for at least 3 minutes.

Afterwards, frequency j)  $50,00$  Hz  $\pm 0,01$  Hz is enabled and kept until transient oscillation of the active power at the earliest.

**Assessment criterion:**

The PGU must have disconnected from the network no later than 200ms after frequency h) is reached. Thereafter, also whilst frequency i) is being held, there may be no resynchronisation or active power feed-in, i.e. not on the characteristic curve as tested before in a) to g).

a) For adjustable PGUs when:

ab) the maximum active power gradient occurring in point j) is lower than 10% of maximum active power  $P_{E_{max}}$  every minute, and

ac) the reaction value of the setpoint determined by the gradient characteristic curve does not differ from  $P_{E_{max}}$  by more than  $\pm 10\%$ .

b) For conditionally adjustable PGUs

ba) when they behave as in a) within their adjustment range, and

bb) when, outside the adjustable range, the power fed in on leaving the adjustment range remains constant until shutdown. Shutdown must be no later than at 51,5 Hz.


**Note:**

The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.

**5.3.5 Active power feed-in for underfrequency**

**P**

Graph of frequency a) to b):



**Test:**

	Switch to:	
1-min mean value	a) $50 \pm 0,01$ [Hz]	b) - 2,4 to - 2,5 [Hz]
Frequency [Hz]:	50,00	47,60
$P_{E60}$ [kW]:	33,026	32,996
$\Delta P_{a)/P_b)$ [%]:	-0,089	

**Test:**

Operating point b) must be kept for at least 1 minute.

The test must be carried out at 100%  $P_{E_{max}}$ .

With a programmable AC source, the PGU is operated at 100%  $P_{E_{max}}$  and  $50 \pm 0,01$  Hz, thereafter the frequency is reduced by 1 Hz/min. to - 2,4 to - 2,5 Hz. A 1-min mean value is recorded both before and after the frequency change.

**Assessment criterion:**

The test is passed when the PGU does not disconnect from the network on a network frequency change and continues to feed in 100%  $P_{E_{max}}$ .

**Note:**

The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.

### 5.3.6 Reactive power output

(these tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 5.7.5 are met)

The PGU has:

- passed for use for the adjustable  $\cos \varphi$  range
- not passed for use for the adjustable  $\cos \varphi$  range
- limitations for use in PGs  $> 3,68 \text{ kVA}$  or  $\leq 13,8 \text{ kVA}$

#### 5.3.6.1 Tests of the $\cos \varphi$ setting accuracy

**P**

Setting values	cos $\varphi$ over-excited:	0,80
	cos $\varphi$ under-excited:	0,80

#### d) and e) PGUs used in PGs $> 13,8 \text{ kVA}$

##### Test: SOFAR 33000TL-G2

30 s mean value	$U_n$			$1,09 U_n$		
Active power	$S_{E_{max}}$	40 – 60 % $P_{E_{max}}$		$S_{E_{max}}$	40 – 60 % $P_{E_{max}}$	

##### d) cos $\varphi$ 0,8 over-excited

U [V]:	230,08	229,93	250,71	250,73
$P_{E30}$ [kW]:	29,331	16,583	29,361	16,556
$Q_{E30}$ [kVar]:	21,967	12,400	21,963	12,409
cos $\varphi_{E30}$ -over-excited:	0,801	0,801	0,801	0,800

##### e) cos $\varphi$ 0,8 under-excited

U [V]:	230,12	230,05	250,82	250,77
$P_{r30}$ [kW]:	29,240	16,495	29,123	16,517
$Q_{E30}$ [kVar].	-21,891	-12,314	-21,824	-12,326
cos $\varphi_{E30}$ -under-excited:	0,800	0,801	0,800	0,801

##### Limit cos $\varphi_{E30}$ :


cos  $\varphi = 0,79$  to  $0,81$  (c) and cos  $\varphi = 0,79$  to  $0,81$  (i)

$P_n/P$ [%]	10	20	30	40	50	60	70	80	80	80
-------------	----	----	----	----	----	----	----	----	----	----


30 s mean value	cos $\varphi$ over-excited (c) @ $U_n$									
U [V]:	N/A	230,04	230,03	229,98	229,93	229,91	229,94	230,00	230,08	230,08
$P_{E30}$ [kW]:	N/A	6,605	9,940	13,268	16,583	20,002	23,096	26,434	29,377	29,331
$Q_{E30}$ [kVar]:	N/A	4,996	7,474	9,948	12,400	14,991	17,300	19,799	21,999	21,967
cos $\varphi_{E30}$ -over-excited:	N/A	0,798	0,799	0,800	0,801	0,801	0,801	0,801	0,801	0,801
	cos $\varphi$ over-excited (c) @ $U_{1,09}$									
U [V]:	N/A	250,71	250,72	250,72	250,73	250,70	250,70	250,71	250,72	250,71
$P_{r30}$ [kW]:	N/A	6,605	10,019	13,242	16,556	19,856	23,141	26,413	29,460	29,361
$Q_{E30}$ [kVar]:	N/A	5,013	7,547	9,943	12,409	14,866	17,322	19,758	22,035	21,963
cos $\varphi_{E30}$ -over-excited:	N/A	0,797	0,799	0,800	0,800	0,800	0,801	0,801	0,801	0,801

30 s mean value	cos $\phi$ under-excited (i) @ $U_n$									
U [V]:	N/A	230,03	230,06	230,08	230,05	230,09	230,12	230,11	230,11	230,12
$P_{E30}$ [kW]:	N/A	6,592	9,039	13,208	16,495	18,485	23,034	27,297	29,444	29,240
$Q_{E30}$ [kVAr]:	N/A	-4,993	-6,819	-9,822	-12,314	-13,790	-17,268	-20,440	-21,851	-21,891
cos $\phi_{E30}$ -under-excited:	N/A	0,797	0,798	0,802	0,801	0,801	0,800	0,800	0,803	0,800
	cos $\phi$ under-excited (i) @ $U_{1,09}$									
U [V]:	N/A	250,70	250,86	250,73	250,77	250,80	250,80	250,80	250,81	250,82
$P_{E30}$ [kW]:	N/A	6,590	9,910	13,219	16,517	19,515	23,073	26,331	29,124	29,123
$Q_{E30}$ [kVAr]:	N/A	-4,962	-7,442	-9,809	-12,326	-14,557	-17,289	-19,780	-22,082	-21,824
cos $\phi_{E30}$ -under-excited:	N/A	0,799	0,800	0,803	0,801	0,802	0,800	0,800	0,797	0,800
<b>Limit cos <math>\phi_{E30}</math>:</b>	cos $\phi$ = 0,79 to 0,81 (c) and cos $\phi$ = 0,79 to 0,81 (i)									

Graph of  $\cos \phi$  over-excited (c) and under-excited (i) @  $U_n$ : SOFAR 33000TL-G2




Graph of  $\cos \phi$  over-excited (c) and under-excited (i) @  $U_{1.09}$ : SOFAR 33000TL-G2




Test: SOFAR 20000TL-G2										
30 s mean value	U <sub>n</sub>					1,09 U <sub>n</sub>				
Active power	S <sub>E<sub>max</sub></sub>		40 – 60 %P <sub>E<sub>max</sub></sub>			S <sub>E<sub>max</sub></sub>		40 – 60 %P <sub>E<sub>max</sub></sub>		
d) cos φ 0,8 over-excited										
U [V]:	230,06		230,04			251,15		250,71		
P <sub>E30</sub> [kW]:	17,851		10,021			17,856		10,058		
Q <sub>E30</sub> [kVAr]:	13,384		7,541			13,311		7,417		
COS φ <sub>E30-over-excited</sub> :	0,800		0,799			0,802		0,805		
e) cos φ 0,8 under-excited										
U [V]:	230,32		230,08			250,76		250,73		
P <sub>n30</sub> [kW]:	17,884		10,049			17,667		10,024		
Q <sub>E30</sub> [kVAr].	-13,300		-7,432			-13,259		-7,559		
COS φ <sub>E30-under-excited</sub> :	0,802		0,804			0,800		0,798		
<b>Limit cos φ<sub>E30</sub>:</b>	cos φ= 0,79 to 0,81 (c) and cos φ= 0,79 to 0,81 (i)									
P <sub>n</sub> /P [%]	10	20	30	40	50	60	70	80	90	100
30 s mean value	cos φ over-excited (c) @ U <sub>n</sub>									
U [V]:	N/A	230,01	230,02	230,02	230,04	230,02	230,05	230,05	230,06	230,06
P <sub>E30</sub> [kW]:	N/A	4,037	6,045	8,036	10,021	12,027	14,032	16,032	17,851	17,851
Q <sub>E30</sub> [kVAr]:	N/A	3,083	4,578	6,061	7,541	9,042	10,539	12,025	13,385	13,384
COS φ <sub>E30-over-excited</sub> :	N/A	0,795	0,797	0,798	0,799	0,799	0,800	0,800	0,800	0,800
	cos φ over-excited (c) @ U <sub>1,09</sub>									
U [V]:	N/A	250,71	250,74	250,76	250,71	250,74	250,77	251,11	251,15	251,15
P <sub>n30</sub> [kW]:	N/A	3,987	6,015	8,036	10,058	12,071	14,081	16,436	17,849	17,856
Q <sub>E30</sub> [kVAr]:	N/A	2,997	4,520	6,097	7,417	8,940	10,464	12,254	13,326	13,311
COS φ <sub>E30-over-excited</sub> :	N/A	0,799	0,799	0,797	0,805	0,804	0,803	0,802	0,801	0,802
30 s mean value	cos φ under-excited (i) @ U <sub>n</sub>									
U [V]:	N/A	230,00	230,05	230,04	230,08	230,10	230,05	230,11	230,32	230,32
P <sub>E30</sub> [kW]:	N/A	3,999	6,043	8,069	10,049	12,060	14,065	16,064	17,884	17,884
Q <sub>E30</sub> [kVAr]:	N/A	-3,008	-4,557	-6,149	-7,432	-8,950	-10,464	-11,976	-13,301	-13,300
COS φ <sub>E30-under-excited</sub> :	N/A	0,799	0,798	0,795	0,804	0,803	0,802	0,802	0,802	0,802
	cos φ under-excited (i) @ U <sub>1,09</sub>									
U [V]:	N/A	250,72	250,72	250,72	250,73	250,74	250,75	250,74	250,74	250,76
P <sub>E30</sub> [kW]:	N/A	3,954	5,982	8,004	10,024	12,035	14,047	16,048	17,880	17,667
Q <sub>E30</sub> [kVAr]:	N/A	-3,039	-4,549	-6,055	-7,559	-9,061	-10,564	-12,052	-13,414	-13,259
COS φ <sub>E30-under-excited</sub> :	N/A	0,793	0,796	0,798	0,798	0,799	0,799	0,800	0,800	0,800
<b>Limit cos φ<sub>E30</sub>:</b>	cos φ= 0,79 to 0,81 (c) and cos φ= 0,79 to 0,81 (i)									



Graph of cos  $\phi$  over-excited (c) and under-excited (i) @  $U_n$ : SOFAR 20000TL-G2



Graph of cos  $\phi$  over-excited (c) and under-excited (i) @  $U_{1.09}$ : SOFAR 20000TL-G2



**Test:**

- a) With no specification of  $\cos \varphi$ , the active power must be adjust between 40 %  $P_{E_{max}}$  and 60 %  $P_{E_{max}}$  and to  $S_{E_{max}}$
- b) & c) For  $\cos \varphi$  0,95 over-excited and  $\varphi$  0,95 under-excited, the active power must be adjust between 40 %  $P_{E_{max}}$  and 60 %  $P_{E_{max}}$  and to  $S_{E_{max}}$
- d) & e) For  $\cos \varphi$  0,90 over-excited and  $\varphi$  0,90 under-excited, the active power must be adjust between 40 %  $P_{E_{max}}$  and 60 %  $P_{E_{max}}$  and to  $S_{E_{max}}$

For measurements a) to c), there may be no power limitation by the primary energy source.

**Assessment criterion:**


- a) Applicable for PGUs  $\leq 3,68$  kVA that cannot be used in PGSs  $> 3,68$  kVA:  
The test is passed when all operating points of a) of the PGU lie in range  $\cos \varphi = 0,95$  over-excited to  $\cos \varphi = 0,95$  under-excited.
- b) and c) For PSUs  $> 3,68$  kVA and  $\leq 13,8$  kVA that cannot be used in PGSs  $> 13,8$  kVA, and for PGUs  $\leq 3,68$  kVA that can be used in PGSs  $\leq 13,8$  kVA, the following applies:  
The test is passed when all measurement points of b) lie within range  $\cos \varphi = 0,94$  to  $0,96$  over-excited and of c) in range  $\cos \varphi = 0,94$  to  $0,96$ .
- d) and e) For PGUs  $> 13,8$  kVA and for PGUs  $\leq 13,8$ kVA also in PGSs  $> 13,8$  kVA  
The test is passed when all measurement points of d) lie within range  $\cos \varphi = 0,89$  to  $0,91$  over-excited and of e) in range  $\cos \varphi = 0,89$  to  $0,91$ .

**Note:**


The tests had been performed on the SOFAR 33000TL-G2 and SOFAR 20000TL-G2 are valid for the SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.

5.3.6.4 Test for a displacement factor/active power characteristic curve $\cos \varphi$ (P)										P
<b>Test a):</b>										
$P_{E_{max}}/P$ [%]	10	20	30	40	50	60	70	80	90	100
30 s mean value	20% to 100% $P_{E_{max}}$									
U [V]:	N/A	230,03	230,09	230,14	230,19	230,24	230,27	230,33	230,39	230,43
$P_{E30}$ [kW]:	N/A	6,573	9,914	13,227	16,529	19,776	23,003	26,212	29,403	32,576
$P_{E30}$ of $P_{E_{max}}$ [%]:	N/A	19,92	30,04	40,08	50,09	59,93	69,71	79,43	89,10	98,71
$Q_{E30}$ [kVAr]:	N/A	0,317	0,368	0,439	0,535	-3,228	-6,277	-9,264	-12,378	-15,620
$\cos \varphi_{E30}$ :	N/A	0,999	0,999	0,999	0,999	0,987	0,965	0,943	0,922	0,902
$\cos \varphi_{\text{setpoint}}$ of $P_{E30}$ :	N/A	1,0	1,0	1,0	1,0	0,98	0,96	0,94	0,92	0,92
<b>Limit <math>\cos \varphi_{E30}</math>:</b>	$\cos \varphi_{\text{setpoint}} \pm 0,01$									
<b>Test b):</b>										
$P_{E_{max}}/P_n$ [%]	20			50			90			
30 s mean value	20% to 50% to 100% $P_{E_{max}}$									
U [V]:	230,00			230,05			230,10			
$P_{E30}$ [kW]:	6,616			16,575			32,868			
$P_{E30}$ of $P_{E_{max}}$ [%]:	20,05			50,23			99,60			
$Q_{E30}$ [kVAr]:	0,868			0,897			-15,556			
$\cos \varphi_{E30}$ :	0,991			0,998			0,904			
$\cos \varphi_{\text{setpoint}}$ of $P_{E30}$ :	1,0			1,0			0,90			
$T_0$ [s]:	< 1 s					2 s				
30 s mean value	100% to 50% to 20% $P_{E_{max}}$									
U [V]:	230,00			230,09			230,11			
$P_{E30}$ [kW]:	6,615			16,557			32,841			
$P_{E30}$ [%]:	20,05			50,17			99,52			
$Q_{E30}$ [kVAr]:	0,866			0,894			-15,531			
$\cos \varphi_{E30}$ :	0,991			0,998			0,904			
$\cos \varphi_{\text{setpoint}}$ of $P_{E30}$ :	1,0			1,0			0,90			
$T_0$ [s]:	< 1 s					2s				
<b>Limit <math>T_0</math> [s]:</b>	10 s									
<b>Limit <math>\cos \varphi_{E30}</math>:</b>	$\cos \varphi_{\text{setpoint}} \pm 0,01$									

**Graph of cos φ(P): Test a)**



**Graph of setting (T<sub>0</sub>) time: Test b)**




**Test:**

Test 1: Using the standard characteristic curve increases the active power from 20%  $P_{E_{max}}$  in increments of 10%  $P_{E_{max}}$  to  $P_{E_{max}}$ . The test is carried out in reverse.

Test 2: Using the standard characteristic curve increases the active power from 20%  $P_{E_{max}}$  to 50%  $P_{E_{max}}$  and to  $P_{E_{max}}$ . The test is carried out in reverse. After the PGU has settled, the end value reached is determined as a 30 s mean value.

**Characteristic curve  $\cos \varphi (P)$**



\*) Depending on  $S_{Amax}$

**Assessment criterion:**

Test 1:  $\cos \varphi$  accuracy  $\cos \varphi (\pm 0,01)$

Test 2:  $\cos \varphi$  accuracy  $\cos \varphi (\pm 0,01)$

For the test to be passed, the  $\cos \varphi$  setpoint from the active power must be measured at the terminals of the PGU within a settling time of 10 s.

**Note:**

The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.

**5.4 Testing of NS protection**  
**5.5 Testing of connecting conditions and synchronisation**  
**DIN VDE V 0124-100:2012-07**

Clause	Test	Result
5.4.1	General These tests are designed to provide evidence that the requirements of VDE-AR-N 4105 are met	<b>P</b>
5.4.2	Central NS protection	<b>N/A</b>
5.4.3	Integrated NS protection	<b>P</b>
5.4.4	Interface switch	
	5.4.4.1 General	<b>P</b>
	5.4.4.2 Integrated interface switch	<b>P</b>
5.4.5	Protection devices for the interface switch	
	5.4.5.1 General	<b>P</b>
	5.4.5.2 Functional safety	<b>P</b>
	5.4.5.3 Voltage control	<b>P</b>
	5.4.5.3.3 Measurement of the rise-in voltage protection as a running 10-min mean value	<b>P</b>
	5.4.5.4 Frequency measurement	<b>P</b>
	5.4.5.5 Reporting NS protection	<b>P</b>
5.4.6	Islanding detection	<b>P</b>
5.5	Connecting conditions and synchronisation	<b>P</b>
	5.5.2 Short interruption	<b>P</b>

<p><b>5.4.2 Central NS protection</b> (these tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 6.2 are met)</p>	<p><b>N/A</b></p>
--	-------------------

NS protection provides the possibility for sealing  
or

Password protection is given for protection functions.

The interface switch is triggered when the switch in the "NS protection interface switch" circuit is actuated (only relevant for external NS protection).

Actuation of the interface switch is displayed on the power generation unit. Display is provided by warning light or display text .

<p><b>5.4.3 Integrated NS protection</b> (these tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 6.3 are met)</p>	<p><b>P</b></p>
---	-----------------

Password protection is given for protection function U >.

#### 5.4.4 Interface switch

##### 5.4.4.1 General

(these tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 6.4.1 are met)

**P**

The interface switch consists of two electrical break devices connected in series and is therefore designed with redundancy.

See 5.4.5.2 Functional safety for the test for single-fault tolerance and fault finding with subsequent disconnection for the entire functional chain.

An all-pole galvanic break device is provided.

**Note:**

For synchronous machines, the break device for synchronisation is designed three pole instead of four pole.



### 5.4.4.2 Integrated interface switch

(these tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 6.4.3 are met)

P

The inverter that is not galvanically separated has two independent galvanically separating breaking devices

See 5.4.5.2 Functional safety for the test for single-fault tolerance of the interface switch

The interface switch is short-circuit proof for the maximum short-circuit current of the power generation unit.

max. short-circuit current of the power generation unit= 50A, 250 Vac

max. switching current relay= 50 A, 440Vac

### Datasheet of the relay:

# AZSR235/250

## 50 A (35 A) MINIATURE POWER RELAY

### FEATURES

- 50 Amp switching (AZSR250)
- 35 Amp switching (AZSR235)
- Wide contact gap > 1.85mm (AZSR250)
- Wide contact gap > 2.05mm (AZSR235)
- Holding power <100 mW
- Dielectric strength 5000 Vrms
- Isolation spacing greater than 10 mm
- Reinforced insulation, EN 60730-1 (VDE 0631, part 1), EN 60335-1 (VDE 0700, part 1)
- UL, CUR file E44211
- VDE certificate 40033251

RoHS compliant !



### CONTACTS

Arrangement	SPST (1 Form A) DPST (2 Form A)
Ratings	Resistive load:  AZSR235 Max. switched power: 1050 W or 9695 VA Max. switched current: 35 A Max. switched voltage: 150 VDC* or 440 VAC  AZSR250 Max. switched power: 1500 W or 13850 VA Max. switched current: 50 A Max. switched voltage: 150 VDC* or 440 VAC  * Note: If switching voltage is greater than 30 VDC, special precautions must be taken. Please contact the factory.
Rated Load UL	AZSR235 35 A at 277 VAC, resistive  AZSR250 50 A at 277 VAC, resistive
VDE	AZSR235 35 A at 263 VAC, test referring to AC-7a, 85°C  AZSR250 50 A at 263 VAC, test referring to AC-7a, 85°C
Material	Silver tin oxide
Resistance	< 50 milliohms initially

### GENERAL DATA

Life Expectancy Mechanical Electrical	Minimum operations 1 x 10 <sup>6</sup> 5 x 10 <sup>4</sup> at 35 A 250 VAC Res. (AZSR235) 5 x 10 <sup>4</sup> at 50 A 250 VAC Res. (AZSR250)
Operate Time (typical)	40 ms at nominal coil voltage
Release Time (typical)	5 ms at nominal coil voltage (with no coil suppression)
Dielectric Strength (at sea level for 1 min.)	5000 Vrms coil to contact 2500 Vrms between contact sets 2500 Vrms between open contacts
Insulation Resistance	1000 megohms min. at 20°C 500 VDC 50% RH
Insulation (according to DIN VDE 0110, IEC 60664-1)	C250 Overvoltage category: III Pollution degree: 3 Nominal voltage: 250 VAC
Dropout	Greater than 5% of nominal coil voltage
Ambient Temperature Operating	At nominal coil voltage -40°C (-40°F) to 85°C (185°F)
Vibration	0.062* (1.5 mm) DA at 10-55 Hz
Shock	10 g
Enclosure	P.B.T. polyester
Terminals	Tinned copper alloy, P.C.
Max. Solder Temp.	270°C (518°F)
Max. Solder Time	5 seconds
Weight	105 grams
Packing unit in pcs	10 per inner carton / 100 per carton box.

### COIL

Power At Pickup Voltage (typical)	270 mW (AZSR250)
Max. Continuous Dissipation	2.0 W at 20°C (68°F) ambient
Temperature Rise	15°C (27°F) at nominal coil voltage
Temperature	Max. 155°C (311°F) Class F

### NOTES

1. All values at 20°C (68°F).
2. Relay may pull in with less than "Must Operate" value.
3. Specifications subject to change without notice.

## ZETTLER electronics GmbH

Junkersstr. 3, D-82178 Puchheim, Germany

phone: +49 89 800 97-0 office@ZETTLERelectronics.com  
fax: +49 89 800 97-200 www.ZETTLERelectronics.com

This product specification to be used only together with the application notes  
which can be downloaded from <http://www.ZETTLERelectronics.com/pdfs/relais/ApplicationNotes.pdf>

2013-06-27



General Purpose Relays  
Power Relays

Potter & Brumfield

**Power PCB Relay T9V Solar**

- 1 pole 40A, 1 form A (NO) contact
- Contact gap >1.8mm (suffix S)
- 350mW hold power
- Ambient temperature up to 85°C at 35A
- The appliance is able to meet VDE V 0126-1-1
- Product in accordance to IEC 60335-1
- EN61095: AC7a at 85°C



Typical applications  
Electrical vehicle loading stations  
Electrical vehicle  
Photovoltaic inverter

**Approvals**

VDE 40030974, UL E58304, CQC16002145203, TUV R50369970  
Technical data of approved types on request

**Contact Data**

Contact arrangement	1 form A (NO)
Contact gap	>1.8mm
Rated voltage	277VAC (1.8mm gap)
Rated current	40A <sup>1)</sup>
Breaking capacity max.	10 000 VA
Contact material	AgNi
Initial contact resistance	75mΩ max. at 1A 6VDC
Frequency of operation, with/without load	6/300min <sup>-1</sup>
Operate/release time max., incl bounce time	18/15ms

**Contact ratings<sup>2)</sup>**

Type	Contact	Load	Cycles
<b>IEC 61810</b>			
T9VV1K15-12S	A (NO)	35A, 250VAC, cosφ=1, 85°C	20x10 <sup>3</sup>
<b>UL 508</b>			
T9VV1K15-12S	A (NO)	35A, 250VAC, resistive, 85°C	20x10 <sup>3</sup>
T9VV1K15-12S	A (NO)	40A, 30VDC, resistive, 70°C	60x10 <sup>3</sup>
<b>CQC</b>			
T9VV1K15-12S	A (NO)	40A, 250VAC, resistive, 60°C	20x10 <sup>3</sup>
<b>TUV</b>			
T9VV1K15-12S	A (NO)	40A, 30VDC, resistive, 70°C	60x10 <sup>3</sup>

Mechanical endurance, DC coil 1x10<sup>6</sup> operations

- 1) The relay connections and wiring have to be designed with an adequate cross sections to ensure the current flow and heat dissipation.
- 2) Contact ratings with relay properly vented.

**Coil Data**

Rated coil voltage	12VDC
Coil insulation system according UL	class F

**Coil versions, DC coil**

Coil code	Rated voltage VDC	Operate voltage VDC	Release voltage VDC	Coil resistance Ω±10%	Rated coil power W
12	12 <sup>2)</sup>	9.6	0.8	64±10%	2.25 / min. 0.35 hold

2) After the energization time of 100 ms with 12 VDC the coil requires a reduction of the coil voltage to 4.7...6.0 VDC.

All figures are given for coil without pre-energization, at ambient temperature +23°C. Other coil voltages on request.

**Insulation Data**

Initial dielectric strength between open contacts	2500V <sub>rms</sub>
between contact and coil	4000V <sub>rms</sub>
Clearance/creepage between contact and coil	3/4mm
Material group of insulation parts	III
Tracking index of relay base	PTI 325

**Other Data**

Material compliance: EU RoHS/ELV, China RoHS, REACH, Halogen content refer to the Product Compliance Support Center at [www.te.com/customer-support/rohssupportcenter](http://www.te.com/customer-support/rohssupportcenter)

Ambient temperature	-40 to +85°C <sup>1)</sup>
Category of environmental protection IEC 61810	RTII - flux proof
Vibration resistance (functional)	10g
Shock resistance (functional)	10g
Shock resistance (destructive)	100g
Terminal type	PCB-THT
Mounting	see note <sup>1)</sup>
Mounting distance	≥10mm
Weight	appr. 30g
Resistance to soldering heat THT IEC 60068-2-20	260°C/5s
Packaging unit	box/500 pcs.

1) The relay connections and wiring have to be designed with an adequate cross sections to ensure the current flow and heat dissipation.

12-2016, Rev. 1216  
[www.te.com](http://www.te.com)

© 2015 Tyco Electronics Corporation, a TE Connectivity Ltd. company

Datasheets and product specification according to IEC 61810-1 and to be used only together with the 'Definitions' section.

Datasheets and product data is subject to the terms of the disclaimer and all chapters of the 'Definitions' section, available at <http://relays.te.com/definitions>

Datasheets, product data, 'Definitions' section, application notes and all specifications are subject to change.

1

**Note:**

AZSR250-2AE-12D for SOFAR 30000TL-G2, SOFAR 33000TL-G2

T9VV1K15-12S for SOFAR 20000TL-G2, SOFAR 25000TL-G2-G2

### 5.4.5 Protection devices for the interface switch

#### 5.4.5.1 General

(these tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 6.5.1 are met)

**P**

#### Test condition:

The measurements were performed in the testing laboratory.  
at the grid-simulator:  
 $U_N$  = between 86 %  $U_n$  and 109%  $U_n$  until the test  
Frequency: 50 Hz +/- 0,5%

#### Note:

If an examination is required for any other requirements, these apply to this test.

#### 5.4.5.2 Functional safety

**P**

Component No.	Fault	Test condition:		Test time	Fuse no.	Fault condition		Result
		AC	DC			AC	DC	
Relay defect RYB1 pin4-pin5	Short before start up	230V <1A	850V <1A	10min.	--	230V <1A	850V <1A	Error message"Relay test fail", PV inverter do not connect to the grid.
Relay defect RYB2 pin4-pin5	Short before start up	230V <1A	850V <1A	10min.	--	230V <1A	850V <1A	Error message"Relay test fail", PV inverter do not connect to the grid.
Relay defect RYB3 pin4-pin5	Short before start up	230V <1A	850V <1A	10min.	--	230V <1A	850V <1A	Error message"Relay test fail", PV inverter do not connect to the grid.
Relay defect RYB4 pin4-pin5	Short before start up	230V <1A	850V <1A	10min.	--	230V <1A	850V <1A	Error message"Relay test fail", PV inverter do not connect to the grid.
Relay defect RYB5 pin4-pin5	Short before start up	230V <1A	850V <1A	10min.	--	230V <1A	850V <1A	Error message"Relay test fail", PV inverter do not connect to the grid.
Relay defect RYB6 pin4-pin5	Short before start up	230V <1A	850V <1A	10min.	--	230V <1A	850V <1A	Error message"Relay test fail", PV inverter do not connect to the grid.
Grid voltage monitoring RB137	Open	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error".
Grid voltage monitoring RB 139	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error".
Grid voltage monitoring RB 131	Open	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error".

Grid voltage monitoring RB 128	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error".
Grid voltage monitoring RB 122	Open	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error".
Grid voltage monitoring RB 120	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error".
Grid voltage monitoring RB 112	Open	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error".
Grid voltage monitoring RB 110	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error".
RCMU detect defect RB 96	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"GFCI error".
RCMU detect defect RB 11	Open	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"GFCI error".
RCMU detect defect RB 8	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"GFCI error".
RCMU detect defect UB1 PIN5 to 6	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"GFCI error".
RCMU detect defect QB1 PIN2 to 3	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"GFCI error".
RCMU detect defect QB3 PIN2 to 3	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"GFCI error".
RCMU detect defect UB2 PIN5 to 7	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"GFCI error".
RCMU detect defect RB23	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"GFCI error".
RCMU detect defect CB17	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"GFCI error".
RCMU detect defect UB2 PIN12 to 14	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"GFCI error".
RCMU detect defect RB25	Open	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"GFCI error".

RCMU detect defect UB2 PIN10 to 8	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"GFCI error".
Grid voltage monitoring RC6	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error". No damaged.No hazard.
Grid voltage monitoring RC19	Open	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error". No damaged.No hazard.
Grid voltage monitoring UC627 PIN2 to 3	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error". No damaged.No hazard.
Grid voltage monitoring UC627 PIN5 to 7	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage sample error". No damaged.No hazard.
Grid voltage monitoring UC627 PIN8 to 10	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage sample error". No damaged.No hazard.
Grid voltage monitoring RC73	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error". No damaged.No hazard.
Grid voltage monitoring UC629 PIN2 to 3	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error". No damaged.No hazard.
Grid voltage monitoring RC70	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage error". No damaged.No hazard.
Grid voltage monitoring UC629 PIN8 to 10	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage sample error". No damaged.No hazard.
Grid voltage monitoring UC629 PIN5 to 7	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter disconnected from grid immediately. Error message:"The grid voltage sample error". No damaged.No hazard.
ISO detect defect RC167	Short before start-up	230V <1A	850V <1A	10min.	--	230V <1A	850V <1A	Inverter did not start-up. Error message:"The ISO error".
ISO detect defect RC98	Short before start-up	230V <1A	850V <1A	10min.	--	230V <1A	850V <1A	Inverter did not start-up. Error message:"The ISO error".

ISO detect defect RC113	Short before start-up	230V <1A	850V <1A	10min.	--	230V <1A	850V <1A	Inverter did not start-up. Error message:"The ISO error".
ISO detect defect RC116	Short before start-up	230V <1A	850V <1A	10min.	--	230V <1A	850V <1A	Inverter did not start-up. Error message:"The ISO error".
ISO detect defect UC634 PIN6 to 7	Short before start-up	230V <1A	850V <1A	10min.	--	230V <1A	850V <1A	Inverter did not start-up. Error message:"The ISO error".
DSP communication defect XLC1 PIN1 to 2	Short	230V 47.7 A	850V 40A	10min.	--	230V <1A	850V <1A	Inverter did not start-up. Error message:"The SPI error"


**Note:**

The errors in the control circuit simulate that the safety is even ensured during a single fault.


The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.

5.4.5.3 Voltage control							P
<b>Integrated NS protection three phase <math>\leq 30\text{kVA}</math> (phase to neutral)</b>							
Setting values of the NS protection:	Setting $U_{<}$ [V]:			184,0			
	Setting $U_{>>}$ [V]:			264,5			
	Setting $T_{\text{disconnection}}$ [ms]			150			
<b>Operating time of the monitoring device:</b>							
	<b>Under voltage:</b>			<b>Over voltage:</b>			
L1 to N:							
Step [V to V]:	230,0 V to 177,1 V			230,0 V to 271,4 V			
Limit [V]:	184,0 V			264,5 V			
Measurement [V:]	183,7	183,7	183,7	264,9	264,9	264,9	
Limit [ms]:	200 ms			200 ms			
Disconnection time [ms]:	160,5	161,5	174,7	196,1	198,1	197,7	
L2 to N:							
Step [V to V]:	230,0 V to 177,1 V			230,0 V to 271,4 V			
Limit [V]:	184,0 V			264,5 V			
Measurement [V:]	183,6	183,6	183,6	263,9	263,9	263,9	
Limit [ms]:	200 ms			200 ms			
Disconnection time [ms]:	184,7	160,7	162,7	193,7	197,7	199,7	
L3 to N:							
Step [V to V]:	230,0 V to 177,1 V			230,0 V to 271,4 V			
Limit [V]:	184,0 V			264,5 V			
Measurement [V:]	183,1	183,1	183,1	264,6	264,6	264,6	
Limit [ms]:	200 ms			200 ms			
Disconnection time [ms]:	182,7	172,7	168,7	193,7	199,7	198,5	
<b>Test:</b>							
The voltages per phase conductor are measured, into which current is fed between the line conductor and the neutral conductor.							
To measure the disconnection time a surge of 77% <sub>n</sub> is taken from the nominal voltage and of 118% <sub>n</sub> from the nominal voltage for undervoltage and undervoltage.							
<b>Assessment criterion:</b>							
The permitted tolerance between setting value and trip value of the voltage may not exceed $\pm 1\%$ of $U_n$ .							
<u>Limit values:</u>							
Voltage drop protection	$U_{<}$	0,8 $U_n$	200 ms				
Rise-in voltage protection	$U_{>>}$	1,15 $U_n$	200 ms				
<b>Note:</b>							
The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.							

Graph of under voltage : L1 to N




Graph of over voltage : L1 to N







Graph of under voltage : L2 to N




Graph of over voltage : L2 to N



Graph of under voltage : L3 to N




Graph of over voltage : L3 to N




5.4.5.3.3 Measuring the rise-in voltage protection as a running 10-minute mean value			P
<b>Test:</b>			
	Disconnection time:	Limit:	
a)	The voltage is set to 100% $U_n$ and held for 600 s. Thereafter the voltage is set to 112% $U_n$ . Disconnection must take place within 600 s.		
	Phase 1:	484 s	600 s
	Phase 2:	530 s	
	Phase 3:	482 s	
b)	The voltage is set to $U_n$ for 600 s and then to 108% $U_n$ for 600 s. No disconnection should take place.		
	Phase 1:	No disconnected	Disconnection should not take place.
	Phase 2:	No disconnected	
	Phase 3:	No disconnected	
c)	The voltage is set to 106 % $U_n$ and held for 600 s. Thereafter the voltage is set to 114 % $U_n$ . *The disconnection should last for half the period as in Point a)		
	Phase 1:	302 s	*
	Phase 2:	245 s	
	Phase 3:	271 s	
<b>Test:</b>			
a) This test serves as proof of the measurement accuracy and the maximum set time.			
b) This test serves as proof of the measurement accuracy.			
c) This test serves as proof of the correct formation of the 10 minute running mean value.			
<b>Assessment criterion:</b>			
The permitted tolerance between setting value and trip value of the voltage may not exceed $\pm 1\%$ of $U_n$ .			
<u>Limit values:</u>			
Rise-in voltage protection	$U >$	1,1 $U_n$	after a max. 600 s, the switch off after 200 ms.
<b>Note:</b>			
If only one integrated NS protection is used for the power generation systems $\leq 30\text{kVA}$ , the value of the rise-in voltage protection $U >$ of 1,1 $U_n$ may not be changed.			
* The disconnection time for test c) may vary due to tolerances of the measurement accuracy of the voltage of the NS protection. For a setting value 600 s a range from 225 s to 375 s is within the permissible tolerance.			
The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.			


Graph of test a) Voltage set to 112 %  $U_n$ :



Graph of test b) Voltage set to 108%  $U_n$ :



Graph of test c) Voltage set to 106 %  $U_n$ , thereafter 114%  $U_n$ :



5.4.5.4 Frequency measurement						P
Setting values of the NS protection:	Setting f< [Hz]:			47,50		
	Setting f>[Hz]:			51,50		
	Setting T <sub>disconnection</sub> [ms]			150		
Operating time of the monitoring device						
	Under frequency			Over frequency		
Ramp [Hz to Hz]:	48,00 Hz -> 47,00 Hz			51,00 Hz -> 52,00 Hz		
Limit [Hz]:	47,50 Hz			51,50 Hz		
Measurement [Hz]:	47,50	47,50	47,50	51,50	51,50	51,50
Limit [ms]:	200 ms			200 ms		
Disconnection time [ms]:	181	199	198	156	152	156
<b>Test:</b>						
The measuring is performed at a continuous change of frequency of 1 Hz/s. The trip value was determined manually by reducing the frequency in 10 mHz steps. When the trip value is known (e.g. 47,50 Hz), the grid simulator is programmed to run from e.g. 48,00 Hz to 47,00 Hz with 1 Hz/s. The disconnection time is calculated by the measured time minus the 500 ms from 48,00 Hz to 47,50 Hz.						
<b>Assessment criterion:</b>						
The setting value and the trip value of the frequency may not vary by more than $\pm 0.1 \% f_n$ .						
For frequencies of between 47,5 Hz and 51,5 Hz ( $\pm 0,1\% f_n$ ) automatic disconnection from the network as a result of a deviation in frequency is not permitted.						
<u>Limit values:</u>						
Frequency decrease protection	f<	47,5 Hz	200 ms			
Frequency increase protection	f<	51,5 Hz	200 ms			
<b>Note:</b>						
The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.						

**Graph of under frequency:**



**Graph of over frequency:**



#### 5.4.5.5 Reporting NS protection

P

The last 5 dated failure reports on the NS protection can be read. An interruption in the supply voltage of  $\leq 3s$  does not result in any loss of failure reports.

##### Central NS protection:

It is possible to read the setting values and the failure reports of the NS protection independently of the operational state and without any additional aids.

##### Integrated NS protection:

It is possible to read out the values of the NS protection via the data interface, if the values are not directly readable.

##### Note:



#### 5.4.6 Islanding detection

(these tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 6.5.3 are met)

For power generation systems, islanding detection must be carried out using one of the following processes:


- a) active method, e.g. by means of frequency – shift process (oscillating circuit)
- b) passive method with the help of the three-phase voltage control (only possible for power generation systems without converters or for single-phase generation units with converters).  
(see 5.4.5.3 3-phase voltage control)

With the passive process, it is important to provide evidence that the power generation unit can be set not equal to  $120^\circ$ .


5.4.6.1 Active method (these tests are designed to provide evidence that the requirements of VDE-AR-N 4105, D.1 are met)		P	
<b>Test condition:</b>	Frequency: 50+/-0,01 Hz $U_N = 230 \pm 1\% V_{ac}$ RLC consumes inverter real power within +/-3% Distortion factor of chokes <3% Quality $Q > 2$		
Disconnection limit:	5 s		
<b>L1 phase</b>			
<del>Output power: Osc. parameter</del>	25%	50%	100%
- 5%	77,4	194,2	120,2
- 4%	92,4	190,2	229,2
- 3%	98,4	151,2	219,2
- 2%	87,4	180,2	230,2
- 1%	89,4	196,2	220,2
0%	98,8	197,2	234,2
+1%	89,4	147,2	216,2
+2%	87,8	168,2	136,2
+3%	88,8	181,2	201,2
+4%	76,8	149,2	210,2
+5%	85,8	151,6	135,2
Parameter at 0%	L=32,26 mH R= 20,27 $\Omega$ C= 314,10 $\mu F$	L= 14,93 mH R= 9,38 $\Omega$ C= 678,74 $\mu F$	L= 7,34 mH R= 4,61 $\Omega$ C= 1380,35 $\mu F$
<b>L2 phase</b>			
<del>Output power: Osc. parameter</del>	25%	50%	100%
- 5%	90,2	149,2	145,2
- 4%	84,2	134,2	138,2
- 3%	79,2	106,2	143,2
- 2%	85,2	108,2	119,2
- 1%	88,2	133,2	470,2
0%	92,2	153,2	652,2
+1%	82,2	120,2	138,2
+2%	92,2	120,2	155,2
+3%	83,2	146,2	147,2
+4%	91,2	136,2	137,2
+5%	88,2	137,2	121,2
Parameter at 0%	L=32,38 mH R= 20,35 $\Omega$ C= 312,89 $\mu F$	L= 16,64 mH R= 10,45 $\Omega$ C= 608,94 $\mu F$	L= 8,34 mH R= 5,24 $\Omega$ C= 1215,47 $\mu F$

<b>L3 phase</b>			
Output power: Osc. parameter	25%	50%	100%
- 5%	97,4	128,6	94,6
- 4%	77,4	128,4	216,0
- 3%	87,2	139,4	224,0
- 2%	72,6	129,4	218,0
- 1%	79,4	131,6	210,0
0%	88,4	143,4	268,6
+1%	80,4	123,6	210,6
+2%	87,4	123,6	217,6
+3%	86,4	110,6	194,6
+4%	82,4	95,4	226,6
+5%	88,4	137,6	202,6
Parameter at 0%	L=32,13 mH R= 20,19 Ω C= 315,30μF	L= 16,64 mH R= 10,45 Ω C= 608,94μF	L= 8,44 mH R= 5,31 Ω C= 1199,83 μF
<p><b>Test:</b> The capacitors and the chokes of the resonant circuit were adjusted in order to reach a quality of &gt;2. <math>P_{QC}+P_{QL}=P_{Q,WR}</math>. The resistors of the resonant circuit consumed the real power of the inverter (<math>P_{WR}</math>) within +/-3%.</p> $L = \frac{U^2}{2 \cdot \pi \cdot 50Hz \cdot P \cdot Q} \qquad C = \frac{P \cdot Q}{2 \cdot \pi \cdot 50Hz \cdot U^2}$			
<p><b>Assessment criterion:</b> <u>Limit values:</u> Quality factor Q &gt; 2 Disconnection t ≤ 5 s</p>			
<p><b>Note:</b> The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.</p>			


### Oscillating circuit test: 25% output power



### Oscillating circuit test: 50% output power



### Oscillating circuit test: 100% output power



5.4.6.1 Passive method	N/A
<p>Three-phase voltage control is permitted for islanding detection, as the currents of the power generation unit are controlled independently, so that arbitrary phase relationships can develop.</p>	
<p><b>Test:</b> The test is performed according to the voltage disconnection testing clause 5.4.5.3.1 a). The test is passed, if the current follows without phase displacement of the voltage on the displaced phase.</p> <p>For test results, see clause 5.4.5.3.1 a) above.</p>	
<p><b>Note:</b></p>	

**5.5 Testing of connecting conditions and synchronisation  
DIN VDE V 0124-100:2012-07**

Clause	Test	Result
5.5	Connecting conditions and synchronisation	<b>P</b>
	5.5.2 Short interruption	<b>P</b>

<b>5.5 Connecting conditions and synchronisation</b> (these tests are designed to provide evidence that the requirements of VDE-AR-N 4105, 8.3.1 are met)			<b>P</b>
Setting values of the NS protection:	Setting $T_{\text{reconnection } 60\text{s}}$ [s]:	70	
	Setting $f_{<}$ [Hz]:	47,5	
	Setting $f_{>}$ [Hz]:	51,5	
	Setting $V_{<}$ [V]:	184,0	
	Setting $V_{>>}$ [V]:	264,5	
<b>Test:</b>			
	$f_{\text{ist}}$	<b>Reset time:</b>	<b>Limit:</b>
<b>Connecting conditions for frequencies:</b>			
a)	47,45 Hz	No reconnected.	No resetting allowed
	Switch to:		
b)	$\geq 47,55$ Hz	65 s	$\geq 60$ s
c)	50,06 Hz	No reconnected.	No resetting allowed
	Switch to:		
d)	$\geq 50,0$ Hz	75 s	$\geq 60$ s
<b>Connecting conditions for voltages: L1 phase</b>			
e)	84%	No reconnected.	No resetting allowed
	Switch to:		
f)	$\geq 86\%$	67 s	$\geq 60$ s
g)	111 %	No reconnected.	No resetting allowed
	Switch to:		
h)	$\leq 109\%$	71 s	$\geq 60$ s
<b>Connecting conditions for voltages: L2 phase</b>			
e)	84%	No reconnected.	No resetting allowed
	Switch to:		
f)	$\geq 86\%$	66 s	$\geq 60$ s
g)	111 %	No reconnected.	No resetting allowed
	Switch to:		
h)	$\leq 109\%$	66 s	$\geq 60$ s
<b>Connecting conditions for voltages: L3 phase</b>			
e)	84%	No reconnected.	No resetting allowed
	Switch to:		
f)	$\geq 86\%$	66 s	$\geq 60$ s
g)	111 %	No reconnected.	No resetting allowed
	Switch to:		
h)	$\leq 109\%$	67 s	$\geq 60$ s



**Test:**

see points a) to h) for the test process.

The measurement was carried out with a programmable AC source.

e.g. connecting conditions for frequencies: Point a) and b). The AC source was programmed in such a way that the first step of 230 V / 50 Hz to 200 V / 47,0 Hz resulted in a faulty disconnection. Thereafter the voltage and frequency for 100 s is set to 215 V / 47,45 Hz. Switching on again is not permitted. After a lapse of 100 s the voltage is set to 230 V / 47,55 Hz. Setting again after 60 s is permitted.


**Assessment criterion:**

After actuating the NS protection it should be checked that the system can only be switched within the tolerance ranges ( $(85\% U_n \leq U \leq 110\% U_n)$  and  $(47,5 \text{ Hz} \leq f \leq 50,05 \text{ Hz})$ ) at the earliest after 60 s after voltage and frequency has remained within the tolerance ranges.


**Note:**

The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.


a) 47,50 Hz to b)  $\geq 47,55$  Hz:




c) 50,10 Hz to d)  $\leq 50,00$  Hz:




e) 84 %  $U_n$  to f)  $\geq 86$  %  $U_n$ : L1 phase




g) 111 %  $U_n$  to h)  $\leq 109$  %  $U_n$ : L1 phase




e) 84 %  $U_n$  to f)  $\geq 86$  %  $U_n$ : L2 phase




g) 111 %  $U_n$  to h)  $\leq 109$  %  $U_n$ : L2 phase



e) 84 %  $U_n$  to f)  $\geq 86$  %  $U_n$ : L3 phase




g) 111 %  $U_n$  to h)  $\leq 109$  %  $U_n$ : L3 phase




5.5.2 Short interruption		P
Setting values of the NS protection:	Setting $T_{\text{disconnection } 5s}$ [s]:	30
	Setting $T_{\text{reconnection } 60s}$ [s]:	70
	Setting $V <$ [V]:	184,0
	<b>Step 1:</b>	<b>Step 2:</b>
Step [V to V]	230 V to 177,1 V	230 V to 177,1 V
Jump Duration [s]:	2 s	4 s
Limit [s]:	$\geq 5$ s	$\geq 60$ s
Reconnection Time [s]:	36	67
<p><b>Test:</b>            After providing evidence of a short interruption the network voltage is reduced from the nominal voltage with a surge of 77% <math>U_n</math>. A surge to the nominal voltage takes place after 2 s.            After providing evidence of a short interruption the network voltage is reduced from the nominal voltage with a surge of 77% <math>U_n</math>. A surge to the nominal voltage takes place after 4 s.</p>		
<p><b>Assessment criterion:</b>  <u>Limit values:</u>            Short interruption <math>\leq 2</math> s Reset time <math>\geq 5</math> s            Short interruption <math>\geq 3</math> s Reset time <math>\geq 60</math> s</p>		
<p><b>Note:</b>            A short interruption is characterised by exceeding or not reaching the NS protection settings for the network frequency and/or network voltage for a maximum period of 3 seconds.             A ramp of 10% <math>P_n</math> is not necessary after short interruptions.             The tests had been performed on the SOFAR 33000TL-G2 is valid for the and SOFAR 20000TL-G2, SOFAR 25000TL-G2 and SOFAR 30000TL-G2, since it is similar in hardware and just power derated by software.</p>		

Step 1: 230 V to 177,1 V in 2 s:



Step 2: 230 V to 177,1 V in 4 s:



# Annex No. 1

**Pictures of the unit**


**The full pictures refer to PHOTO DOCUMENT**

**Project No.: 180712N013**

**Date: 20190424**



Enclosure front view: SOFAR 20000TL-G2



Enclosure rear view: SOFAR 20000TL-G2



**Enclosure front view: SOFAR 25000TL-G2**



**Enclosure rear view: SOFAR 25000TL-G2**



**Enclosure front view: SOFAR 3000TL-G2, SOFAR 33000TL-G2**



**Enclosure rear view: SOFAR 3000TL-G2, SOFAR 33000TL-G2**



# Annex No. 2

## Test Equipment list

**Test location: Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch**

**Dates of performance test: 2018-07-12 to 2019-04-20**

Equipment	Internal No.	Manufacturer	Type	Serial No.	Last Calibration
Power Analyzer	A4080002DG	YOKOGAWA	WT3000	91M210852	Dec. 13, 2018
AC Source	A7040019DG	Chroma	61512	61512000439	Monitored by Power Analyzer
	A7040020DG	Chroma	61512	61512000438	
DC Simulation Power Supply	A7040015DG	Chroma	62150H-1000S	62150EF00488	
	A7040016DG	Chroma	62150H-1000S	62150EF00490	
	A7040017DG	Chroma	620028	620028EF00120	
RLC Load	A7150027DG	Qunling	ACLT-3803H	93VOO2869	
Eight Channel Digital Phosphor Oscilloscope	A4089017DG	YOKOGAWA	DL850	91N726247	Sep. 14, 2018
Four Channel Digital Phosphor Oscilloscope	A4089003DG	Tektronix	DPO4104B	C010624	Oct. 25, 2018
Oscilloscope probel	A1490009DG	YOKOGAWA	701901	//	Nov. 01, 2018
	A1490010DG	YOKOGAWA	701901	//	Nov. 01, 2018
	A1490011DG	YOKOGAWA	701901	//	Nov. 01, 2018
Current transducer	A1060008DG	YOKOGAWA	CT200	1130700017	Nov. 17, 2018
	A1060009DG	YOKOGAWA	CT200	1130700019	Nov. 17, 2018
	A1060009DG	YOKOGAWA	CT200	1130700019	Nov. 17, 2018