




# Certificate of Conformity

**Certificate No.:** 2088AP0302N015014  
**Product:** Hybrid inverter  
**Brand Name:**   
**Test Model No.:** HYD 5KTL-3PH, HYD 6KTL-3PH, HYD 8KTL-3PH, HYD 10KTL-3PH,  
HYD 15KTL-3PH, HYD 20KTL-3PH  
**Applicant:** Shenzhen SOFAR SOLAR Co., Ltd.  
401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community,  
XinAn Street, BaoAn District, Shenzhen, China  
**Report No.:** PVDK200302N015

## Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with TECHNICAL REGULATION 3.3.1:2019 for electrical energy storage systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. It replaces the disconnection device with an insulating function, which the distribution network provider can access at any time.

## Applied rules and standards

**TECHNICAL REGULATION 3.3.1:2019**  
FOR ELECTRICAL ENERGY STORAGE FACILITIES

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.



**Name: James Huang**  
**Technical Manager/ New Energy Team**  
**Date: 2020-10-15**

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.  
Information given in this document is related to the tested specimen of the described electrical sample.