



Test Report issued under the responsibility of:

中国认可
国际互认
检测
TESTING
CNAS L6791

Page 1 of 50

TEST REPORT
IEC 60255-27Measuring relays and protection equipment –
Part 27: Product safety requirements

Report Number..... : BL-DG20A0099-B01

Date of issue..... : Jan. 13, 2021

Total number of pages : 50

Name of Testing Laboratory preparing the Report : Shenzhen BALUN Technology Co., Ltd

Applicant's name : Shenzhen SOFARSOLAR Co., Ltd.

Address..... : 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China.

Test specification:

Standard : IEC 60255-27:2013

Test procedure : Commissioned test

Non-standard test method : N/A

Test item description..... : Solar Grid-tied Inverter

Trade Mark..... :



Manufacturer : Shenzhen SOFARSOLAR Co., Ltd.

Model/Type reference..... : SOFAR 15KTLX-G3, SOFAR 17KTLX-G3, SOFAR 20KTLX-G3, SOFAR 22KTLX-G3, SOFAR 24KTLX-G3

Ratings..... : See copy of marking label and model list.

Testing Laboratory : Shenzhen BALUN Technology Co., Ltd

Testing location/ address 1 : Room 104, 204, 205, Building 1, No. 6, Industrial South Road, Songshan Lake District, Dongguan, Guangdong, China

Testing location/ address 2 : Block B, 1/F., Baisha Science & Technology Park, Shahe West Road, Nanshan District, Shenzhen, Guangdong, China

Tested by (name, function, signature)..... : Colin Chen /Engineer

Approved by (name, function, signature)..... : Simon Qi /Chief Engineer

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the Testing Laboratory, responsible for this Test Report.

For the report with CNAS mark, the items marked with "☆" are not within the accredited scope.

List of Attachments (including a total number of pages in each attachment):

Tests against:

Total test reports contain 1 part and 1 attachments listed in below table:

Item	Description	pages
Part 1	Test report of IEC 60255-27:2013	51
ATTACHMENT 1	Photo documentation	7

Summary of testing:

Tests performed (name of test and test clause):	Testing location:
10.6.1.1 Dry-heat test – operational. 10.6.1.2 Cold test – operational. 10.6.1.3 Dry heat test at maximum storage temperature. 10.6.1.4 Cold test at minimum storage temperature. 10.6.1.5 Damp-heat test. 10.6.1.6 Cyclic temperature with humidity test. 10.6.2.1 Vibration 10.6.2.2 Shock 10.6.2.3 Bump 10.6.2.4 Seismic ☆ 10.6.2.5 Accessible parts test 10.6.2.6 IP rating 10.6.3 Clearances and creepage distances 10.6.4.2 Impulse voltage 10.6.4.3 AC or d.c. dielectric voltage 10.6.4.4 Insulation resistance 10.6.4.5 Protective bonding resistance 10.6.4.5.2 Protective bonding continuity 10.6.5.1 Maximum temperature of parts and materials ☆ 10.6.5.3 Thermal short time 10.6.5.4 Output relay, make and carry 10.6.5.5 Single-fault condition 10.6.6 Reverse polarity and slow ramp Remark: - The max.operating temperature is 60°C specified by manufacturer, the temperature rise tests were conducted at the max.rated ambient temperature of 45°C or 60°C (derating) in the chamber. - Other testing conditions considered in this test report, see General Product Information on the following pages.	All tests except Ingress protection are performed at address 1 listed on page 1. Ingress protection test is performed at address 2 listed on page 1

Summary of compliance with National Differences (List of countries addressed): None. The product fulfils the requirements of IEC 60255-27:2013.

Copy of marking plate:**The artwork below may be only a draft.**

Solar Grid-tied Inverter

Model No:	SOFAR 15KTLX-G3
Max.DC Input Voltage	1100V
Operating MPPT Voltage Range	140~1000V
Max. Input Current	26A/26A
Max. PV Isc	36A/36A
Nominal Grid Voltage	3/N/PE,380/400V
Max. Output Current	3x23.9A
Nominal Grid Frequency	50/60Hz
Nominal Output Power	15000W
Max. Output Power	16500VA
Power Factor	1(adjustable+/-0.8)
Ingress Protection	IP65
Operating Temperature Range	-30°C~+60°C
Protective Class	Class I
Made in China	

Manufacturer : Shenzhen SOFARSOLAR Co.,Ltd.
Address : 401, Building 4, AnTongDa Industrial Park,
District 68, XingDong Community,XinAn Street,
BaoAn District, Shenzhen, China
VDE0126-1-1,VDE-AR-N4105,G99,IEC61727
IEC62116,UTE C15-712-1,AS4777



Solar Grid-tied Inverter

Model No:	SOFAR 17KTLX-G3
Max.DC Input Voltage	1100V
Operating MPPT Voltage Range	140~1000V
Max. Input Current	26A/26A
Max. PV Isc	36A/36A
Nominal Grid Voltage	3/N/PE,380/400V
Max. Output Current	3x27.1A
Nominal Grid Frequency	50/60Hz
Nominal Output Power	17000W
Max. Output Power	18700VA
Power Factor	1(adjustable+/-0.8)
Ingress Protection	IP65
Operating Temperature Range	-30°C~+60°C
Protective Class	Class I
Made in China	

Manufacturer : Shenzhen SOFARSOLAR Co.,Ltd.
Address : 401, Building 4, AnTongDa Industrial Park,
District 68, XingDong Community,XinAn Street,
BaoAn District, Shenzhen, China
VDE0126-1-1,VDE-AR-N4105,G99,IEC61727
IEC62116,UTE C15-712-1,AS4777



SOFAR 15KTLX-G3



SOFAR 17KTLX-G3



Solar Grid-tied Inverter

Model No:	SOFAR 20KTLX-G3
Max.DC Input Voltage	1100V
Operating MPPT Voltage Range	140~1000V
Max. Input Current	26A/26A
Max. PV Isc	36A/36A
Nominal Grid Voltage	3/N/PE,380/400V
Max. Output Current	3x31.9A
Nominal Grid Frequency	50/60Hz
Nominal Output Power	20000W
Max. Output Power	22000VA
Power Factor	1(adjustable+/-0.8)
Ingress Protection	IP65
Operating Temperature Range	-30°C~+60°C
Protective Class	Class I
Made in China	

Manufacturer : Shenzhen SOFARSOLAR Co.,Ltd.
Address : 401, Building 4, AnTongDa Industrial Park,
District 68, XingDong Community,XinAn Street,
BaoAn District, Shenzhen, China
VDE0126-1-1,VDE-AR-N4105,G99,IEC61727
IEC62116,UTE C15-712-1,AS4777



SOFAR 20KTLX-G3



Solar Grid-tied Inverter

Model No:	SOFAR 22KTLX-G3
Max.DC Input Voltage	1100V
Operating MPPT Voltage Range	140~1000V
Max. Input Current	26A/26A
Max. PV Isc	36A/36A
Nominal Grid Voltage	3/N/PE,380/400V
Max. Output Current	3x35.1A
Nominal Grid Frequency	50/60Hz
Nominal Output Power	22000W
Max. Output Power	24200VA
Power Factor	1(adjustable+/-0.8)
Ingress Protection	IP65
Operating Temperature Range	-30°C~+60°C
Protective Class	Class I
Made in China	

Manufacturer : Shenzhen SOFARSOLAR Co.,Ltd.
Address : 401, Building 4, AnTongDa Industrial Park,
District 68, XingDong Community,XinAn Street,
BaoAn District, Shenzhen, China
VDE0126-1-1,VDE-AR-N4105,G99,IEC61727
IEC62116,UTE C15-712-1,AS4777



SOFAR 22KTLX-G3



Model No: SOFAR 24KTLX-G3

Max. DC Input Voltage 1100V

Operating MPPT Voltage Range 140~1000V

Max. Input Current 26A/26A

Max. PV Isc 36A/36A

Nominal Grid Voltage 3/N/PE,380/400V

Max. Output Current 3x38.3A

Nominal Grid Frequency 50/60Hz

Nominal Output Power 24000W

Max. Output Power 26400VA

Power Factor 1(adjustable+/-0.8)

Ingress Protection IP65

Operating Temperature Range -30°C~+60°C

Protective Class Class I

Made in China

Manufacturer : Shenzhen SOFARSOLAR Co.,Ltd.

Address : 401, Building 4, AnTongDa Industrial Park,

District 68, XingDong Community,XinAn Street,

BaoAn District, Shenzhen, China

VDE0126-1-1,VDE-AR-N4105,G99,IEC61727

IEC62116, UTE C15-712-1, AS4777



SOFAR 24KTLX-G3

Note:

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation

Test item particulars			
Equipment mobility	<input type="checkbox"/> movable <input checked="" type="checkbox"/> fixed	<input type="checkbox"/> hand-held <input type="checkbox"/> transportable	<input type="checkbox"/> stationary <input type="checkbox"/> for building-in
Connection to the mains	<input type="checkbox"/> pluggable equipment <input checked="" type="checkbox"/> permanent connection	<input type="checkbox"/> direct plug-in <input type="checkbox"/> for building-in	
Environmental category	<input checked="" type="checkbox"/> outdoor unconditional	<input type="checkbox"/> indoor conditional	
Over voltage category Mains	<input type="checkbox"/> OVC I <input type="checkbox"/> OVC II <input checked="" type="checkbox"/> OVC III <input type="checkbox"/> OVC IV		
Over voltage category PV.....	<input type="checkbox"/> OVC I <input checked="" type="checkbox"/> OVC II <input type="checkbox"/> OVC III <input type="checkbox"/> OVC IV		
Mains supply tolerance (%).....	According to the specified supply range.		
Tested for power systems	TN		
IT testing, phase-phase voltage (V)	N/A		
Class of equipment	<input checked="" type="checkbox"/> Class I <input type="checkbox"/> Not classified	<input type="checkbox"/> Class II	<input type="checkbox"/> Class III
Mass of equipment (kg)	See model list.		
Pollution degree.....	PD3(Inside PD2)		
IP protection class.....	IP65		
.....			
Possible test case verdicts:			
- test case does not apply to the test object.....	N/A		
- test object does meet the requirement	P (Pass)		
- test object was not evaluated for the requirement:	N/E		
- test object does not meet the requirement.....	F (Fail)		
Testing			
Date of receipt of test item	Oct. 14, 2020		
Date (s) of performance of tests.....	Oct. 14, 2020 to Nov. 27, 2020		

General remarks:

"(See Enclosure #)" refers to additional information appended to the report.

"(See appended table)" refers to a table appended to the report.

The tests results presented in this report relate only to the object tested.

This report shall not be reproduced except in full without the written approval of the testing laboratory.

List of test equipment must be kept on file and available for review.

Additional test data and/or information provided in the attachments to this report.

Throughout this report a comma / point is used as the decimal separator.

Determination of the test results includes consideration of measurement uncertainty from the test equipment and methods.

Manufacturer's Declaration per sub-clause 4.2.5 of IECEE 02:

The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided

- Yes
 Not applicable

When differences exist; they shall be identified in the General product information section.

**Name and address of factory (ies)..... : Dongguan SOFAR SOLAR Co., Ltd.
1F - 6F, Building E, No. 1 JinQi Road, Bihu Industrial Park, Wulian Village, Fenggang Town, Dongguan City.**

General product information:Brief description:

The PCE under test (EUT) is Solar Grid-tied Inverter. During inverter, which convert the variable DC power generated from the photovoltaic (PV) arrays to the stable utility AC power which can be fed into the commercial electrical grid.

Model Number	SOFAR 15KTLX-G3	SOFAR 17KTLX-G3	SOFAR 20KTLX-G3	SOFAR 22KTLX-G3	SOFAR 24KTLX-G3
Input (DC)					
Max. input voltage	1100Vdc				
Rated input voltage	600Vdc				
MPPT operating voltage range	140V~1000V				
Full load MPPT Voltage Range	420V~850V	450V~850V	480V~850V	510V~850V	540V~850V
Number of MPP trackers	2/2				
Number for DC inputs	2 for each MPPT				
Max. input current per MPPT	26A/26A	26A/26A	26A/26A	26A/26A	26A/26A
Max. input short circuit current per MPPT	36A/26A	36A/36A	36A/36A	36A/36A	36A/36A
Output(AC)					
Rated power	15kW	17kW	20kW	22kW	24kW
Max. AC power	16.5kVA	18.7kVA	22kVA	24.2kVA	26.4kVA
Max. output current	23.9A	27.1A	31.9A	35.1A	38.3A
Nominal grid voltage	3/N/PE, 230V/400Vac, 220V/380Vac				
Grid voltage range	310Vac-480Vac				
Nominal frequency	50 / 60Hz				
General Data					
Ambient temperature range	-30°C ~+60°C				
Degree of protection	IP65				
Weight	20kg	22kg	22kg	23kg	23kg
Dimension	513*425*189mm				


The model SOFAR 15KTLX-G3, SOFAR 17KTLX-G3, SOFAR 20KTLX-G3, SOFAR 22KTLX-G3 and SOFAR 24KTLX-G3 are almost identical in hardware, except the Communication control (CSB or COM), DC input channel and Fuse board for PV input. The difference as below.

	SOFAR 15KTLX-G3	SOFAR 17KTLX-G3	SOFAR 20KTLX-G3 SOFAR 22KTLX-G3 SOFAR 24KTLX-G3
BUS film capacitor	4 pcs 110uF/550V	6 pcs 110uF/550V	
Inverter IGBT	6 pcs 40A/1200V	6 pcs 75A/1200V	
fan	1 pcs		2pcs

Unless otherwise specified, all the tests were conducted on the basic model of SOFAR 24KTLX-G3

The input and output are protected by varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high-power switching bridge and two relays. This assures that the opening of the output circuit can operate in case of single fault.

Block Diagram:



Throughout the test report following abbreviations may be used:

- input	i/p	- Test repeated, similar result(3 times)	TRSR
- output	o/p	- No indication of dielectric breakdown	NB
- short-circuited	s-c	- Cheesecloth remained intact	NC
- overloaded	o-l	- Tissue paper remained intact	NT
- open-circuited	o-c	- No hazards	NH
- normal conditions	N.C.	- The PCE can recover to operate automatically after removing the abnormal condition	RO
- single fault conditions	SFC	- functional insulation	FI
- between parts of opposite polarity	BOP	- basic insulation	BI
- internal protection operated	IPO	- supplementary insulation	SI
- Component damage (list damaged component)	CD	- double insulation	DI



- No component damaged	NCD	- reinforced insulation	RI
- Power Conversion Equipment Indicate used abbreviations (if any)	PCE	- Equipment Under Test	EUT

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
--------	--------------------	-----------------	---------

4	General safety requirements		-
4.1	General		P
4.2	Earthing requirements		P
5	Protection against electric shock		-
5.1	General		-
5.1.1	Introductory remark :		P
5.1.2	Protection from contact with hazardous live parts		P
5.1.2.1	General		P
5.1.2.2	Insulation		P
5.1.2.3	Equipment case and barriers	IP65 enclosure and no opening in the case.	-
	Hazardous live parts..... :	Hazardous live parts were separated from the accessible part.	P
	Top surfaces of barriers accessible in normal use. :	No opening of EUT and the cover only can be removed with tool by trained personnel.	P
	Protection in service access areas :		P
	- with rigid test finger and a force of 10 N :		N/A
	- with jointed test finger :		N/A
5.1.2.4	Hazardous live terminations using stranded wire		P
5.1.3	Discharge of capacitors		-
	Compliance checked by calculation :		P
	Measured voltage (V); time-constant (s) :		P
	Residual charge (μ C) :		P
5.1.4	Protective impedance	No protective impedance used.	-
	Requirements of 5.1.5.3.2 in normal and to level of 5.2.4.1.2 in single fault condition		N/A
	The protective impedance consists of one or more of the following:		N/A
	- appropriate high-integrity single component :		N/A
	- combination of components :		N/A
	- combination of basic insulation and a current- or voltage-limiting device :		N/A
	Voltage test for double/reinforced insulation :		N/A

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
	Components and associated basic insulation checked after a single-fault condition assessment or test according to 10.6.5.5.....:		N/A
	Clearance, creepage distance between terminations of the impedance meet requirements of double or reinforced insulation of Annex C of this standard and 6.7 of IEC 61010-1:2010		N/A
5.1.5	Accessible parts		-
5.1.5.1	General	All accessible metal parts were earthed and separated from live parts by basic insulation. All external accessible circuit were separated from live parts by reinforce insulation.	P
5.1.5.2	Determination of accessible parts		-
5.1.5.2.1	General		P
	Normal operational use, with or without the aid of a too lwhich will increase the accessibility..... :	See 5.1.5.2.2 to 5.1.5.2.4 or test by inspection	P
5.1.5.2.2	General examination	No opening of EUT and the cover only can be removed with tool by trained personnel.	-
	Test with jointed test finger.....:		N/A
	Test with rigid test finger (force of 10 N)		N/A
5.1.5.2.3	Openings above parts, enclosed by the case, which are hazardous live	No opening of EUT and the cover only can be removed with tool by trained personnel.	-
	Test with test pin (100mm, Ø4mm)		N/A
5.1.5.2.4	Openings for pre-set controls	No opening of EUT and the cover only can be removed with tool by trained personnel.	-
	Test with test pin (100mm, Ø3mm)		N/A
5.1.5.2.5	ELV rated or live parts accessible when cover removed		-
	Removing the cover without tools	No opening of EUT and the cover only can be removed with tool by trained personnel.	N/A
	- Symbol 14		N/A
	- Symbol 12		N/A
5.1.5.2.6	Wiring terminals		-
	IP1X according to 5.1 of IEC 60529		P
	- Symbol 12		P
5.1.1.3	Permissible limits for accessible parts		-

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
5.1.5.3.1	General : Values of 5.1.5.3.2 in normal operational condition and nor those of 5.2.4.1.2 in single-fault condition.		P
5.1.5.3.2	Values under normal conditions a) Voltage limits less than 33 V r.m.s. or 70 V d.c. : for wet locations voltage limits less than 25 V r.m.s. or 37.5V d.c. :	Communication port was accessible conductive part that voltage less than 25 V r.m.s. or 37.5 V d.c.	P
	Voltages are not hazardous live the levels of: b) Current less than 0,5 mA r.m.s. for sinusoidal, 0,7 mA peak non-sinusoidal or mixed frequencies or 2 mA d.c. when measured with measuring circuit A.1 or A.2 if less than 100 Hz for WET LOCATIONS measuring circuit A.4 used	Communication port.	P
	70 mA r.m.s. when measured with circuit A.3 for higher frequencies :		N/A
	c) Levels of capacitive charge or energy less: 1) 45 µC for voltages up to 15 kV peak or d.c. or line A of Figure 3 of IEC 61010-1:2010 2) 350 mJ stored energy for voltages above 15 kV peak or d.c.		N/A
5.1.6	Bonding to the protective conductor		-
5.1.6.1	Insulation between live parts and accessible conductive parts Accessible conductive parts : Unearthed accessible conductive parts: - separated from by double insulation or reinforced insulation, or..... : - Equipment of class I protection..... :		P
5.1.6.2	Protective bonding Accessible conductive parts bonded, or - EVL circuit protected in case of direct contact of 5.1.5..... : - magnetic cores are used..... : - parts of small dimensions separated from hazardous live parts by at least basic insulation		P
5.1.6.3	Bonding of parts connected to the protective conductor..... :		P

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
5.1.6.4	Protection against corrosion		P
5.1.6.5	Interruption of protective bonding.....	No such protective bonding.	N/A
5.1.7	Protective conductor connection		P
	- means of connection		P
	- suitable for use.....		P
	- not be used as a part of the mechanical assembly		P
5.1.8	High leakage current		N/A
5.1.9	Solid insulation		-
5.1.9.1	General		P
5.1.9.2	Requirements		P
5.1.10	Clearances and creepage distances		-
5.1.10.1	General		P
5.1.10.2	Clearances		P
5.1.10.2.1	General		P
5.1.10.2.2	Clearances for primary circuits	(see appended table 10.6.3)	P
5.1.10.2.3	Clearances for non-primary circuits.....	(see appended table 10.6.3)	P
5.1.10.2.4	Creepage distances.....	(see appended table 10.6.3)	P
5.1.11	Functional earthing		P
	Requirements:		P
	- Connection to protective conductor terminal permitted		P
	- separated by a functional insulation.....		P
	- separated from parts at hazardous voltage by		P
	1) double insulation or reinforced insulation : or		P
	2) a protectively earthed screen or another protectively earthed conductive part, separated from parts at hazardous voltages by at least basic insulation:		P
5.2	Single-fault conditions		-
5.2.1	Testing in single-fault condition	(see appended table 5.2)	P
	not risk of electric shock or fire after a single-fault test.....		P
5.2.2	Application of single-fault condition		P
5.2.2.1	General		P

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
5.2.2.2	Protective impedance :		N/A
5.2.2.3	Transformers :		P
5.2.2.4	Outputs :		P
5.2.2.5	Insulation between circuits and parts :		P
5.2.2.6	Primary circuits and hazardous voltage non-primary circuits :		P
5.2.2.7	Overloads :		P
5.2.2.8	Intermittently rated resistors :	No such resistors used.	N/A
5.2.2.9	DC inputs :		P
5.2.3	Duration of tests :		P
5.2.4	Compliance		-
5.2.4.1	Compliance with requirements for electric shock protection		-
5.2.4.1.1	General :		P
5.2.4.1.2	Values in single-fault condition	(see appended table 5.2)	P
	a) Voltage limits less than 55 V r.m.s. or 140 V d.c. :		P
	- For temporary voltages, limits less than 55 V r.m.s. and 78 V peak or 140 V d.c. :		P
	- for wet locations voltage limits less than 33V r.m.s. or 70d.c. :	Communication port was accessible conductive part that voltage less than 33 V r.m.s. or 70 V d.c.	P
	b) Current less than 3,5 mA r.m.s. for sinusoidal, 5 mA peak non-sinusoidal or mixed frequencies or 15 mA d.c. when measured with measuring circuit A.1 or A.2 if less than 100 Hz or 500mA r.m.s (Figure with $RB = 75 \Omega$ Relates to possible burns in the frequency range 30 kHz to 500 kHz)		N/A
	- for wet locations measuring circuit A.4 used (with $RS = 375 \Omega$ (instead of $1\ 500 \Omega$) :		N/A
	- Current less than 3,5 mA r.m.s. for sinusoidal, 5 mA peak non-sinusoidal or mixed frequencies or 15 mA d.c :		N/A
	c) capacitance level is that defined in Figure 3. curve B in IEC 61010-1:2010 :		N/A
5.2.4.2	Compliance with requirements for temperature protection :		P
5.2.4.3	Compliance with requirements for protection against the spread of fire :		P

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
5.2.4.4	Compliance with requirements for hazardous gases and chemicals..... :		P
5.2.4.5	Compliance with requirements for mechanical protection		P
6	Mechanical aspects		-
6.1	Protection against mechanical hazards		-
6.1.1	Stability :		P
6.1.2	Moving parts :		P
6.1.3	Edges and corners :		P
6.2	Mechanical requirements		P
	Mechanical tests requirements of 10.6.2.1 to 10.6.2.4. :		P
	Higher severity levels :		N/A
6.3	Mechanical security of terminations	(see Annex E)	P
7	Flammability and resistance to fire		-
7.1	General		P
	reducing the risk of fire by one of the following means:		-
	- Eliminating or reducing the sources of ignition within the equipment..... :		P
	- Reducing the amount of combustible (or flammable) materials within the equipment :		P
	- Containment of a fire within the equipment :		P
7.2	Rationale		P
	Risk of fire in normal and single fault condition..... :		P
	In order for a risk of fire within the equipment to exist, all three of the following basic elements shall exist:		P
	- The equipment circuits shall have sufficient power or energy to be an ignition source.. :		P
	- There shall be oxygen present (air is about 21 % oxygen)		P
	- There shall be combustible materials present to support the combustion process		P
	Conformity is checked by minimum one or a combination of the following (see Figure 1):		P
	- Equipment temperature limits of 7.3.1		P

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
	- Single Fault test of 7.11 and 10.6.5.5		P
	- Minimization of fire risk and reducing sources of ignition of 7.4 and 7.4.2.....		P
	- Containment of a fire within equipment of 7.10		P
7.3	General hazards from overheating and fire		-
7.3.1	Equipment temperature limits:		P
	- In normal conditions..... : (See appended table 7.3)		P
	- In single-fault condition (limits of clause 7.11)	(See appended table 5.2)	P
	Symbol 13 of Table 10..... :		P
	Symbol 14 of Table 10..... :		P
7.3.2	Hazardous gases and chemicals	No gases and chemicals used.	-
	Manufacturer's documentation		N/A
7.4	Minimization of fire risk		-
7.4.1	General:		P
	Critical components of primary circuits and circuits exceeding ELV voltage limits. Compliance with Annex D		P
7.4.2	Eliminating or reducing the sources of ignition within the equipment		P
	a) Either 1) or 2)		P
	1) Limited-energy circuit as specified in 7.12		P
	2) Insulation between parts at different potentials, compliance with clause 7.11		P
	b) circuits designed to produce heat in compliance with clause 5.2		N/A
	Circuits not classified as limited-energy circuits. Method i) or ii) below shall be used.		P
	i) Testing in the single-fault conditions in compliance with clause 5.2		P
	ii) Verifying as in 7.11 that if a fire occurs it will be contained within the equipment.....		P
7.5	Cabling and fusing		P
	Manufacturer's recommendations:		P
	- Connection cables: minimum cross-section and voltage rating		P
	- Protection devices		P
7.6	Flammability of materials and components		-

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
7.6.1	General		P
	Conformity is checked by inspection		P
	Tests in compliance with IEC 60695-11-10.....		P
7.6.2	Materials for components and other parts inside fire enclosures		P
7.6.3	Materials for fire enclosures		P
7.6.4	Materials for components and other parts outside fire enclosures		P
7.7	Fire ignition sources		P
7.8	Conditions for a fire enclosure	Metal enclosure used.	-
7.8.1	General		P
7.8.2	Parts requiring a fire enclosure		P
7.8.3	Parts not requiring a fire enclosure		P
7.9	Requirements for primary circuits and circuits exceeding ELV limits		P
7.10	Fire enclosures and flame barriers		-
	Enclosure meets following requirements:	No opening in the metal enclosure.	P
	Bottom:		P
	- no openings, or		P
	- to the extent in Figure 3, shall be constructed with baffles as specified in Figure 2, or		N/A
	- be made of metal, perforated as specified in Table 6, or		N/A
	- be a metal screen with a mesh not exceeding 2 mm × 2 mm centre to centre and a wire diameter of at least 0,45 mm ..		N/A
	The sides shall have no openings within the area that is included within the inclined line C in Figure 3 or.....		N/A
	Case and baffle or flame barrier		N/A
7.11	Assessment of the fire risk due to a single-fault condition		-
7.11.1	Guidelines for maximum acceptable temperatures when subjecting a circuit or component to a single-fault condition		P
7.11.2	Temperature of windings under a normal condition or a single-fault condition	(See appended table 7.3 and 5.2)	P

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
7.11.3	Compliance of equipment with requirements for protection against the spread of fire		P
7.12	Limited-energy circuit	Not applied.	N/A
	a) Potential not more than 33 r.m.s. or 70 V dc		N/A
	b) Current limited by one of following means:		N/A
	3) Inherently or by impedance (see Table 8); or		N/A
	4) Overcurrent protective device (see Table 9); or		N/A
	5) A regulating network limits also in single fault condition (see Table 8)		N/A
	c) Is separated by at least basic insulation		N/A
	Fuse or a nonadjustable electromechanical device is used		N/A
8	General and fundamental design requirements for safety		-
8.1	Climatic conditions for safety		P
	Environmental ranges declared by the manufacturer:		P
	- temperature, operation and storage..... :		P
	- humidity, non-condensing		P
	- atmospheric pressure		P
8.2	Electrical connections		P
	- electrical terminations and connection points..... :		P
	- protective bonding..... :	(See appended table 10.6.4.5)	P
	- wires and cables		P
	- Conductors		P
	- electrical connections		P
8.3	Components		-
8.3.1	General	(See appended table 8.3)	P
8.3.2	High-integrity part or component		P
8.4	Connection to telecommunication networks Requirements according to IEC 62151	Not connect to telecommunication networks	N/A
8.5	Connection to other equipment Requirements in accordance with Table A.1		P
8.6	Laser sources Requirements in accordance with IEC 60825-1	No such device.	N/A
8.7	Explosion		-
8.7.1	General		P

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
8.7.2	Components at risk of explosion		-
8.7.2.1	General : (see clause 5.2.4.5)		P
8.7.2.2	Batteries	No battery used	N/A
	Compliance with Annex F :		N/A
	Marking and warning :		N/A
	Rechargeable batteries :		N/A
	Battery compartment :		N/A
	Batteries intended to be replaced by the user..... :		N/A
9	Marking, documentation and packaging		-
9.1	Marking		-
9.1.1	General		P
	Removable parts :		P
	Symbols according to table 9.. :		P
	Rack or panel equipment :		P
	Voltages, currents, frequency and their tolerances according to IEC 60255-6..... :		P
9.1.2	Identification		-
	Equipment is identified on the equipment by :		P
	a) Manufacturer's or supplier's name or trademark		P
	b) Model or type reference :		P
	Manufacturing location identified :		P
9.1.3	Auxiliary supplies, VT, CT, I/O9	No such device.	-
9.1.3.1	General requirements for marking		-
	For marking the following should be taken into account:		N/A
	a) a.c. – with symbol 2 of Table 9 and rated frequency or frequency range :		N/A
	b) d.c. – with symbol 1 of Table 9 :		N/A
	c) symbol 3 of Table 9 on equipment for a.c. and d.c. supply		N/A
	d) symbol 4 of Table 9 on equipment for 3 phase a.c. supply		N/A
	e) a hyphen (-) shall be used to separate the lower and upper nominal voltages, for example, 125 V-230 V		N/A
	f) for measurands either a hyphen (-) or an ellipse (...) shall be used to separate the lower and upper voltages..... :		N/A

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
	g) for selectable voltage or current markings:		N/A
	- the lower and upper selectable values shall be separated by means of a solidus, i.e. forward slash (/) :		N/A
	- voltages or frequencies where switching is automatic then the markings shall be according to symbol 15 of Table 9 or the word "AUTO" :		N/A
	- operating voltage achieved using an external, separate device, use +EXT.R. :		N/A
	h) the burden in watts (active power) or volt-amperes (apparent power) or the rated input current, with all accessories or plug-in modules connected :		N/A
	The documentation shall specify the burden..... :		N/A
	The measured value shall not exceed the marked value by more than 10 % :		N/A
	i) the rated supply voltage(s) or the rated supply voltage range :		N/A
	- voltage range more than 20 % of the mean value..... :		N/A
	- different rated supply voltages :		N/A
9.1.3.2	Auxiliary supply		-
	The following information shall be provided:		-
	a) on the equipment and in the documentation..... :		N/A
	- -a.c. and/or d.c. supply		N/A
	- the rated values		N/A
	b) in the documentation..... :		N/A
	- the burden..... :		N/A
9.1.3.3	Measurands		-
	The following information shall be provided:		N/A
	a) on the equipment and in the documentation..... :		N/A
	- the nominal values, for example, voltage, current, frequency..... :		N/A
	b) in the documentation..... :		N/A
	- the burden..... :		N/A
	- the overload withstand		N/A
9.1.3.4	Inputs		-
	The following information shall be provided in the documentation		N/A

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
	a) a.c. and/or d.c. supply		N/A
	b) the rated values		N/A
	c) burden on the supply input		N/A
9.1.3.5	Outputs		-
	The following information shall be provided in the documentation		N/A
	a) the kind of output, for example, relay, optocoupler etc.....		N/A
	b) burden on the supply input		N/A
	c) the switching capability on/off		N/A
	d) the switching voltage		N/A
	e) the permissible current, continuous value and short time value for 1 s		N/A
	f) withstand voltage across open contacts.....		N/A
9.1.4	Fuses	No such device used.	-
	Operator replaceable fuse marking		N/A
	Not replaceable by the user		N/A
9.1.5	Measuring circuit terminals		-
	Marking shall be adjacent to the measuring terminals		N/A
	If insufficient space, symbol 14 used.....		N/A
	Symbol 14 and/or 12 of Table 9		N/A
	Voltage 33 V a.c. or 70 V d.c.		N/A
	Exceptions		N/A
9.1.6	Terminals and operating devices		-
	Safety markings		P
	AC or d.c. supply		P
	Operating device markings		P
	Functional earth terminals		N/A
	Protective conductor terminals.....		P
	Marking place		P
	Plug/socket device.....		P
	Marking for accessible terminals.....		P
	Marking for lasers or high-intensity infra-red diodes of class 2 rating or higher		N/A
9.1.7	Equipment protected by double or reinforced insulation.....		N/A

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
9.1.8	Batteries		-
9.1.8.1	Replaceable batteries..... : Battery accessible to the user..... : Battery not accessible to the user..... : Polarity of the battery..... :	No battery used. N/A N/A N/A	N/A
9.1.8.2	Charging		N/A
9.1.9	Test voltage marking		N/A
9.1.10	Warning markings Rack- or panel-mounted equipment	Wall mounted equipment.	P
	Access in normal use		P
	Equipment documentation		P
	Batteries		N/A
	Warning markings size		N/A
9.1.11	Marking durability		P
9.2	Documentation		-
9.2.1	General		P
	Explanation of warning symbols		P
	Protective conductor connections		P
	Equipment ratings, operating instructions and installation instructions		P
	Information specified in 9.2.2 to 9.2.5.....		P
	Intended use		P
9.2.2	Equipment ratings	See rating label	-
9.2.2.1	General Overvoltage category	OVC III for MAINS; OVC II for PV	P
	Rated voltage(s) or voltage range(s) (V)		P
	Rated frequency or rated frequency range (Hz)		P
	Rated power (W) rated current (mA or A)		P
	Nominal functional value		P
	Input and output connections		P
9.2.2.2	Fuses and external protective devices		-
	Fuse ratings		N/A
	External device	According to user manual the circuit breaker should use in final Installation.	P

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
9.2.2.3	Environmental requirement		-
	IP rating..... : IP65		P
	Pollution degree : PD2 (Inside); PD3 (Outside)		P
	Insulation class..... : Class I		P
9.2.3	Equipment installation		-
	Safe mounting..... :		P
	Protective earthing..... :		P
	Ventilation requirements..... :		P
	Digital input circuits and output relays		N/A
	Wire..... :		P
	External devices		P
9.2.4	Equipment commissioning and maintenance		-
	Fault-finding and repair		P
	Equipment part		P
	Safe methods for changing and disposal of:		-
	Accessible fuses..... :		N/A
	Replaceable batteries..... :		N/A
	Re-charging and/or replacement for re-chargeable batteries		N/A
	Fibre-optic output devices		N/A
9.2.5	Equipment operation		-
	Operating instructions:		-
	- CT circuits		N/A
	- Responsibility of the user		P
	- pictures and symbols used		P
9.3	Packaging		P
10	Type tests and routine tests		-
10.1	General		P
10.2	Safety type tests		P
10.3	Routine testing or sample testing		N/A
10.4	Conditions for testing..... :	Considered.	P
10.5	Verification procedure..... :	Considered.	P
10.6	Tests		-
10.6.1	Climatic environmental tests		-

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
10.6.1.1	Dry-heat test – operational. Tests according to IEC 60255-1	Test Bd of IEC60068-2-2 60°C, 16h.	P
10.6.1.2	Cold test – operational. Tests according to IEC 60255-1	Test Bd of IEC60068-2-1 -30°C, 16h.	P
10.6.1.3	Dry heat test at maximum storage temperature. Tests according to IEC 60255-1	Test Bb of IEC60068-2-2 60°C, 16h	P
10.6.1.4	Cold test at minimum storage temperature. Tests according to IEC 60255-1	Test Bd of IEC60068-2-1 -40°C, 16h	P
10.6.1.5	Damp-heat test. Tests according to IEC 60255-1	Test Cab of IEC60068-2-78 40°C, 93%, 10d	P
10.6.1.6	Cyclic temperature with humidity test. Tests according to IEC 60255-1	Test Db: IEC 60068-2-30	P
10.6.2	Mechanical tests		-
10.6.2.1	Vibration Tests according to IEC 60255-21-1.....	1. Frequency: 10-150Hz; 2. Acceleration:1g; 3. Cycle Time:8 min / axis, total 20 cycles / axis; 4. Direction: X, Y ,Z axis.	P
10.6.2.2	Shock Tests according to IEC 60255-21-2.....	1. Acceleration: 15g 2. Duration: 11ms; 3. Times: 3 times / direction, total 18 times, 4. Direction: ±X, ±Y , ±Z axis.	P
10.6.2.3	Bump Tests according to IEC 60255-21-2.....	1. Acceleration: 10g 2. Duration: 16ms; 3. Number: 1000 times / direction. 4. Direction: ±X, ±Y , ±Z axis.	P
10.6.2.4	Seismic Tests according to IEC 60255-21-3.....	1.Frequency: 1-35Hz; 2. Cross-over Frequency: 8- 9Hz; 3. Horizontal (X, Y): Peak Displacement : 3.5mm; Acceleration: 1.0g; 4. Vertical (Z); 5. Cycle time: 10 min/ axis; 6. Direction: X, Y ,Z axis.	P
10.6.2.5	Accessible parts test	(See clause 5.1.5)	P
10.6.2.6	Dust/water ingress protection Tests according to IEC 60529	IP 65	P

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
10.6.3	Clearances and creepage distances		-
	Compliance with Annex C : (see appended table 10.6.3)		P
	Compliance with clause 5.1.10.2.2..... : (see appended table 10.6.3)		P
	Transient suppressor used to reduce the overvoltage. Tests according to IEC 60255-26..... :		N/A
10.6.4	Safety-related electrical tests		-
10.6.4.1	General :		P
10.6.4.2	Impulse voltage test		-
10.6.4.2.1	General :		P
10.6.4.2.2	Test procedures..... :		P
10.6.4.2.3	Waveform and generator characteristics..... :		P
10.6.4.2.4	Selection of impulse test voltage..... :		P
10.6.4.2.4.1	General :		P
	Altitudes(m) :		P
10.6.4.2.4.2	Equipment to tested at 5 kV peak nominal		P
10.6.4.2.4.3	Equipment to tested at 1 kV peak nominal		N/A
	- auxiliary (power supply) circuits :		N/A
	- equipment power supply :		N/A
	- I/O circuits :		N/A
10.6.4.2.5	Performing of tests		P
	test performed between the followings part: - between each circuit specified for the same impulse voltage	(see appended table 10.6.4.2)	P
	- between independent circuits		P
	- across the terminals of a given circuit..... :		P
	Equipment with an insulated case..... :		P
10.6.4.2.6	Test acceptance criteria		-
	During the tests		P
	After the tests		P
10.6.4.2.7	Repetition of the impulse voltage test		P
10.6.4.3	AC or d.c. dielectric voltage test		-
10.6.4.3.1	General		P

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
10.6.4.3.2	Performing the dielectric voltage test : (see appended table 10.6.4.3)		-
10.6.4.3.2. 1	Type tests		-
	test performed between the followings part:		P
	- between each circuit and the accessible conductive parts :		P
	- between independent circuits :		P
	- dielectric voltage withstand, for open metallic contacts..... :		P
10.6.4.3.2. 2	Routine tests..... :		N/A
10.6.4.3.2. 3	Routine tests by sampling :		N/A
10.6.4.3.3	Value of the dielectric test voltage..... :		P
10.6.4.3.4	Test voltage source :		P
10.6.4.3.5	Test method..... :		P
10.6.4.3.6	Test acceptance criteria :		P
10.6.4.3.7	Repetition of the dielectric voltage test..... :		P
10.6.4.4	Insulation resistance..... : (See appended table 10.6.4.4)		P
10.6.4.5	Protective bonding tests	(See appended table 10.6.4.5)	P
10.6.5	Electrical environment and flammability		-
10.6.5.1	Maximum temperature of parts and materials..... :		P
10.6.5.2	Flammability of insulating materials, components and fire enclosures : (See appended table 7.6)		N/A
10.6.5.3	Thermal short-time test		-
	Overvoltage :		N/A
	Overcurrent..... :		N/A
10.6.5.4	Output relay parameters Parameters in according to IEC 60255-26 :		N/A
10.6.5.5	Single-fault condition :		N/A
10.6.6	Reverse polarity and slow ramp test : (See appended table 5.2)		P

IEC 60255-27

Clause	Requirement – Test	Result – Remark	Verdict
A	ANNEX A, ISOLATION CLASS REQUIREMENTS AND EXAMPLE DIAGRAMS (NORMATIVE) (see 5.1.2; 5.1.6.2; 5.1.10)		P
B	ANNEX B, RATED IMPULSE VOLTAGES (NORMATIVE) (see 5.1.2.2)		P
C	ANNEX C, GUIDANCE FOR THE DETERMINATION OF CLEARANCE, CREEPAGE DISTANCE AND WITHSTAND VOLTAGES (NORMATIVE) (see 5.1.2.2; 5.1.4; 5.1.10; 10.6.3)		P
D	ANNEX D, COMPONENTS (INFORMATIVE) (see 7.4.1; 8.3; 8.7.1)		P
E	ANNEX E, EXTERNAL WIRING TERMINATIONS (NORMATIVE) (see 6.3)		-
E.1	General		P
E.2	Permanently connected equipment		P
	a) a set of terminals; or		P
	b) a non-detachable power supply cable.		N/A
	terminals :		P
	screws and nuts :		P
	power supply cables:		N/A
	a) two independent fixings..... :		N/A
	b) mechanical fixing of the cables :		N/A
E.3	Conductors		N/A
	Connection of conductors in compliance with Table E1. :		N/A
E.4	Terminals		P
	Contact pressure size in compliance with Table E2. :		P
	Terminals contact pressure..... :		P
	Slipping of the conductor..... :		P
	Terminals shall be so fixed that when the means of clamping the conductor is tightened or loosened:		P
	a) the terminal itself does not work loose :		P
	b) internal wiring is not subjected to stress..... :		P
	Ordinary non-detachable power supply cables :		N/A
	c) creepage distances and clearances are not reduced below the values specified in Annex C. :		P

**IEC 60255-27**

Clause	Requirement – Test	Result – Remark	Verdict
--------	--------------------	-----------------	---------

F	ANNEX F, EXAMPLES OF BATTERY PROTECTION (INFORMATIVE) (see 8.7.2.2)		N/A
---	---	--	-----

IEC 60255-27

5.2		TABLE: Fault condition tests						P
No.	component No.	fault	test voltage (V)	test time	fuse No.	fuse current (A)	Comments/ Observation	
1	R5	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.	
2	R12	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.	
3	R3	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message: "HwPVOCP". No damaged. No hazard.	
4	R852	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.	
5	U1 pin1-3	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.	
6	Q50	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message: "HwPVOCP". No damaged. No hazard.	
7	CTF4	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message: "VbusRmsUnbalance". No damaged. No hazard.	
8	CTF9	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message: "VbusRmsUnbalance". No damaged. No hazard.	
9	RL1	Short before start-up	Input:230V Output:850V	10min.	--	--	Inverter did not start-up. Error message: "RelayTestFail". No damage. No hazard.	
10	RL2	Short before start-up	Input:230V Output:850V	10min.	--	--	Inverter did not start-up. Error message: "RelayTestFail". No damage. No hazard.	
11	RL3	Short before start-up	Input:230V Output:850V	10min.	--	--	Inverter did not start-up. Error message: "RelayTestFail". No damage. No hazard.	



IEC 60255-27

12	RL4	Short before start-up	Input:230V Output:850V	10min.	--	--	Inverter did not start-up. Error message:"RelayTestFail". No damage. No hazard.
13	RL5	Short before start-up	Input:230V Output:850V	10min.	--	--	Inverter did not start-up. Error message:"RelayTestFail". No damage. No hazard.
14	RL6	Short before start-up	Input:230V Output:850V	10min.	--	--	Inverter did not start-up. Error message:"RelayTestFail". No damage. No hazard.
15	R56	Open	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
16	R58	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
17	R95	Open	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
18	R96	Open	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
19	R97	Open	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
20	R101	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
21	R102	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
22	R103	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
23	R168	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"IsoFault". No damaged. No hazard.
24	R169	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
25	R22	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"IsoFault". No damaged. No hazard.
26	R23	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.



IEC 60255-27

27	R186	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"IsoFault". No damaged. No hazard.
28	R188	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
29	R193	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"IsoFault". No damaged. No hazard.
30	R194	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
31	R174	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"IsoFault". No damaged. No hazard.
32	R175	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
33	R212	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"IsoFault". No damaged. No hazard.
34	R207	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
35	T1 pin6-8	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
36	T1 pin3-5	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
37	T1 pin1-2	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
38	CAE1	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
39	CAE3	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
40	EC19	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.

IEC 60255-27

41	R147	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"AFCIFault". No damaged. No hazard.
42	R421	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"AFCIFault". No damaged. No hazard.
43	R426	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"AFCIFault". No damaged. No hazard.
44	C275	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"AFCIFault". No damaged. No hazard.
45	C270	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"AFCIFault". No damaged. No hazard.
46	R146	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"AFCIFault". No damaged. No hazard.
47	R413	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"AFCIFault". No damaged. No hazard.
48	U5 pin12-14	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"AFCIFault". No damaged. No hazard.
49	U5 pin10-8	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"AFCIFault". No damaged. No hazard.
50	C252	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"AFCIFault". No damaged. No hazard.

IEC 60255-27

51	R411	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message: "AFCIFault". No damaged. No hazard.
52	T5 Pin7-8-9-10-11-12	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
53	T5 Pin5-6	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
54	T5 Pin3-4	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
55	T5 Pin17-18	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
56	CAE5	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
57	CAE7	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
58	CAE8	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
59	CAE10	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
60	CAE11	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
61	CAE12	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
62	CAE13	Short	Input:230V Output:850V	10min.	--	--	Non-display, Auxiliary source hiccup protections. No damaged. No hazard.
63	R515	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
64	R517	Open	Input:230V Output:850V	10min.	--	--	MPPT1 operation failure, MPPT2 normal operation. Inverter operated normally. No damaged. No hazard.
65	R522	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.



IEC 60255-27

66	R524	Open	Input:230V Output:850V	10min.	--	--	MPPT1 operation failure, MPPT2 normal operation. Inverter operated normally. No damaged. No hazard.
67	R529	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
68	R531	Open	Input:230V Output:850V	10min.	--	--	MPPT2 operation failure, MPPT1 normal operation. Inverter operated normally. No damaged. No hazard.
69	R538	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
70	R540	Open	Input:230V Output:850V	10min.	--	--	MPPT2 operation failure, MPPT1 normal operation. Inverter operated normally. No damaged. No hazard.
71	R547	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:” VbusRmsUnbalance”. No damaged. No hazard.
72	R549	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:” VbusRmsUnbalance”. No damaged. No hazard.
73	R552	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:” VbusRmsUnbalance”. No damaged. No hazard.
74	R554	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:” VbusRmsUnbalance”. No damaged. No hazard.
75	R557	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:” VbusRmsUnbalance”. No damaged. No hazard.
76	R559	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:” VbusRmsUnbalance”. No damaged. No hazard.



IEC 60255-27

77	R562	Short	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"VbusRmsUnbalance". No damaged. No hazard.
78	R564	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"VbusRmsUnbalance". No damaged. No hazard.
79	C62	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
80	R601	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"GridUVP". No damaged. No hazard.
81	R602	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged.No hazard.
82	R613	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"GridUVP". No damaged. No hazard.
83	R614	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
84	R189	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"IsoFault". No damaged. No hazard.
85	R510	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
86	R799	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"IsoFault". No damaged. No hazard.
87	R801	Short	Input:230V Output:850V	10min.	--	--	Inverter operated normally. No damaged. No hazard.
88	U13 pin82	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message:"BluetoothFault". No damaged. No hazard.

IEC 60255-27

89	U13 pin95	Open	Input:230V Output:850V	10min.	--	--	Inverter disconnected from grid immediately. Error message: "BluetoothFault". No damaged. No hazard.
----	--------------	------	---------------------------	--------	----	----	--

Supplementary information

7.3	TABLE: Heating Test					P
	test voltage (V) :			See below		
	t1 (°C) :			See below		
	t2 (°C) :			See below		
Thermocouple Locations		Max. temperature measured (°C)				Max. temperature limit (°C)
Test voltage		Input: 850Vdc	Input: 540Vdc	Input: 850Vdc	Input: 540Vdc	--
Outside fan 1		52.7	53.1	66.2	66.2	70
Outside fan 2		57.4	56.9	66.9	66.9	70
PV input connector		47.2	47.8	62.4	62.4	85
DC switch handle		46.1	46.8	61.4	61.4	85
LCD display button		52.9	53.9	67.2	67.2	100
AC terminals		54.9	55.2	68.8	68.8	105
Enclosure surface		58.7	61.1	72.7	72.7	100
Enclosure side		59.9	61.4	74.8	74.8	100
Mounting surface		64.8	60.8	79.0	79.0	100
Q6		85.8	74.1	99.7	99.7	130
Q13		96.8	83.2	107.2	107.2	130
Q3		100.8	86.4	110.3	110.3	130
Q8		83.4	81.0	94.2	94.2	130
D2		70.5	87.8	84.1	84.1	130
Q14		65.9	88.0	79.7	79.7	130
Q50		65.4	81.9	78.7	78.7	130
D98		70.2	75.0	83.0	83.0	130
CY1		60.6	68.7	73.9	73.9	85
Varistor MOV1		63.6	69.9	76.8	76.8	125
Input DC SPD F4		62.5	67.8	75.7	75.7	85
Winding of T1 transformer		71.3	73.3	84.3	84.3	110
Core of T1 transformer		71.0	73.5	84.2	84.2	110
Winding of T3 transformer		68.6	72.3	82.6	82.6	110
Core of T3 transformer		67.6	71.4	81.4	81.4	110

IEC 60255-27

Winding of EMI inductor L1	67.3	92.1	79.7	79.7	130
C16	63.8	70.8	77.4	77.4	105
HCT1	64.3	70.7	77.9	77.9	105
Relay RL2	73.0	74.3	86.0	86.0	105
Winding of EMI inductor L2	87.1	86.8	103.6	103.6	130
Winding of GFCI LP2	74.5	76.2	88.2	88.2	130
Core of EMI inductor L2	82.1	81.9	103.3	103.3	130
Y-Cap CY26	70.6	72.8	82.4	82.4	85
C62	71.6	73.5	84.8	84.8	105
Winding of EMI inductor L3	84.6	86.7	96.9	96.9	130
Varistor MOV5	70.0	72.5	83.7	83.7	125
R phase INV Inductor	96.1	86.6	99.1	99.1	130
T phase INV Inductor	109.1	78.1	98.2	98.2	130
C32	73.5	75.6	86.2	86.2	105
Line of INV inductor	73.3	75.2	85.6	85.6	105
C34	74.5	75.2	87.7	87.7	105
VU11	73.5	74.3	86.7	86.7	105
HCT6	80.3	74.7	81.7	81.7	85
C35	70.9	72.6	84.5	84.5	105
Relay RL5	76.8	77.4	88.7	88.7	105
C65	67.8	70.2	81.1	81.1	110
CAS1	68.3	70.5	81.5	81.5	90
AC line	70.6	72.2	82.3	82.3	105
DSP U13	69.3	70.9	82.8	82.8	130
DSP U30	71.1	72.1	82.5	82.5	130
PCB	87.7	82.0	99.9	99.9	130
PV line	46.3	46.2	61.7	61.7	105
ISO relay RY2	64.3	70.5	77.7	77.7	85
Winding of boost1 inductor	61.0	78.9	74.8	74.8	130
Winding of boost2 inductor	62.6	89.7	76.4	76.4	130
CTF9	64.6	69.6	78.0	78.0	105
UV2	68.5	75.6	81.9	81.9	130
Line of boost inductor	63.8	71.5	77.7	77.7	105
CTF5	72.8	74.1	86.0	86.0	105
DC switch body	59.8	66.6	72.8	72.8	85

IEC 60255-27

UV1	75.7	78.2	86.7	86.7	130
ambient	44.7	44.6	60.3	60.4	--
TABLE: Heating test, resistance method					
Test voltage (V) :					—
Ambient, t₁ (°C) :					—
Ambient, t₂ (°C) :					—
Temperature rise of winding	R₁ (Ω)	R₂ (Ω)	ΔT (K)	Max. dT (K)	Insulation class

Supplementary information: Virtual ground used for the test.

7.6	TABLE: Flammability of materials and components					N/A
Object/ Part No./ Material		Manufacturer/ trademark		Duration of application of test flame (ta); (s)	Ignition of specified layer Yes/No	Duration of burning (tb) (s)
--		--		--	--	--
Supplementary information:						
Part		Manufacturer of material		Type of material	Thickness (mm)	Flammability class
--		--		--	--	--
Supplementary information:						

IEC 60255-27

8.3	TABLE: Critical components information					P
Component	Manufacturer/ trademark	Type/model	Technical data	Standard	Mark(s) of conformity	
Metal Enclosure	All	All accepted	Min. thickness : 1.5mm	--	--	
Plastic cover (LCD screen)	MACDERMID AUTOTYPE LTD	Autotex XE(f2)	105°C, V-0, min. 0.2mm thickness	UL 94 UL 746C	UL	
DC connector	Stäubli Electrical Connectors AG	PV-KST4/xy-UR PV-KBT4/xy-UR	1000Vdc, 39A, Max. 85°C, IP68	IEC 62852:2014	TUV R60127190	
	Dongguan Vaconn Electronic Technology Co.,Ltd.	VP-D4a- bcdef (DEVALAN)	1000Vdc, 39A, Max. 85°C, IP68	IEC 62852:2014 EN 62852:2014	TUV R50396796	
Internal wiring(DC switch-The mainboard PV line)	All	All accepted	Min.10AWG, 2000V,105°C	UL11627	UL	
Internal wiring(PV-DC)	All	All accepted	Min,12AWG,20 00V,105°C	UL11627	UL	
Internal wiring (AC-out)	All	All accepted	Min,10AWG,10 00V,105°C	UL10269	UL	
Earthing wire	All	All accepted	Min.10AWG, yellow-green, 105°C	UL10269	UL	
DC Switch	Santon Switchgear Ltd	XBHP+3410/ 2-D	1000V/30A, 600V/60A, Max.85°C	EN 60947- 3:2009 EN60947- 3:2009/A1:2012 /C1:2013 EN 60947- 3:2009/A2:2015	DEKRA 71-107727	
		XBHP+3419- AAX/6	1000V/30A, 600V/50A, Max.85°C			
	ProJoy Electric Co., Ltd.	PEDS150R- HM55-4	1000V/25A,4P, Max.85°C	EN 60947- 3:2009+A1+A2	TUV R 50389807	
	Shanghai Liangxin Electrical Co., Ltd	NDG3V- 32/20/4 /1/02/M/1100	1100V/20A, 600V/30A,4P, Max.85°C	IEC 60947-1 IEC 60947-3	TUV B 083574 02 50 Rev.03	
Inductor	ANHUI ECRIEEMAG TECHNOLOGY CO., LTD. Huizhou baohui electro-tech ltd CHINA AMORPHOUS	Alloy power core	BOOST: 2*475µH INV: 3*244µH	--	--	

IEC 60255-27

8.3	TABLE: Critical components information					P	
Component	Manufacturer/ trademark	Type/model	Technical data	Standard	Mark(s) of conformity		
	TECHNOLOGY CO.,LTD						
	Shenzhen jingquanhua electronics co., Ltd						
	ShenZhen Highlight Electronic Co., LTD						
-Lead wire	All	All accepted	10AWG,1000V, 105°C, VW-1	UL10269	UL		
DC Fans (internal)	Dongguan PROTECHNIC ELECTRIC CO., LTD.	MGT9212UB R25	12V, 0.54A, Max.70°C	EN60950-1: 2006/A2:2013	TUV B 031023 0131 Rev.02		
	ASAI VITAL COMPONENTS CO LTD	DS09225B12 U	12V, 0.56A, Max.70°C	EN55032:2015 EN 55024:2010/A1: 2015	TUV E8A 17 09 25730 775		
DC Fans (External)	NMB Technologies Corporation	08025KA-12NGT-01	12V,0.3A, Max.70°C	EN 62368-1:2014/A11:2017 IEC 62368-1:2014 EN 62368-1:2014	VDE		
		08025VE-12MCTD	12V,0.3A, Max.70°C	EN 62368-1:2014/A11:2017 IEC 62368-1:2014 EN 62368-1:2014	VDE		
Heat shrinkable tube	Shenzhen QFR Electronics Co., Ltd	QFR-H-600	125°C, VW-1, 600V	UL 224	UL		
	SHENZHEN W OER HEAT-SHRINKABLE MAT ERIAL CO.,LTD	RSFR-H	125°C, VW-1, 600V	UL 224	UL		
	Shenzhen QFR Electronics Co., Ltd	QFR-H-600	125°C, VW-1, 600V	UL 224	UL		
AC output terminal Block	Shenzhen Conn ection Electroni c Co Ltd	DRTB16-05-RST	65A/600Vac, Max. 105°C	UL1059	UL		
All PCB	All	All accepted	Min.130°C, min. V-0, CTI≥175	UL 796	UL		

IEC 60255-27

8.3	TABLE: Critical components information					P
Component	Manufacturer/ trademark	Type/model	Technical data	Standard	Mark(s) of conformity	
Input Y-Cap (CY1, CY2, CY3, CY4, CY5, CY6, CY7, CY10, CY14, CY15)	Samwha Capacitor Co., Ltd	SC	Y1, 4.7nF, 400Vac, Max.85°C	EN 60384-14:2013/A1:2016; EN 60384-14:2013-08	VDE	
	WALSIN TECH NOLOGY CORP	AH	Y1, 4.7nF, 400Vac, Max. 85°C	EN 60384-14:2013/A1:2016; EN 60384-14:2013-08	VDE	
Input Y-Cap (CY8, CY9, CY11, CY12, CY13, CY16, CY21)	Samwha Capacitor Co., Ltd	SC	100pF, 400Vac, Max. 85°C	EN 60384-14:2013/A1:2016; EN 60384-14:2013-08	VDE	
	WALSIN TECH NOLOGY CORP	AH	100pF, 400Vac, Max. 85°C	EN 60384-14:2013/A1:2016; EN 60384-14:2013-08	VDE	
Input Current transformer(LP1)	HUIZHOU BAOHUI ELECTRONICS TECHNOLOGY CO.,LTD	115-20-007A	Class B (130°C)	--	--	
--Winding	All	All accepted	130°C	UL 1446	UL	
Input Varistor (MOV1, MOV2, MOV3, MOV4,)	TDK (ZHUHAI FTZ) CO., LTD	S20K510/SN F20K510E2 S5	510VAC, Imax: 10kA, Max.: 125°C	IEC 60151-1 IEC 60151-2 IEC 60151-2/AMD1 IEC 61051-2-2	VDE	
	DongGuan LittelfuseElectronics Co., Ltd.	LA SeriesV20E5 10P	510Vac, Imax: 10kA, Max.: 125°C	CECC 42201-006, Issue 3, 2004-10 IEC 60950-1:2013-05 IEC 61051-1:1992 IEC 61051-2(ed.1);am1:2009-05 IEC 61051-2:1992 IEC 61051-1:2007	VDE	
Input DC SPD (F4)	Sichuan Zhongguang Lightning Protection Technologies Co., Ltd.	ZGGS20-500PVh1c1	385Vac/500Vdc Imax:10kA, Max. 85°C	IEC 61643-11:2011 EN 61643-11:2012	TUV R 50342738	
	SHENZHEN HAIPENGXIN ELECTRONICS CO.,LTD.	PV20K-500	385Vac/500Vdc Imax:10kA, Max. 85°C	EN 61643-11:2012	TUV R 50316472	

IEC 60255-27

8.3	TABLE: Critical components information					P
Component	Manufacturer/ trademark	Type/model	Technical data	Standard	Mark(s) of conformity	
Input Line filter (L1)	HUIZHOU BAOHUI ELECTRONICS TECHNOLOGY CO.,LTD	115-20-028A	0.7mH, Max. 130°C	--	--	
--Winding	All	All accepted	180°C	UL 1446	UL	
Input Electronics capacitor(CTF1, CTF2, CTF3)	Xiamen Faratronic Co., Ltd.	C3D1M205K B00382	2μF, 1100Vdc, Max.105°C	--	--	
	Hua Jung Components Co., Ltd	DMJ-PS Series	2μF, 1100Vdc, Max.105°C	--	--	
Input Electronics capacitor(C10, C16)	Xiamen Faratronic Co., Ltd.	C3D1M156K F12382	15μF, 1100Vdc, Max. 105°C	--	--	
	TDK	B32776S015 6K519	15μF, 1100Vdc, Max. 105°C	--	--	
	Hua Jung Components Co., Ltd	DMJ-PS Series	15μF, 1100Vdc, Max. 105°C	--	--	
Input Current sensor (HCT1, HCT4)	Sinomags Technology Co., Ltd	STK-20HD/P2	IPN: 20A Vc: 5V Icc: 5mA Max.: 105°C	--	--	
Current sensor (HCT2、HCT3)	Allegro MicroSystems, LLC	ACS724KMA TR-30AB-T	Di \geq 0.4mm Internall di \geq 7.0mm External di \geq 7.62mm, AC 8000V, reinforced Insulation 115°C	UL 60950-1:2007/A2:2014 EN 60950-1:2006/A2:2013	TUV U8V 16 03 54214 040	
Input Relay (RY1, RY2)	Xiamen Hongfa Electroacoustic Co. Ltd.	HFD3/5	2A, 250Vac, 5Vdc, Max.85°C	IEC 61810-1 VDE 0435	VDE	
Boost IGBT(Q4, Q12, Q50, Q51)	Fairchild	FGY40T120S MD	1200V, 40A, Max.175°C	--	--	
DO	Infineon	IKQ40N120C H3	1200V, 40A, Max.175°C	--	--	
Bus Electronics capacitor(CTF4, CTF5, CTF6, CTF7, CTF8, CTF9)	Xiamen Faratronic Co., Ltd.	C3D	110μF, 550V, Max. 105°C	EN 61071:2007 IEC 61071:2007 IEC 61881-1:2010 EN 61881-1:2011	TUV R 50266108	
	Wuxi CRE New Energy Technology	DMJ-PS DPS1170550 K4	110μF, 550V, Max. 105°C	--	--	

IEC 60255-27

8.3	TABLE: Critical components information					P
Component	Manufacturer/ trademark	Type/model	Technical data	Standard	Mark(s) of conformity	
	CO.,Ltd	22101		--	--	
	Hua Jung Components Co., Ltd	EPB-117K0550DB 1523-FF	110µF, 550V, Max. 105°C	--	--	
INV IGBT(Q5,Q6,Q7,Q8,Q9,Q10)	Fairchild	FGA40T65S HD	40A, 650V, Max. 175°C	--	--	
	Infineon	IKW40N65H5 /IKW40N65E S5	40A, 650V, Max. 175°C	--	--	
INV IGBT(Q1,Q2,Q3,Q11,Q12,Q13)	On-Semi	FGY75T120S QDN	75A, 1200V, Max. 175°C	--	--	
	Infineon	IKQ75N120C H3	75A, 1200V, Max. 175°C	--	--	
INV IGBT(Q1,Q2,Q3,Q11,Q12,Q13)(SOFAR 15KTLX-G3)	On-Semi	FGY40T120S MD	40A, 1200V, TP-247, Max.175°C	--	--	
	Infineon	IKQ40N120C H3	40A, 1200V, TP-247, Max.175°C	--	--	
Power Diode (D1、D2)	CREE	C4D20120D	1200V, 32A, 175°C	--	--	
	On-Semi	FFSH30120A DN-F155	1200V, 30A, 175°C	--	--	
Output Electronics capacitor(C35, C41, C47)	Xiamen Faratronic Co., Ltd.	C6AR8805KF 20382	8µF, 380Vac, Max. 105°C	--	--	
	TDK	Z905927714s 512	8µF, 380Vac, Max. 105°C	--	--	
Output Relay for all models except (RL1, RL2, RL3, RL4, RL5, RL6)	Xiamen Hongfa Electroacoustic Co. Ltd.	HF161F-40W/12-HT(967)	40A, 277Vac, 12Vdc, Max. 105°C	IEC 61810-1:2015 EN 61810-1:2015	TUV R 50475730	
	ZETTLER	AZSR143-1AE-12D	40A, 277Vac, 12Vdc, Max. 105°C	IEC 61810-1	TUV B 088793 0015 Rev.00	
Output Relay for all models except (RL1, RL2, RL3, RL4, RL5, RL6) (SOFAR 15KTLX-G3)	Xiamen Hongfa Electroacoustic Co. Ltd.	HF161F-W/12-HT(477)	26A, 277Vac, 12Vdc, Max. 85°C	EN61810-1:2015	VDE	
	ZETTLER	AZSR131-1AE-12D	31A, 277Vac, 12Vdc, Max. 85°C	IEC 61810-1	TUV B 088793 0005 Rev.01	
Output GFCI Module(LP2)	HUIZHOU BAOHUI ELECTRONICS TECHNOLOGY CO.,LTD	SH-T009	Class B (130°C)	--	--	
	CHINA	CA01-12054				

IEC 60255-27

8.3	TABLE: Critical components information					P
Component	Manufacturer/ trademark	Type/model	Technical data	Standard	Mark(s) of conformity	
AMORPHOUS TECHNOLOGY CO., LTD						
- Winding		All accepted	155°C	UL 1446	UL	
Output Y-Cap (C59, C60, C61,C63,CY24, CY25, CY26,CY17, CY18, CY19, CY22, CY27, CY28)	SAMWHA CAPACITOR CO LTD	SD	Y1, 4.7nF, 400Vac, Max. 85°C	EN 60384-14:2013/A1:2016 IEC 60384-14:2013 IEC 60384-14:2013/AMD1:2016; EN 60384-14:2013-08	VDE	
	WALSIN TECHNOLOGY CORP	AH	Y1, 4.7nF, 500Vac, Max. 85°C	EN 60384-14:2013/A1:2016 IEC 60384-14:2013 IEC 60384-14:2013/AMD1:2016; EN 60384-14:2013-08	VDE	
Output Y-Cap(C58, C62, C64, C69)	Xiamen faratronic Co., Ltd	MKP63	Y2, 33nF, 300Vac, Max. 110°C	EN 60384-14:2013+A1 UL60384-14:2009	ENEC:SE/0366-2D	
Output Line filter(L2)	HUIZHOU BAOHUI ELECTRONICS TECHNOLOGY CO.,LTD	115-20-030A	13µH, Max.130°C	--	--	
- Winding	All	3.0*3.7mm	200°C	UL 758	UL	
Or	All	All accepted	Short wiring, Min2.0*3.8mm, copper, 150°C	--	--	
--Tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	PF-301	180°C	UL 510	UL	
Output Current sensor (HCT5, HCT6, HCT7)		CASR 25-NP	IPN:25A; Vc: 5V. Max.: 85°C	--	--	
		VAC	T60404-	IPN:25A;	--	

IEC 60255-27

8.3	TABLE: Critical components information					P
Component	Manufacturer/ trademark	Type/model	Technical data	Standard	Mark(s) of conformity	
		N4646-X661	Vc: 5V. Max. 85°C			
Output Varistor (MOV5, MOV6, MOV7, MOV8)	TDK	S20K510/SN F20K510E2 S5	510Vac, Imax: 10kA, Max.:125°C	IEC 60151-1 IEC 60151-2 IEC 60151- 2/AMD1 IEC 61051-2-2	VDE	
Or	Littelfuse	LA Series V20E510P	510Vac, Imax: 10kA, Max. 125°C	CECC 42201- 006, Issue 3, 2004-10 IEC 60950- 1:2013-05 IEC 61051- 1:1992 IEC 61051- 2(ed.1);am1:20 09-05 IEC 61051- 2:1992 IEC 61051- 1:2007	VDE	
Output Gas tube (GAS1)	Bencent electronics ltd	B8G1500M	380V, 10kA, Max.: 90°C	UL1449	UL	
Output Thermal fuse(F5, F6, F7)	AUPO ELECTRONIC S LTD	A2	2A, 250V, Max. 203°C	UL 60691	UL	
Output Electronics capacitor(C65, C66, C67, C415)	XIAMEN FARATRONI C CO.,LTD	C46H2474K B3 C450	X1, 0.47uF, 500Vac, Max. 110°C X1, 0.56uF, 500Vac, Max. 110°C X1, 0.68uF, 500Vac, Max. 110°C	--	--	
Opt coupler (U18, U21, U20, U22, U11)	Lite-On Technology Corporation	LTV-816 S2	Di \geq 0.4mm External Cr. And Cl. \geq 8.0mm, AC 8000V, reinforced Insulation 115°C	IEC 60747-5- 5:2007 IEC 60747-5- 5:2007/AMD1:2 013 DIN EN 60747- 5-5 (0884- 5):2015-11; EN60747-5- 5:2011; A1:2015	VDE	
Auxiliary_power transformer(T1)	HUIZHOU BAOHUI ELECTRONICS TECHNOLOGY CO.,LTD	115-20-005A	Class B, Max. 130°C	--	--	



IEC 60255-27

8.3	TABLE: Critical components information					P
Component	Manufacturer/ trademark	Type/model	Technical data	Standard	Mark(s) of conformity	
- Winding	All	All accepted	130°C	UL 1446	UL	
- Bobbin	SUMITOMO BAKELITE CO LTD	PM-9820, PM-9030	V-0, min. thickness: 0.75mm, 150°C	UL 94	UL	
Or	CHANG CHUN PLASTICS CO.,LTD	T375J	V-0, min. thickness: 0.75mm, 150°C	UL 94	UL	
--Tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	CT-	130°C	UL 510	UL	
- Margin Tape	Jingjiang Yahua Pressure Sensitive Glue Co Ltd	WF-	3.0mm, 130°C	UL 510	UL	
- Tube	SHENZHE N WOER HEAT- SHRINKABLE MATERIAL CO.,LTD	WF(PTFE)	600V, Max. 200°C	UL224	UL	
Auxiliary_power transformer(T2)	HUIZHOU BAOHUI ELECTRONIC S TECHNOLOG Y CO.,LTD	115-19-067C	Class B, Max. 130°C	--	--	
- Winding	All	All accepted	130°C	UL 1446	UL	
- Bobbin	SUMITOMO BAKELITE CO LTD	PM-9820, PM-9030	V-0, min. thickness: 0.75mm, 150°C	UL 94	UL	
	CHANG CHUN PLASTIC S CO.,LTD	T375J	V-0, min. thickness: 0.75mm, 150°C	UL 94	UL	
--Tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	CT-	130°C	UL 510	UL	
- Margin Tape	Jingjiang Yahua Pressure	WF-	1.5mm,130°C	UL 510	UL	

IEC 60255-27

8.3	TABLE: Critical components information					P
Component	Manufacturer/ trademark	Type/model	Technical data	Standard	Mark(s) of conformity	
	Sensitive Glue Co Ltd					
- Tube	SHENZHEN N WOER HEAT- SHRINKABLE MATERIAL CO.,LTD	WF(PTFE)	600V, Max. 200°C	UL224	UL	
Auxiliary_power Current transformer(T3, T4)	Shenzhen Spit Electronics Co. LTD	SPT- 08E0313- CT	Max. 130°C	--	--	
- Winding	All	All accepted	155°C	UL 1446	UL	
- Bobbin	CHANG CHUN PLASTICS CO LTD	T373J	V-0	UL 94	UL	
IGBT Driver Power Fuse(FC1)	Littelfuse Inc.	1812L110/33	1.1A, 33V, Max. 85°C	EN 60738- 1:2006 EN 60738-1- 1:2008 IEC 60738- 1:2006 IEC 60738-1- 1:2008	TUV R 50119118	
IGBT Driver Power transformer(T 5)	HUIZHOU BAOHUI ELECTRONIC S TECHNOLOGY CO.,LTD	115-20-004A	Max. 130°C	--	--	
Digital Isolators (U19)	Texas Instruments Deutschland GmbH	ISO7721DW VR	External Cr. And Cl. \geq 8.0mm, AC 8000V, reinforced Insulation 125°C	DIN VDE V 0884- 11:2017	VDE	
LCD_RS485 Gas tube (GAS2,GAS3)	SHENZHEN BENCENT ELECTRONIC CO LTD	B3D090L-C	90V/5kA, 90°C	UL1449	UL	

IEC 60255-27

10.6.3	TABLE: Clearance and creepage distance measurements						P
clearance cl and creepage distance dcr at / of:	Up (V)	U r.m.s. (V)	required cl (mm)	cl (mm)	required dcr (mm)	dcr (mm)	
PV circuit and earthed enclosure(BI)	--	1100Vdc	3.1	11.2	3.1	11.2	
AC circuit and earthed enclosure(BI)	--	1100Vdc	3.1	11.2	3.1	11.2	
Main power board: AC circuit go through Y capacitor C134, C151 to earth on PCB (BI)	--	1100Vdc	3.1	7.3	3.1	7.3	
Main power board: AC circuit go through optocoupler U11 to earth on PCB (BI)	--	1100Vdc	3.1	7.3	3.1	7.3	
AC output circuit L and N on PCB (BI)	--	1100Vdc	4.0	5.5	4.0	5.5	
Main power board: PV circuit go through Y capacitor CY21, CY1, CY16, CY3 to earth on PCB (BI)	--	1100Vdc	4.0	7.4	5.6	7.4	
Power board: PV circuit go through isolation transformer TX3 to communication ports (RI)	--	1100Vdc	6.5	10.1	6.5	10.1	
Main power board: PV circuit go through Y capacitor CY14, CY15 to communication ports (RI)	--	1100Vdc	6.5	16.0	6.5	16.0	
Power board: PV circuit go through optocoupler U20, U21, U18, U22, U10, U9 to communication ports (RI)	--	100Vdc	6.5	8.3	6.5	8.3	
Live parts IGBT and earthed screws (BI)	--	1100Vdc	4.0	7.0	5.6	7.0	
Main power board: Relay (RL3, RL4, RL5, RL6) two polarity on PCB board(BI)	--	230Vac	4.0	7.2	4.0	7.2	
Transformer(T1) primary parts to secondary part	--	1100Vdc	6.5	9.0	6.5	9.0	
Transformer(T1) Iron-core to secondary part	--	1100Vdc	6.5	11.8	6.5	11.8	
Note(s): *, BI= basic insulation, RI=reinforced insulation. When determine the clearance: Consider the maximum working altitude of the machine is 2000m.							

IEC 60255-27

10.6.4.2/ 10.6.4.3	TABLE: Impulse voltage test/Dielectric Strength				P
test voltage applied between:	test voltage (Vdc)	impulse withstand voltage (V)	partial discharge extinction voltage (V)	result	
DC input terminal to earthed enclosure	2797	4000	--	P	
DC input terminal to communication port	5494	6000	--	P	
AC output terminal to earthed enclosure	2120	4000	--	P	
AC output terminal to communication port	4240	6000	--	P	
Insulation sheet	2797	4000	--	P	
Two layers of insulation tape	5494	6000	--	P	
Relay pin 3 to pin 4	2797	4000	--	P	
DC input terminal to earthed enclosure	2797	4000	--	P	
Supplementary information:					

10.6.4.4	TABLE: insulation resistance measurements			P
Insulation resistance R between:	R (MΩ)	Required R (MΩ)		
Between mains poles (primary fuse disconnected)	>100	10		
Between parts separated by basic or supplementary insulation	>100	10		
Between parts separated by double or reinforced insulation	>100	10		
Supplementary information:				

10.6.4.5	TABLE: resistance of bonding conductors and their terminations			P
Accessible conductive part	Test current (A) 20x1'	Voltage drop (V)	Calculated Resistance (Ω)	
PE to Enclosure	20	1.4	0.07	
Supplementary information:				

List of test equipment used:

No	Test Equipment	Equipment model	Equipment No.	Calibration due date
1	Simulation of ac power supply	WPLA-330200KVA	BZ-DGD-L204	2021/07/12
2	Solar IV simulator	WPLA-150KW	BZ-DGD-L013	2021/11/14
3	Programmable ac load	ACLT-38160H	BZ-DGD-L003	--
4	Power analyser	PW6001-16	BZ-DGD-L025	2021/3/25
5	Oscilloscope	MSO4054B	BZ-DGD-L028	2021/3/24
6	Heating Recorder	LR8400-21	BZ-DGD-L032	2021/8/27
7	Hi-Pot & IR tester	Chroma 19032	BZ-DGD-L066	2021/4/25
8	Noise meter	TES-1357	BZ-DGD-L029	2021/3/09
9	Digital Caliper	LS160	BZ-DGD-L048	2021/3/09
10	Testing Finger B	AUTO-B	BZ-DGD-L011	2020/11/1
11	DC Electronic Load	IT8511+	BZ-DGD -L027	2020/10/31
12	Pull and push	2P-1000	BZ-DGB-L080	2021/8/27
13	Electronic Scale	TCS-300	BZ-DGB-L020	2021/3/09
14	Thermostat	16m³	BZ-DGD-L015	2021/3/09
15	Surge generator	HCWG 70	BZ-DGE-L036	2021/5/05
16	Electromagnetic vibration table	ES-20-321	BZ-DGB-L026-1	2021/9/08
17	Impact table	SY11-50	BZ-DGB-L069	2021/3/03

- End of Test Report -