


**TESTING FOR THE VERIFICATION OF COMPLIANCE OF
PV INVERTER WITH :
ENGINEERING RECOMMENDATION G98 ISSUE 1-
AMENDMENT 3 MARCH 2019,
REQUIREMENTS FOR THE CONNECTION OF FULLY TYPE
TESTED MICRO-GENERATORS (UP TO AND INCLUDING
16 A PER PHASE) IN PARALLEL WITH PUBLIC LOW
VOLTAGE DISTRIBUTION NETWORKS ON OR AFTER 27
APRIL 2019**

Test Report Number..... : GZES200702291201

Type..... : 

Tested Model..... : HYD 10KTL-3PH

Variant Models..... : HYD 5KTL-3PH, HYD 6KTL-3PH, HYD 8KTL-3PH


APPLICANT

Hired by..... : Shenzhen SOFAR SOLAR Co., Ltd.
401, Building 4, AnTongDa Industrial Park, District 68,
Address..... : XingDong Community, XinAn Street, BaoAn District,
Shenzhen City, Guangdong Province, P.R. China.

TESTING LABORATORY

Name..... : SGS-CSTC Standards Technical Services Co., Ltd.
Guangzhou Branch
Address..... : 198 Kezhu Road, Science City, Economic & Technology
Development Area, Guangzhou, Guangdong, China

Conducted (tested) by..... : Hugo Zhang
(Project Engineer)




Approved by..... : Roger Hu
(Technical Reviewer)



Date of issue..... : 26 / 08 / 2020

Number of pages..... : 128



Important Note:

- This document is issued by the Company under its General Conditions of service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.
- Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
- Unless otherwise stated the results shown in this test report refer only to the sample(s) tested as received. **Information of derived or extension models of the range as provided by the applicant, (if any), is included in this report only for informative purposes.** The Company SGS shall not be liable for any incorrect results arising from unclear, erroneous, incomplete, misleading or false information provided by Client. This document cannot be reproduced except in full, without prior approval of the Company.

Test Report Historical Revision:

| Test Report Version | Date | Resume |
|---------------------|----------------|----------------|
| GZES200702291201 | 26 / 08 / 2020 | First issuance |

INDEX

| | | |
|----------|--|------------|
| 1 | SCOPE | 4 |
| 2 | GENERAL INFORMATION | 5 |
| 2.1 | Testing Period and Climatic conditions | 5 |
| 2.2 | Equipment under Testing | 5 |
| 2.3 | Test equipment list | 9 |
| 2.4 | Measurement uncertainty | 10 |
| 2.5 | Test set up of the different standard | 11 |
| 2.6 | Definitions | 12 |
| 3 | RESUME OF TEST RESULTS | 13 |
| 4 | TEST RESULTS | 14 |
| 4.1 | Operating Range | 14 |
| 4.2 | Power Quality | 17 |
| 4.2.1 | Current Harmonics | 17 |
| 4.2.2 | Voltage fluctuations and Flicker | 21 |
| 4.2.3 | DC Injection | 27 |
| 4.2.4 | Power Factor | 29 |
| 4.3 | Protection | 31 |
| 4.3.1 | Frequency tests | 31 |
| 4.3.2 | Voltage tests | 52 |
| 4.3.3 | Loss of Mains test | 73 |
| 4.3.4 | Frequency change, Vector Shift Stability test and RoCoF Stability test | 102 |
| 4.4 | Limited Frequency Sensitive Mode - Overfrequency test | 105 |
| 4.5 | Power output with falling frequency test | 107 |
| 4.6 | Re-connection timer | 108 |
| 4.6.1 | Voltage Reconnection Conditions | 108 |
| 4.6.2 | Frequency Reconnection Conditions | 110 |
| 4.7 | Fault level contribution | 112 |
| 4.8 | Self-Monitoring solid state switching | 118 |
| 4.9 | Electromagnetic Compatibility (EMC) | 118 |
| 4.10 | Logic Interface | 119 |
| 5 | PICTURES | 120 |
| 6 | ELECTRICAL SCHEMES | 128 |

1 SCOPE

SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch has been contract by Shenzhen SOFAR SOLAR Co., Ltd, in order to perform the testing according the "Engineering Recommendation G98 Issue 1 - Amendment 3 March 2019, Requirements For The Connection Of Fully Type Tested Micro-Generators (Up To And Including 16 A Per Phase) In Parallel With Public Low Voltage Distribution Networks On Or After 27 April 2019".

2 GENERAL INFORMATION


2.1 TESTING PERIOD AND CLIMATIC CONDITIONS

The necessary testing has been performed along between the 03rd of June to 13th of August of 2020. All the tests and checks have been performed at $25 \pm 5^{\circ}\text{C}$, $96 \text{ kPa} \pm 10 \text{ kPa}$ and $50\% \text{ RH} \pm 10\% \text{ RH}$.

SITE TEST

Name: Shenzhen SOFAR SOLAR Co., Ltd.
 Address: 401, Building 4, AnTongDa Industrial Park, District 68,
 XingDong Community, XinAn Street, BaoAn District,
 Shenzhen City, Guangdong Province, P.R. China.

2.2 EQUIPMENT UNDER TESTING


Apparatus type: Hybrid Inverter (Three phase)
 Installation: Fixed (permanent connection)
 Manufacturer: Shenzhen SOFAR SOLAR Co., Ltd.
 Address: 401, Building 4, AnTongDa Industrial Park, District 68,
 XingDong Community, XinAn Street, BaoAn District,
 Shenzhen City, Guangdong Province, P.R. China.
 Trade mark: 
 Model / Type reference.....: HYD 10KTL-3PH
 Serial Number: SP1ES010H71002
 Software Version: V2.00
 Rated Characteristics: DC input: 180-960 V, Max. 2× 25 A
 AC output: 3~/N/PE 230, 50 Hz, 3× 14.5A
 (max. 3× 16A), 10000 W

Date of manufacturing: 2020

Test item particulars

Input: DC
 Output.....: AC
 Class of protection against electric shock...: Class I
 Degree of protection against moisture.....: IP 65
 Type of connection to the main supply: TN
 Cooling group: See model list on page 8
 Modular: No
 Internal Transformer.....: No

Copy of marking plate (representative) :

| SOFAR SOLAR Hybrid Inverter | |
|--|----------------------|
| Model No: | HYD 10KTL-3PH |
| Max.DC Voltage | 1000V |
| MPPPT Voltage Range | 180~960V |
| Max. Input Current | 25/25A |
| Max.PV Isc | 30/30A |
| Battery Type | Li-Ion |
| Battery Voltage Range | 180~800V |
| Battery Max. Charging Current | 25/25A |
| Battery Max. Discharging Current | 25/25A |
| Nominal Grid/Back-up Voltage | 3/N/PE, 380/400V |
| Nominal Grid/Back-up Frequency | 50/60Hz |
| Max. Current Output to Grid | 16A |
| Max. Power Output to Grid | 11000VA |
| Max. Current from Grid | 29A |
| Max. Power from Grid | 20000VA |
| Back-up Max. Output Current | 16A |
| Back-up Max. Output Power | 11000VA |
| Power Factor | 1(adjustable+/-0.8) |
| Operating Temperature Range | -30~+60°C |
| Ingress Protection | IP65 |
| Protective Class | Class I |
| Inverter Topology | Non-isolated |
| Overvoltage Category | AC III,DC II |
| Manufacturer : Shenzhen SOFAR SOLAR Co.,Ltd. Address : 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community,XinAn Street, BaoAn District, Shenzhen, China | |
| SAA VDE0126-1-1,VDE-AR-N4105 G98, G99, EN50438, AS4777, UTE C15-712-1 | |
|  | |

Note:

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation
3. Labels of other models are as the same with **HYD10KTL-3PH**'s except the parameters of rating.

Equipment Under Testing:

- HYD 10KTL-3PH;

The variants models are:

- HYD 5KTL-3PH;
- HYD 6KTL-3PH;
- HYD 8KTL-3PH;

| Model | HYD 5KTL-3PH | HYD 6KTL-3PH | HYD 8KTL-3PH | HYD 10KTL-3PH |
|---|-----------------|-----------------|-----------------|------------------|
| PV String Input Data | | | | |
| Max. DC voltage | 1000V | | | |
| MPPT voltage range | 180V~960V | | | |
| Full power MPPT voltage range | 250V~850V | 320V~850V | 360V~850V | 220V~850V |
| Max. input current | 12.5A/12.5A | 12.5A/12.5A | 12.5A/12.5A | 25A/25A |
| Max. short current | 15A/15A | 15A/15A | 15A/15A | 30A/30A |
| Battery Input Data | | | | |
| Battery voltage range | 180V~800V | | | |
| Battery voltage range for full load | 200V~800V | 240V~800V | 320V~800V | 200V~800V |
| No. of battery input | 1 | | | 2 |
| Nominal charging/discharging power | 5000W | 6000W | 8000W | 10000W |
| Max. charging/discharging current | 25A | 25A | 25A | 50A (25A/25A) |
| AC Output Data (On-grid) | | | | |
| Nominal AC power | 5000W | 6000W | 8000W | 10000W |
| Max. AC power output to utility grid | 5500VA | 6600VA | 8800VA | 11000VA |
| Max. AC power from utility grid | 10000VA | 12000VA | 16000VA | 20000VA |
| Max. AC current output to utility grid | 8A | 10A | 13A | 16A |
| Rated AC current output to utility grid | 7.2A | 8.7A | 11.6A | 14.5A |
| Max. AC Current from utility grid | 15A | 17A | 24A | 29A |

| | | | | |
|---------------------------------|--------------------------------|-----------|-----------|----------|
| Nominal output voltage | 3/N/PE, 230Vac | | | |
| Nominal output frequency | 50Hz | | | |
| Output power factor | 1(0.8 leading to 0.8 lagging) | | | |
| AC Output Data (Back-up) | | | | |
| Nominal output power | 5000W | 6000W | 8000W | 10000W |
| Max. output power | 5500VA | 6600VA | 8800VA | 11000VA |
| Rated. output current | 7.2A | 8.7A | 11.6A | 14.5A |
| Max. output current | 8A | 10A | 13A | 16A |
| Peak output current, Duration | 15A, 60s | 18A, 60s | 24A, 60s | 30A, 60s |
| Nominal output voltage | 3/N/PE, 230Vac | | | |
| Nominal output frequency | 50Hz | | | |
| Output power factor | ~1(0.8 leading to 0.8 lagging) | | | |
| Operating temperature range | -30°C ~60°C | | | |
| Ingress protection | IP65 | | | |
| Protective class | Class I | | | |
| Cooling method | Heat sink | Heat sink | Heat sink | Fan |

The variants models are:

The variants models have been included in this test report without tests because the following features don't change regarding to the tested model:

- Same connection system and hardware topology
- Same control algorithm.
- Output power within $1/\sqrt{10}$ and 2 times of the rated output power or the EUT or Modular inverters.
- Same Firmware Version

The results obtained apply only to the particular sample tested that is the subject of the present test report. The most unfavorable result values of the verifications and tests performed are contained herein. Throughout this report a point (comma) is used as the decimal separator.

2.3 TEST EQUIPMENT LIST

| From | No. | Equipment Name | Model No. | Equipment No. | Calibration Date | Equipment calibration due date |
|-------------|-----|------------------------------|-------------|----------------------|------------------|--------------------------------|
| Sofar Solar | 1 | Digital oscilloscope | DSOX3014A | MY58491772 | 2020/01/14 | 2021/01/13 |
| | 2 | Voltage probe | SI-9110 | 111152 | 2020/1/14 | 2021/1/13 |
| | 3 | Voltage probe | SI-9110 | 152627 | 2020/01/14 | 2021/01/13 |
| | 4 | Voltage probe | SI-9110 | 111134 | 2020/01/14 | 2021/01/13 |
| | 5 | Power analyzer | PA5000H | C8202909082002110001 | 2020/03/02 | 2021/03/01 |
| | 6 | Current probe | CP1000A | C181000922 | 2020/01/14 | 2021/01/13 |
| | 7 | Current probe | CP1000A | C181000925 | 2020/01/14 | 2021/01/13 |
| | 8 | Current probe | CP1000A | C181000929 | 2020/01/14 | 2021/01/13 |
| | 9 | Temperature & Humidity meter | TH101B | ZB-WSDJ-001 | 2020/01/14 | 2021/01/13 |
| | 10 | Power analyzer | WT3000 | 91N610888 | 2020/01/14 | 2021/01/13 |
| | 11 | Digital oscilloscope | DSOX3014A | MY58101647 | 2020/01/14 | 2021/01/13 |
| | 12 | Power analyzer | PA5000 | C8202909082002110002 | 2020/03/02 | 2021/03/01 |
| SGS | 13 | True RMS Multimeter | Fluke / 187 | GZE012-8 | 2019/12/05 | 2020/12/04 |

2.4 MEASUREMENT UNCERTAINTY

Associated uncertainties through measurements showed in this this report are the maximum allowable uncertainties.


| Magnitude | Uncertainty |
|-----------------------|------------------------|
| Voltage measurement | $\pm 0.05\%$ |
| Current measurement | $\pm 0.05\%$ |
| Frequency measurement | $\pm 0.001\text{ Hz}$ |
| Time measurement | $\pm 0.001\text{ s}$ |
| Power measurement | $\pm 0.5\%$ |
| Phase Angle | $\pm 0.1^\circ$ |
| Temperature | $\pm 3^\circ\text{ C}$ |

Note1: Measurements uncertainties showed in this table are maximum allowable uncertainties. The measurement uncertainties associated with other parameters measured during the tests are in the laboratory at disposal of the solicitant.

Note2: Where the standard requires lower uncertainties that those in this table. Most restrictive uncertainty has been considered.

2.5 TEST SET UP OF THE DIFFERENT STANDARD

Below is the simplified construction of the test set up.



Different equipment has been used to take measures as it shows in chapter 2.3. Current and voltage clamps have been connected to the inverter input / output for all the tests. All the tests described in the following pages have used this specified test setup.

The test bench used includes:

| EQUIPMENT | MARK / MODEL | RATED CHARACTERISTICS | OWNER / ID. CODE |
|-----------|---------------------|-------------------------------|---------------------|
| AC source | Kwell / AFG-S-33800 | Voltage: 0-600 V 750 kVA | Sofarsolar / EP-026 |
| PV source | Kwell / TVS-630kW | Voltage: 0 - 1000 V 630 kW | Sofarsolar / EP-027 |
| RLC load | Qunlin / ACLT3820H | 68 kW, 68 kVAr | Sofarsolar / EP-029 |

2.6 Definitions

| | | | |
|-----------------|--|----------------|-------------------------------|
| EUT | Equipment Under Testing | Hz | Hertz |
| A | Ampere | V | Volt |
| VA _r | Volt-Ampere reactive | W | Watt |
| EMC | Electromagnetic Compatibility | p.u | Per unit |
| U _n | Nominal Voltage | P _n | Nominal Active Power |
| I _n | Nominal Current | Q _n | Nominal Reactive Power |
| I _a | Active Current | S _n | Nominal Apparent Power |
| I _r | Reactive Current | THD | Total Harmonic Distortion |
| I _h | Harmonic Current | TDD | Total Demand Distortion |
| PWHD | Partial Weighted Harmonic Distortion | PLT | Severity of Flicker Long-Term |
| PST | Severity of Flicker Short-Term | d(t) | Variation of Voltage |
| d max | Maximum Absolute Value of Voltage Variation | OV | Over Voltage |
| UV | Under Voltage | OF | Over Frequency |
| | | UF | Under Frequency |

3 RESUME OF TEST RESULTS
INTERPRETATION KEYS

Test object does meet the requirement..... : **P** Pass
 Test object does not meet the requirement..... : **F** Fails
 Test case does not apply to the test object..... : **N/A** Not applicable
 To make a reference to a table or an annex. : See additional sheet
 To indicate that the test has not been realized : **N/R** Not realized

| STANDAARD CLAUSE | STANDARD REQUIREMENTS | | RESULT |
|------------------------------|---|----------------------------------|--------|
| | G98 Issue 1 Amendment 3 March 2019 | | |
| | TEST | REMARKS | |
| EN 50438 D.3.1. | Operating Range | | P |
| EREC G98 Annex A1 A1.3.1 | Harmonics | | P |
| EREC G98 Annex A1 A1.3.3 | Voltage fluctuations and Flicker | | P |
| EN 50438 Annex D.3.10 | DC injection | | P |
| EN 50538 Annex D.3.4.1 | Power factor | | P |
| EREC G98 Annex A1 A.1.2.3 | Frequency tests | | P |
| EREC G98 Annex A1 A.1.2.2 | Voltage tests | | P |
| BS EN 62116 | Loss of Mains test | | P |
| EREC G98 Annex A1 A.1.2.6 | Frequency change, Vector Shift Stability test | | P |
| EREC G98 Annex A1 A.1.2.6 | Frequency change, RoCoF Stability test | | P |
| EN 50438 Annex D.3.3 | Overfrequency test | | P |
| EN 50438 Annex D.3.2 | Power output with falling frequency test | | P |
| EN 50438 Annex A12 | Re-connection timer. | | P |
| EREC G98 Annex A1 A.1.3.5 | Fault level contribution | | P |
| EREC G98 Annex A1 A.1.3.6 | Self-Monitoring solid state switching | No solid state switching devices | N/A |
| EREC G98 Annex A1 A.1.3.7 | Electromagnetic Compatibility (EMC) | | P |

4 TEST RESULTS

4.1 Operating Range

This test should be carried out as specified in EN 50438 D.3.1.

Active Power shall be recorded every second. The tests will verify that the Micro-generator can operate within the required ranges for the specified period of time.

The Interface Protection shall be disabled during the tests.

In case of a PV Micro-generator the PV primary source may be replaced by a DC source.

In case of a full converter Micro-generator (eg wind) the primary source and the prime mover Inverter/rectifier may be replaced by a DC source.

In case of a DFIG Micro-generator the mechanical drive system may be replaced by a test bench motor.

Test 1:

Voltage = 85% of nominal (195.5 V)

Frequency = 47.5 Hz

Power factor = 1

Period of test 90 minutes

Test 2:

Voltage = 110% of nominal (253 V).

Frequency = 51.5 Hz

Power factor = 1

Period of test 90 minutes

Test 3:



Voltage = 110% of nominal (253 V).

Frequency = 52.0 Hz


Power factor = 1

Period of test 15 minutes

Test results are graphically shown in following pages.



Test 3



4.2 POWER QUALITY

4.2.1 Current Harmonics

The tests should be carried out as specified in BS EN 61000-3-2 and can be undertaken with a fixed source of energy at two power levels firstly between 45 and 55% and at 100% of Registered Capacity. The test requirements are specified in Annex A1 A.1.3.1 (Inverter connected) or Annex A2 A.2.3.1 (Synchronous).

Measures have been repeated at 50%P_n and 100%P_n.

Following tables show the test results:

| Micro-generator rating per phase (rpp) | | 10 | kW | | | |
|--|----------------------------------|-----------------------------|------------------------------|----------------|--|--|
| Harmonic | At 45-55% of Registered Capacity | 100% of Registered Capacity | | | | |
| Phase A | | | | | | |
| | Measured Value MV in Amps | Value lh(%) | Measured Value MV in Amps | Value lh(%) | Limit in BS EN 61000- 3-2 in Amps | Higher limit for odd harmonics 21 and above |
| 2 | 0.009 | 0.060 | 0.024 | 0.165 | 1.080 | |
| 3 | 0.006 | 0.044 | 0.013 | 0.089 | 2.300 | |
| 4 | 0.006 | 0.041 | 0.014 | 0.097 | 0.430 | |
| 5 | 0.024 | 0.165 | 0.043 | 0.297 | 1.140 | |
| 6 | 0.006 | 0.044 | 0.004 | 0.027 | 0.300 | |
| 7 | 0.009 | 0.064 | 0.012 | 0.084 | 0.770 | |
| 8 | 0.004 | 0.027 | 0.004 | 0.031 | 0.230 | |
| 9 | 0.005 | 0.037 | 0.005 | 0.038 | 0.400 | |
| 10 | 0.003 | 0.020 | 0.012 | 0.082 | 0.184 | |
| 11 | 0.017 | 0.116 | 0.006 | 0.044 | 0.330 | |
| 12 | 0.002 | 0.014 | 0.002 | 0.013 | 0.153 | |
| 13 | 0.007 | 0.050 | 0.011 | 0.075 | 0.210 | |
| 14 | 0.002 | 0.014 | 0.002 | 0.017 | 0.131 | |
| 15 | 0.005 | 0.032 | 0.003 | 0.024 | 0.150 | |
| 16 | 0.002 | 0.016 | 0.002 | 0.011 | 0.115 | |
| 17 | 0.007 | 0.050 | 0.014 | 0.095 | 0.132 | |
| 18 | 0.001 | 0.008 | 0.001 | 0.008 | 0.102 | |
| 19 | 0.006 | 0.043 | 0.012 | 0.083 | 0.118 | |
| 20 | 0.001 | 0.010 | 0.002 | 0.015 | 0.092 | |
| 21 | 0.003 | 0.023 | 0.003 | 0.019 | 0.107 | 0.160 |
| 22 | 0.002 | 0.014 | 0.001 | 0.010 | 0.084 | |
| 23 | 0.004 | 0.027 | 0.011 | 0.078 | 0.098 | 0.147 |
| 24 | 0.001 | 0.004 | 0.001 | 0.007 | 0.077 | |
| 25 | 0.006 | 0.039 | 0.010 | 0.068 | 0.090 | 0.135 |
| 26 | 0.001 | 0.006 | 0.002 | 0.011 | 0.071 | |
| 27 | 0.003 | 0.020 | 0.004 | 0.029 | 0.083 | 0.124 |
| 28 | 0.002 | 0.014 | 0.001 | 0.006 | 0.066 | |
| 29 | 0.005 | 0.035 | 0.010 | 0.070 | 0.078 | 0.117 |
| 30 | 0.001 | 0.004 | 0.001 | 0.007 | 0.061 | |
| 31 | 0.005 | 0.033 | 0.008 | 0.056 | 0.073 | 0.109 |
| 32 | 0.002 | 0.014 | 0.001 | 0.009 | 0.058 | |
| 33 | 0.002 | 0.012 | 0.004 | 0.025 | 0.068 | 0.102 |
| 34 | 0.002 | 0.015 | 0.001 | 0.007 | 0.054 | |

ENA Engineering Recommendation G98 Issue 1 Amendment 3 2019

| | | | | | | |
|----|-------|-------|-------|-------|-------|-------|
| 35 | 0.004 | 0.025 | 0.007 | 0.048 | 0.064 | 0.096 |
| 36 | 0.001 | 0.004 | 0.001 | 0.007 | 0.051 | |
| 37 | 0.003 | 0.018 | 0.008 | 0.056 | 0.061 | 0.091 |
| 38 | 0.001 | 0.005 | 0.001 | 0.010 | 0.048 | |
| 39 | 0.001 | 0.008 | 0.004 | 0.029 | 0.058 | 0.087 |
| 40 | 0.002 | 0.014 | 0.001 | 0.008 | 0.046 | |

| Phase B | | | | | | |
|---------|----------------|----------|----------------|----------|----------------------------------|---|
| | Measured Value | Limit(%) | Measured Value | Limit(%) | Limit in BS EN 61000-3-2 in Amps | Higher limit for odd harmonics 21 and above |
| | MV in Amps | | MV in Amps | | | |
| 2 | 0.006 | 0.038 | 0.029 | 0.198 | 1.080 | |
| 3 | 0.004 | 0.025 | 0.012 | 0.083 | 2.300 | |
| 4 | 0.003 | 0.018 | 0.015 | 0.101 | 0.430 | |
| 5 | 0.019 | 0.132 | 0.023 | 0.160 | 1.140 | |
| 6 | 0.006 | 0.042 | 0.003 | 0.024 | 0.300 | |
| 7 | 0.009 | 0.065 | 0.013 | 0.087 | 0.770 | |
| 8 | 0.003 | 0.018 | 0.003 | 0.019 | 0.230 | |
| 9 | 0.003 | 0.023 | 0.006 | 0.041 | 0.400 | |
| 10 | 0.003 | 0.021 | 0.006 | 0.042 | 0.184 | |
| 11 | 0.012 | 0.082 | 0.008 | 0.054 | 0.330 | |
| 12 | 0.002 | 0.017 | 0.003 | 0.020 | 0.153 | |
| 13 | 0.004 | 0.030 | 0.008 | 0.057 | 0.210 | |
| 14 | 0.002 | 0.013 | 0.003 | 0.020 | 0.131 | |
| 15 | 0.002 | 0.013 | 0.003 | 0.021 | 0.150 | |
| 16 | 0.002 | 0.011 | 0.002 | 0.016 | 0.115 | |
| 17 | 0.008 | 0.053 | 0.013 | 0.088 | 0.132 | |
| 18 | 0.002 | 0.011 | 0.002 | 0.012 | 0.102 | |
| 19 | 0.006 | 0.041 | 0.010 | 0.066 | 0.118 | |
| 20 | 0.001 | 0.010 | 0.001 | 0.008 | 0.092 | |
| 21 | 0.001 | 0.008 | 0.002 | 0.016 | 0.107 | 0.160 |
| 22 | 0.001 | 0.009 | 0.002 | 0.012 | 0.084 | |
| 23 | 0.006 | 0.038 | 0.009 | 0.062 | 0.098 | 0.147 |
| 24 | 0.001 | 0.007 | 0.001 | 0.009 | 0.077 | |
| 25 | 0.005 | 0.038 | 0.011 | 0.078 | 0.090 | 0.135 |
| 26 | 0.001 | 0.007 | 0.001 | 0.006 | 0.071 | |
| 27 | 0.001 | 0.008 | 0.004 | 0.024 | 0.083 | 0.124 |
| 28 | 0.002 | 0.011 | 0.001 | 0.006 | 0.066 | |
| 29 | 0.002 | 0.017 | 0.008 | 0.057 | 0.078 | 0.117 |
| 30 | 0.001 | 0.005 | 0.001 | 0.010 | 0.061 | |
| 31 | 0.005 | 0.033 | 0.009 | 0.062 | 0.073 | 0.109 |
| 32 | 0.001 | 0.008 | 0.001 | 0.006 | 0.058 | |
| 33 | 0.001 | 0.008 | 0.003 | 0.022 | 0.068 | 0.102 |
| 34 | 0.002 | 0.013 | 0.001 | 0.005 | 0.054 | |
| 35 | 0.002 | 0.017 | 0.007 | 0.045 | 0.064 | 0.096 |
| 36 | 0.001 | 0.004 | 0.002 | 0.011 | 0.051 | |
| 37 | 0.003 | 0.019 | 0.009 | 0.059 | 0.061 | 0.091 |
| 38 | 0.001 | 0.006 | 0.001 | 0.006 | 0.048 | |
| 39 | 0.001 | 0.010 | 0.003 | 0.021 | 0.058 | 0.087 |
| 40 | 0.002 | 0.012 | 0.001 | 0.005 | 0.046 | |


Phase C

ENA Engineering Recommendation G98 Issue 1 Amendment 3 2019


| | Measured Value MV in Amps | Value lh(%) | Measured Value MV in Amps | Value lh(%) | Limit in BS EN 61000- 3-2 in Amps | Higher limit for odd harmonics 21 and above |
|----|------------------------------|----------------|------------------------------|----------------|--|--|
| 2 | 0.008 | 0.054 | 0.008 | 0.057 | 1.080 | |
| 3 | 0.007 | 0.050 | 0.020 | 0.135 | 2.300 | |
| 4 | 0.006 | 0.045 | 0.015 | 0.102 | 0.430 | |
| 5 | 0.021 | 0.146 | 0.040 | 0.278 | 1.140 | |
| 6 | 0.006 | 0.043 | 0.003 | 0.024 | 0.300 | |
| 7 | 0.007 | 0.046 | 0.012 | 0.084 | 0.770 | |
| 8 | 0.003 | 0.022 | 0.003 | 0.022 | 0.230 | |
| 9 | 0.007 | 0.045 | 0.005 | 0.033 | 0.400 | |
| 10 | 0.002 | 0.012 | 0.010 | 0.066 | 0.184 | |
| 11 | 0.014 | 0.095 | 0.005 | 0.037 | 0.330 | |
| 12 | 0.002 | 0.013 | 0.003 | 0.019 | 0.153 | |
| 13 | 0.007 | 0.047 | 0.010 | 0.071 | 0.210 | |
| 14 | 0.001 | 0.009 | 0.001 | 0.010 | 0.131 | |
| 15 | 0.005 | 0.036 | 0.003 | 0.023 | 0.150 | |
| 16 | 0.001 | 0.010 | 0.002 | 0.012 | 0.115 | |
| 17 | 0.005 | 0.035 | 0.013 | 0.093 | 0.132 | |
| 18 | 0.001 | 0.008 | 0.002 | 0.015 | 0.102 | |
| 19 | 0.008 | 0.056 | 0.010 | 0.069 | 0.118 | |
| 20 | 0.001 | 0.007 | 0.002 | 0.012 | 0.092 | |
| 21 | 0.005 | 0.034 | 0.002 | 0.014 | 0.107 | 0.160 |
| 22 | 0.002 | 0.011 | 0.002 | 0.012 | 0.084 | |
| 23 | 0.007 | 0.048 | 0.010 | 0.072 | 0.098 | 0.147 |
| 24 | 0.001 | 0.006 | 0.001 | 0.010 | 0.077 | |
| 25 | 0.006 | 0.039 | 0.011 | 0.078 | 0.090 | 0.135 |
| 26 | 0.001 | 0.005 | 0.001 | 0.008 | 0.071 | |
| 27 | 0.003 | 0.022 | 0.003 | 0.019 | 0.083 | 0.124 |
| 28 | 0.002 | 0.013 | 0.001 | 0.007 | 0.066 | |
| 29 | 0.004 | 0.027 | 0.009 | 0.064 | 0.078 | 0.117 |
| 30 | 0.001 | 0.006 | 0.001 | 0.008 | 0.061 | |
| 31 | 0.005 | 0.032 | 0.009 | 0.061 | 0.073 | 0.109 |
| 32 | 0.001 | 0.009 | 0.001 | 0.008 | 0.058 | |
| 33 | 0.002 | 0.015 | 0.002 | 0.015 | 0.068 | 0.102 |
| 34 | 0.002 | 0.014 | 0.001 | 0.007 | 0.054 | |
| 35 | 0.002 | 0.016 | 0.005 | 0.037 | 0.064 | 0.096 |
| 36 | 0.001 | 0.004 | 0.001 | 0.007 | 0.051 | |
| 37 | 0.003 | 0.022 | 0.007 | 0.049 | 0.061 | 0.091 |
| 38 | 0.001 | 0.005 | 0.001 | 0.009 | 0.048 | |
| 39 | 0.002 | 0.010 | 0.004 | 0.024 | 0.058 | 0.087 |
| 40 | 0.002 | 0.014 | 0.001 | 0.008 | 0.002 | |

Note the higher limits for odd harmonics 21 and above are only allowable under certain conditions, if these higher limits are utilised please state the exemption used as detailed in part 6.2.3.4 of BS EN 61000-3-2 in the box below.

Current Harmonics



THD



4.2.2 Voltage fluctuations and Flicker

These tests should be undertaken in accordance with EREC G98 Annex A1 A.1.3.3 (Inverter connected) or Annex A2 A.2.3.3 (Synchronous).

The measurements of voltage fluctuations have been measured according to the standard, at 100 % of the nominal power value of the inverter.

The test impedance is recorded in the table below:

| | | | | | | |
|--------------------|---|-----|----------|---|------|----------|
| Test Impedance | R | 0.4 | Ω | X | 0.25 | Ω |
| Standard Impedance | R | 0.4 | Ω | X | 0.25 | Ω |
| Maximum Impedance | R | 0.4 | Ω | X | 0.25 | Ω |

| Starting operation and Stopping operation | | | |
|---|---------------|--------------------------|--------------------------|
| Pbin (%) | 100% | | |
| Phase A | | | |
| | Limit | Starting measured values | Stopping measured values |
| PST | ≤ 1 | 0.058 | 0.059 |
| PLT | ≤ 0.65 | 0.059 | 0.059 |
| dc | $\leq 3.30\%$ | 0.094% | 0.108% |
| d(t) | $\leq 3.30\%$ | 0.00% | 0.00% |
| dmax | 4% | 0.284% | 0.353% |
| Phase B | | | |
| | Limit | Starting measured values | Stopping measured values |
| PST | ≤ 1 | 0.135 | 0.135 |
| PLT | ≤ 0.65 | 0.135 | 0.135 |
| dc | $\leq 3.30\%$ | 0.034% | 0.034% |
| d(t) | $\leq 3.30\%$ | 0.00% | 0.00% |
| dmax | 4% | 0.113% | 0.101% |
| Phase C | | | |
| | Limit | Starting measured values | Stopping measured values |
| PST | ≤ 1 | 0.042 | 0.042 |
| PLT | ≤ 0.65 | 0.043 | 0.043 |
| dc | $\leq 3.30\%$ | 0.019% | 0.008% |
| d(t) | $\leq 3.30\%$ | 0.000% | 0.000% |
| dmax | 4% | 0.100% | 0.112% |

As it can be seen in the next screenshots, this test has two steps:

1. Starting operation
2. Stopping operation

All values are the most unfavorable of the two steps.

Starting operation and Stopping operation

100% Pn

Phase A

Flicker Mode
Flicker

Range Over

| | | | | | | |
|----|----|----|----|----|----|----|
| U1 | U2 | U3 | U4 | U5 | U6 | U7 |
| I1 | I2 | I3 | I4 | I5 | I6 | I7 |

SCL Line Filter

AVG Freq Filter

CH: 1 2 3

4 5 6 7

Count 2/2 Complete

Interval 00:00s/10:00s

Element 1

Volt Range 300 V/50Hz

Un (U1) 230.468V

Freq (U1) 50.000Hz

Dmin 0.10%

Element1 Judgement Pass

Total Judgement Pass

(Element1,2,3)

| | dc[%] | dmax[%] | d(t)[ms] | Pst | Plt |
|--------|--|--|--|--|--|
| Limit | 3.30 | 4.00 | 500 3.30% | 1.00 | 0.65 N:2 |
| No. 1 | 0.094 Pass | 0.284 Pass | 0.0 Pass | 0.058 Pass | |
| 2 | 0.108 Pass | 0.353 Pass | 0.0 Pass | 0.059 Pass | |
| Result | Pass | Pass | Pass | Pass | 0.059 Pass |

ΣA(3P4W)

U1 300 V
I1 50 A
Sync Src: U1
Integral: Reset

U2 300 V
I2 50 A
Sync Src: U1
Integral: Reset

U3 300 V
I3 50 A
Sync Src: U1
Integral: Reset

Element 4

U4 1000 V
I4 50 A
Sync Src: U1
Integral: Reset

Element 5

U5 1000 V
I5 5 A
Sync Src: U1
Integral: Reset

Update: 633

Runtime: 5:08:58

138% 10% x1
2020-06-06 13:50:45

Phase B

Flicker Mode
Flicker

Range Over

| | | | | | | |
|----|----|----|----|----|----|----|
| U1 | U2 | U3 | U4 | U5 | U6 | U7 |
| I1 | I2 | I3 | I4 | I5 | I6 | I7 |

SCL Line Filter

AVG Freq Filter

PA_00013.tif

CH: 1 2 3

4 5 6 7

Count 2/2 Complete

Interval 00:00s/10:00s

Element 2

Volt Range 300 V/50Hz

Un (U2) 230.528V

Freq (U2) 50.000Hz

Dmin 0.10%

Element2 Judgement Pass

Total Judgement Pass

(Element1,2,3)

| | dc[%] | dmax[%] | d(t)[ms] | Pst | Plt |
|--------|--|--|--|--|--|
| Limit | 3.30 | 4.00 | 500 3.30% | 1.00 | 0.65 N:2 |
| No. 1 | 0.034 Pass | 0.113 Pass | 0.0 Pass | 0.135 Pass | |
| 2 | 0.001 Pass | 0.101 Pass | 0.0 Pass | 0.135 Pass | |
| Result | Pass | Pass | Pass | Pass | 0.135 Pass |

ΣA(3P4W)

U1 300 V
I1 50 A
Sync Src: U1
Integral: Reset

U2 300 V
I2 50 A
Sync Src: U1
Integral: Reset

U3 300 V
I3 50 A
Sync Src: U1
Integral: Reset

Element 4

U4 1000 V
I4 50 A
Sync Src: U1
Integral: Reset

Element 5

U5 1000 V
I5 5 A
Sync Src: U1
Integral: Reset

Update: 637

Runtime: 5:09:06

138% 10% x1
2020-06-06 13:50:53

Phase C

Flicker Mode
Flicker

Range Over

| | | | | | | |
|----|----|----|----|----|----|----|
| U1 | U2 | U3 | U4 | U5 | U6 | U7 |
| I1 | I2 | I3 | I4 | I5 | I6 | I7 |

SCL Line Filter

AVG Freq Filter

PA_00014.tif

CH: 1 2 3

4 5 6 7

Count 2/2 Complete

Interval 00:00s/10:00s

Element 3

Volt Range 300 V/50Hz

Un (U3) 230.635V

Freq (U3) 50.000Hz

Dmin 0.10%

Element3

Total

(Element1,2,3)

Judgement Pass

Judgement Pass

| | dc[%] | dmax[%] | d(t)[ms] | Pst | Pit |
|--------|---|---|---|---|---|
| Limit | 3.30 | 4.00 | 500 3.30% | 1.00 | 0.65 N:2 |
| No. 1 | 0.019 Pass | 0.100 Pass | 0.0 Pass | 0.042 Pass | |
| 2 | 0.008 Pass | 0.112 Pass | 0.0 Pass | 0.043 Pass | |
| Result | Pass | Pass | Pass | Pass | 0.043 Pass |

Σ A(3P4W)

U1 300 V

I1 50 A

Sync Src: U1

Integral: Reset

U2 300 V

I2 50 A

Sync Src: U1

Integral: Reset

U3 300 V

I3 50 A

Sync Src: U1

Integral: Reset

Element 4

U4 1000 V

I4 50 A

Sync Src: U1

Integral: Reset

Element 5

U5 1000 V

I5 5 A

Sync Src: U1

Integral: Reset

Update: 640

Runtime: 5:09:13

38%

10%

2020-06-06

13:51:00

| Running operation 2 hours | | | | |
|---------------------------|---------|-----------------|-----------------|-----------------|
| Pbin (%) | 100% | | | |
| | Limit | Phase A | Phase B | Phase C |
| | | Measured values | Measured values | Measured values |
| PST | ≤ 1 | 0.044 | 0.139 | 0.048 |
| PLT | ≤ 0.65 | 0.032 | 0.137 | 0.046 |
| dc | ≤ 3.30% | 0.114% | 0.010% | 0.020% |
| d(t) | ≤ 3.30% | 0.000% | 0.000% | 0.000% |
| dmax | 4% | 0.213% | 0.119% | 0.108% |

As it can be seen in the next screenshots is running operation. The values took of Pst and Plt are the most unfavorable of the twelve steps.

Running operation
100% Pn
Phase A

Flicker Mode
Flicker

Range Over
U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL
 Line Filter
 AVG
 Freq Filter

PA_00000.tif

CH: 1 2 3
 4 5 6 7

Count 12/12 Complete
 Interval 00:00s/10:00s

Element 1
 Volt Range 600 V/50Hz
 Un (U1) 230.272V
 Freq (U1) 50.000Hz
 Dmin 0.10%

Element1 Judgement Pass
 Total Judgement Pass
 (Element1,2,3)

Σ A(3P4W)
 U1 600 V
 I1 50 A
 Sync Src: U1
 Integral: Reset
 U2 600 V
 I2 50 A
 Sync Src: U1
 Integral: Reset
 U3 600 V
 I3 50 A
 Sync Src: U1
 Integral: Reset
 Element 4
 U4 1000 V
 I4 50 A
 Sync Src: U1
 Integral: Reset
 Element 5
 U5 1000 V
 I5 5 A
 Sync Src: U1
 Integral: Reset

| | dc[%] | dmax[%] | d(t)[ms] | Pst | Plt |
|---------------|---|---|---|---|---|
| Limit | 3.30 | 4.00 | 500 3.30% | 1.00 | 0.65 N:12 |
| No. 1 | 0.114 Pass | 0.159 Pass | 0.0 Pass | 0.044 Pass | |
| 2 | 0.068 Pass | 0.109 Pass | 0.0 Pass | 0.037 Pass | |
| 3 | 0.092 Pass | 0.132 Pass | 0.0 Pass | 0.027 Pass | |
| 4 | 0.017 Pass | 0.165 Pass | 0.0 Pass | 0.033 Pass | |
| 5 | 0.098 Pass | 0.213 Pass | 0.0 Pass | 0.025 Pass | |
| 6 | 0.071 Pass | 0.133 Pass | 0.0 Pass | 0.025 Pass | |
| 7 | 0.078 Pass | 0.171 Pass | 0.0 Pass | 0.026 Pass | |
| 8 | 0.104 Pass | 0.199 Pass | 0.0 Pass | 0.032 Pass | |
| 9 | 0.036 Pass | 0.151 Pass | 0.0 Pass | 0.027 Pass | |
| 10 | 0.095 Pass | 0.152 Pass | 0.0 Pass | 0.028 Pass | |
| 11 | 0.081 Pass | 0.146 Pass | 0.0 Pass | 0.030 Pass | |
| 12 | 0.090 Pass | 0.144 Pass | 0.0 Pass | 0.033 Pass | |
| Result | Pass | Pass | Pass | Pass | 0.032 Pass |

Update: 3716

Runtime: 7:39:47

51%
10%

2020-06-03
16:06:00

x1

Phase B

Flicker Mode
Flicker

Range Over

| | | | | | | |
|----|----|----|----|----|----|----|
| U1 | U2 | U3 | U4 | U5 | U6 | U7 |
| I1 | I2 | I3 | I4 | I5 | I6 | I7 |

SCL

Line Filter

AVG

Freq Filter

PA_00004.tif

CH: 1 2 3

4 5 6 7

Count 12/12 Complete

Interval 00:00s/10:00s

Element 2

Volt Range 600 V/50Hz

Un (U2) 230.157V

Freq (U2) 50.000Hz

Dmin 0.10%

| | | | |
|--|----------------|-----------|------|
| | Element2 | Judgement | Pass |
| | Total | Judgement | Pass |
| | (Element1,2,3) | | |

| | dc[%] | dmax[%] | d(t)[ms] | Pst | Pit |
|--------|------------|------------|--------------|------------|--------------|
| Limit | 3.30 | 4.00 | 500 3.30% | 1.00 | 0.65 N:12 |
| No. 1 | 0.010 Pass | 0.119 Pass | 0.0 Pass | 0.139 Pass | |
| 2 | 0.007 Pass | 0.111 Pass | 0.0 Pass | 0.138 Pass | |
| 3 | 0.006 Pass | 0.114 Pass | 0.0 Pass | 0.137 Pass | |
| 4 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.136 Pass | |
| 5 | 0.007 Pass | 0.104 Pass | 0.0 Pass | 0.136 Pass | |
| 6 | 0.009 Pass | 0.103 Pass | 0.0 Pass | 0.137 Pass | |
| 7 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.136 Pass | |
| 8 | 0.006 Pass | 0.105 Pass | 0.0 Pass | 0.137 Pass | |
| 9 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.137 Pass | |
| 10 | 0.011 Pass | 0.104 Pass | 0.0 Pass | 0.136 Pass | |
| 11 | 0.010 Pass | 0.119 Pass | 0.0 Pass | 0.137 Pass | |
| 12 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.137 Pass | |
| Result | Pass | Pass | Pass | Pass | 0.137 Pass |

Σ(A3P4W)

U1 600 V
I1 50 A
Sync Src: U1
Integral: Reset

U2 600 V
I2 50 A
Sync Src: U1
Integral: Reset

U3 600 V
I3 50 A
Sync Src: U1
Integral: Reset

Element 4

U4 1000 V
I4 50 A
Sync Src: U1
Integral: Reset

Element 5

U5 1000 V
I5 5 A
Sync Src: U1
Integral: Reset

Update: 3722

Runtime: 7:40:00

51%
10%

2020-06-03
16:06:13

Phase C

Flicker Mode
Flicker

Range Over

| | | | | | | |
|----|----|----|----|----|----|----|
| U1 | U2 | U3 | U4 | U5 | U6 | U7 |
| I1 | I2 | I3 | I4 | I5 | I6 | I7 |

SCL

Line Filter

AVG

Freq Filter

PA_00005.tif

CH: 1 2 3

4 5 6 7

Count 12/12 Complete

Interval 00:00s/10:00s

Element 3

Volt Range 600 V/50Hz

Un (U3) 230.253V

Freq (U3) 50.000Hz

Dmin 0.10%

| | | | |
|--|----------------|-----------|------|
| | Element3 | Judgement | Pass |
| | Total | Judgement | Pass |
| | (Element1,2,3) | | |

| | dc[%] | dmax[%] | d(t)[ms] | Pst | Pit |
|--------|------------|------------|--------------|------------|--------------|
| Limit | 3.30 | 4.00 | 500 3.30% | 1.00 | 0.65 N:12 |
| No. 1 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.048 Pass | |
| 2 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.047 Pass | |
| 3 | 0.013 Pass | 0.101 Pass | 0.0 Pass | 0.046 Pass | |
| 4 | 0.009 Pass | 0.101 Pass | 0.0 Pass | 0.045 Pass | |
| 5 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.046 Pass | |
| 6 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.046 Pass | |
| 7 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.046 Pass | |
| 8 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.046 Pass | |
| 9 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.046 Pass | |
| 10 | 0.020 Pass | 0.108 Pass | 0.0 Pass | 0.046 Pass | |
| 11 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.047 Pass | |
| 12 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.047 Pass | |
| Result | Pass | Pass | Pass | Pass | 0.046 Pass |

Σ(A3P4W)

U1 600 V
I1 50 A
Sync Src: U1
Integral: Reset

U2 600 V
I2 50 A
Sync Src: U1
Integral: Reset

U3 600 V
I3 50 A
Sync Src: U1
Integral: Reset

Element 4

U4 1000 V
I4 50 A
Sync Src: U1
Integral: Reset

Element 5

U5 1000 V
I5 5 A
Sync Src: U1
Integral: Reset

Update: 3726

Runtime: 7:40:07

51%
10%

2020-06-03
16:06:20

4.2.3 DC Injection

The DC component shall be measured under steady-state conditions for the following power levels: 20 %, 50 %, 75 %, and 100 % of nominal power with a tolerance of ± 5 % of nominal power and as far as adjustable for the tested micro-generator. These tests should be undertaken in accordance with Annex A1.3.4.


Following tables show the test results:

| Power quality – DC injection: This test should be carried out in accordance with EN 50438 Annex D.3.10 | | | | |
|---|-------|-------|-------|-------|
| Phase A | | | | |
| Test power level | 20% | 50% | 75% | 100% |
| Recorded value in Amps | 0.008 | 0.008 | 0.009 | 0.010 |
| as % of rated AC current | 0.05% | 0.05% | 0.06% | 0.07% |
| Limit | 0.25% | 0.25% | 0.25% | 0.25% |

| Phase B | | | | |
|--------------------------|-------|-------|-------|-------|
| Test power level | 20% | 50% | 75% | 100% |
| Recorded value in Amps | 0.003 | 0.007 | 0.012 | 0.015 |
| as % of rated AC current | 0.02% | 0.05% | 0.08% | 0.11% |
| Limit | 0.25% | 0.25% | 0.25% | 0.25% |

| Phase C | | | | |
|--------------------------|-------|-------|-------|-------|
| Test power level | 20% | 50% | 75% | 100% |
| Recorded value in Amps | 0.012 | 0.012 | 0.011 | 0.013 |
| as % of rated AC current | 0.08% | 0.08% | 0.08% | 0.09% |
| Limit | 0.25% | 0.25% | 0.25% | 0.25% |

DC injection test result




4.2.4 Power Factor

This test shall be carried out in accordance with EN 50538 Annex D.3.4.1 but with nominal voltage -6% and +10%. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test.


The following table shows the test results at required voltage levels:

| | 216.2 V | 230 V | 253 V |
|------------------------------------|---------|-------|-------|
| 20% of Registered Capacity | 0.996 | 0.995 | 0.994 |
| 50% of Registered Capacity | 0.999 | 0.999 | 0.999 |
| 75% of Registered Capacity | 0.999 | 0.999 | 0.999 |
| 100% of Registered Capacity | 0.999 | 1.000 | 0.999 |
| Limit | >0.95 | >0.95 | >0.95 |


Test results are graphically shown below.



Power Factor 230V



Power Factor 253V



4.3 PROTECTION

4.3.1 Frequency tests

These tests should be carried out in accordance with EN 50438 Annex D.2.4 and the notes in EREC G98 Annex A1 A.1.2.3 (Inverter connected) or Annex A2 A.2.2.3 (Synchronous).



To establish a trip frequency, the test frequency should be applied in a slow ramp rate of less than 0.1 Hz/s, or if this is not possible in steps of 0.05 Hz for a duration that is longer than the trip time delay.

To establish the trip time, the test frequency should be applied starting from 0.3 Hz below or above the recorded trip frequency and should be changed to 0.3 Hz above or below the recorded trip frequency in a single step. For each trip setting five tests shall be carried out.



Following tables show the test results:

| Function | Setting | | Trip test (5 times) | | "No trip tests" | |
|-------------|-----------|------------|---------------------|----------------|-------------------|-----------------|
| | Frequency | Time delay | Frequency (Hz) | Time delay (s) | Frequency /time | Confirm no trip |
| U/F stage 1 | 47.5 Hz | 20 s | 47.48 | 20.180 | 47.7 Hz / 25 s | Pass |
| | | | 47.46 | 20.130 | | |
| | | | 47.46 | 20.090 | | |
| | | | 47.46 | 20.100 | | |
| | | | 47.46 | 20.160 | | |
| U/F stage 2 | 47 Hz | 0.5 s | 46.96 | 0.496 | 47.2 Hz / 19.98 s | Pass |
| | | | 46.98 | 0.520 | | |
| | | | 46.96 | 0.492 | | |
| | | | 46.98 | 0.516 | | |
| | | | 46.96 | 0.486 | | |
| | | | | | 46.8 Hz / 0.48 s | Pass |
| O/F stage 1 | 52 Hz | 0.5 s | 51.98 | 0.502 | 51.8 Hz / 89.98 s | Pass |
| | | | 51.98 | 0.496 | | |
| | | | 51.98 | 0.512 | | |
| | | | 51.98 | 0.510 | | |
| | | | 51.98 | 0.508 | | |
| | | | | | 52.2 Hz / 0.48 s | Pass |



Test results are graphically shown below.





U/F stage 1-2





U/F stage 1-3




U/F stage 1-4





U/F stage 1-5





U/F stage 2-1





U/F stage 2-2





U/F stage 2-3





U/F stage 2-4





U/F stage 2-5





O/F stage 1-1





O/F stage 1-2





O/F stage 1-3





O/F stage 1-4





O/F stage 1-5





No trip tests - 47.7Hz





No trip tests – 47.2Hz





No trip tests – 46.8Hz



No trip tests - 51.8Hz



No trip tests – 52.2Hz



4.3.2 Voltage tests

To establish the certified trip voltage, the test voltage should be applied in steps of $\pm 0.5\%$ of setting for a duration that is longer than the trip time delay.


To establish the certified trip time, the test voltage should be applied starting from $\pm 1.8\%$ below the certified trip voltage in a step of at least $\pm 0.5\%$ of setting for a duration that is longer than the trip time delay. For each trip setting five tests shall be carried out.

Following tables show the test results:



| Function | Setting | | Trip test | | "No trip tests" | |
|-------------|---------|------------|-------------|----------------|------------------|-----------------|
| | Voltage | Time delay | Voltage (V) | Time delay (s) | Voltage /time | Confirm no trip |
| U/V | 184 V | 2.5 s | 183.3 | 2.544 | 188 V / 3.50 s | Pass |
| | | | 183.3 | 2.517 | | |
| | | | 183.3 | 2.524 | | |
| | | | 183.3 | 2.527 | | |
| | | | 183.3 | 2.532 | | |
| | | | | | 180 V / 2.48 s | Pass |
| O/V stage 1 | 262.2 V | 1.0 s | 262.4 | 1.034 | 258.2 V / 2.0 s | Pass |
| | | | 262.5 | 1.017 | | |
| | | | 262.5 | 1.016 | | |
| | | | 262.5 | 1.021 | | |
| | | | 262.5 | 1.015 | | |
| O/V stage 2 | 273.7 V | 0.5 s | 273.5 | 0.505 | 269.7 V / 0.98 s | Pass |
| | | | 273.5 | 0.501 | | |
| | | | 273.5 | 0.493 | | |
| | | | 273.5 | 0.489 | | |
| | | | 273.5 | 0.503 | | |
| | | | | | 277.7 V / 0.48 s | Pass |

Note for Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.



Test results are graphically shown in following pages.





U/V -2





U/V -3




U/V -4





UV -5




O/V stage 1-1




O/V stage 1-2





O/V stage 1-3





O/V stage 1-4





O/V stage 1-5





O/V stage 2-1





O/V stage 2-2





O/V stage 2-3





O/V stage 2-4





O/V stage 2-5





No trip tests – 188V





No trip tests – 180V




No trip tests – 258.2V



No trip tests – 269.7V



No trip tests – 277.7V



4.3.3 Loss of Mains test

For PV Inverters shall be tested in accordance with BS EN 62116.



The maximum trip time is 0.5 s.

Note for technologies which have a substantial shut down time this can be added to the 0.5 s in establishing that the trip occurred in less than 0.5 s. Maximum shut down time could therefore be up to 1.0 s for these technologies.


Following tables show the test results:



| Table: tested condition and trip time | | | | | | P |
|---------------------------------------|-----------------------------|-----------------------------|----------|----------|--------------|--|
| No. | P_{EUT} (% of EUT rating) | Reactive load (% of normal) | P_{AC} | Q_{AC} | Trip time(s) | Which load is selected to be adjusted (R or L) |
| Test condition A | | | | | | |
| 1 | 100 | 100 | 0 | 0 | 494 | -- |
| 2 | 100 | 100 | -5 | -5 | 468 | R/L |
| 3 | 100 | 100 | -5 | 0 | 470 | R |
| 4 | 100 | 100 | -5 | +5 | 384 | R/L |
| 5 | 100 | 100 | 0 | -5 | 446 | L |
| 6 | 100 | 100 | 0 | +5 | 450 | L |
| 7 | 100 | 100 | +5 | -5 | 492 | R/L |
| 8 | 100 | 100 | +5 | 0 | 478 | R |
| 9 | 100 | 100 | +5 | +5 | 430 | R/L |
| 10 | 100 | 100 | -10 | +10 | 408 | R/L |
| 11 | 100 | 100 | -5 | +10 | 424 | R/L |
| 12 | 100 | 100 | 0 | +10 | 422 | L |
| 13 | 100 | 100 | +10 | +10 | 470 | R/L |
| 14 | 100 | 100 | +10 | +5 | 436 | R/L |
| 15 | 100 | 100 | +10 | 0 | 470 | R |
| 16 | 100 | 100 | +10 | -5 | 474 | R/L |
| 17 | 100 | 100 | +10 | -10 | 476 | R/L |
| 18 | 100 | 100 | +5 | -10 | 432 | R/L |
| 19 | 100 | 100 | +5 | +10 | 484 | R/L |
| 20 | 100 | 100 | 0 | -10 | 466 | L |
| 21 | 100 | 100 | -5 | -10 | 400 | R/L |
| 22 | 100 | 100 | -10 | -10 | 450 | R/L |
| 23 | 100 | 100 | -10 | -5 | 424 | R/L |
| 24 | 100 | 100 | -10 | 0 | 472 | R |
| 25 | 100 | 100 | -10 | +5 | 388 | R/L |
| Test condition B | | | | | | |
| 1 | 66 | 66 | 0 | 0 | 422 | -- |
| 2 | 66 | 66 | 0 | -5 | 442 | L |
| 3 | 66 | 66 | 0 | -4 | 472 | L |
| 4 | 66 | 66 | 0 | -3 | 422 | L |
| 5 | 66 | 66 | 0 | -2 | 430 | L |
| 6 | 66 | 66 | 0 | -1 | 426 | L |
| 7 | 66 | 66 | 0 | 1 | 424 | L |
| 8 | 66 | 66 | 0 | 2 | 436 | L |
| 9 | 66 | 66 | 0 | 3 | 400 | L |
| 10 | 66 | 66 | 0 | 4 | 448 | L |
| 11 | 66 | 66 | 0 | 5 | 418 | L |
| Test condition C | | | | | | |
| 1 | 33 | 33 | 0 | 0 | 486 | -- |
| 2 | 33 | 33 | 0 | -5 | 422 | L |
| 3 | 33 | 33 | 0 | -4 | 454 | L |
| 4 | 33 | 33 | 0 | -3 | 466 | L |
| 5 | 33 | 33 | 0 | -2 | 422 | L |
| 6 | 33 | 33 | 0 | -1 | 458 | L |
| 7 | 33 | 33 | 0 | 1 | 472 | L |
| 8 | 33 | 33 | 0 | 2 | 432 | L |
| 9 | 33 | 33 | 0 | 3 | 438 | L |
| 10 | 33 | 33 | 0 | 4 | 436 | L |
| 11 | 33 | 33 | 0 | 5 | 416 | L |



Test results are graphically shown in following pages.







Test Condition C




























































































4.3.4 Frequency change, Vector Shift Stability test and RoCoF Stability test

Four tests are required to be carried out with all protection functions enabled including loss of mains. For each stability test the Micro-generator should not trip during the test.

For the step change test the Micro-generator should be operated with a measurable output at the start frequency and then a vector shift should be applied by extending or reducing the time of a single cycle with subsequent cycles returning to the start frequency. The start frequency should then be maintained for a period of at least 10 s to complete the test. The Micro-generator should not trip during this test.


For frequency drift tests the Micro-generator should be operated with a measurable output at the start frequency and then the frequency changed in a ramp function at 0.95 Hzs-1 to the end frequency. On reaching the end frequency it should be maintained for a period of at least 10 s. The Micro-generator should not trip during this test.

Test results are graphically shown in following pages.


Protection – Frequency change, Vector Shift Stability test: This test should be carried out in accordance with EREC G98 Annex A1 A.1.2.6 (Inverter connected) or Annex A2 A.2.2.6 (Synchronous).

| | Start Frequency | Change | Confirm no trip |
|-----------------------|-----------------|--------------|-----------------|
| Positive Vector Shift | 49.0 Hz | +50 degrees | Pass |
| Negative Vector Shift | 50.0 Hz | - 50 degrees | Pass |

Positive Vector Shift:




Negative Vector Shift:




Protection – Frequency change, RoCoF Stability test: The requirement is specified in section 11.3, test procedure in Annex A.1.2.6 (Inverter connected) or Annex A2 A.2.2.6 (Synchronous).

| Ramp range | Test frequency ramp: | Test Duration | Confirm no trip |
|--------------------|-------------------------|---------------|-----------------|
| 49.0 Hz to 51.0 Hz | +0.95 Hzs ⁻¹ | 2.4 s | Pass |
| 51.0 Hz to 49.0 Hz | -0.95 Hzs ⁻¹ | 2.1 s | Pass |

+0.95 Hz/s:



-0.95 Hz/s:



4.4 Limited Frequency Sensitive Mode - Overfrequency test

The test serves to verify the active power reduction of the micro-generator at over-frequency. We perform the test according to EN 50438 Annex D.3.3 Power response to over-frequency.

The tests for providing evidence of the frequency dependent active power feed-in of the micro-generator shall be carried out on a network simulator.


The test should be carried out using the specific threshold frequency of 50.4 Hz and Droop of 10%.

Following tables show the test results:


| Test sequence at Registered Capacity >80% | Measured Active Power Output (W) | Frequency (Hz) | Primary Power Source | Active Power Gradient(%) |
|---|----------------------------------|----------------|----------------------|--------------------------|
| Step a) 50.00 Hz ±0.01 Hz | 10011.3 | 50.00 | DC Source | N/A |
| Step b) 50.45 Hz ±0.05 Hz | 9917.0 | 50.45 | | 10.6 |
| Step c) 50.70 Hz ±0.10 Hz | 9447.6 | 50.70 | | 10.7 |
| Step d) 51.15 Hz ±0.05 Hz | 8570.5 | 51.15 | | 10.4 |
| Step e) 50.70 Hz ±0.10 Hz | 9455.2 | 50.70 | | 10.8 |
| Step f) 50.45 Hz ±0.05 Hz | 9916.7 | 50.45 | | 10.6 |
| Step g) 50.00 Hz ±0.01 Hz | 10010.3 | 50.00 | | N/A |

| Test sequence at Registered Capacity >80% | Measured Active Power Output (W) | Frequency (Hz) | Primary Power Source | Active Power Gradient(%) |
|---|----------------------------------|----------------|----------------------|--------------------------|
| Step a) 50.00 Hz ±0.01 Hz | 5012.28 | 50.00 | DC Source | N/A |
| Step b) 50.45 Hz ±0.05 Hz | 4964.39 | 50.45 | | 10.5 |
| Step c) 50.70 Hz ±0.10 Hz | 4719.23 | 50.70 | | 10.3 |
| Step d) 51.15 Hz ±0.05 Hz | 4296.13 | 51.15 | | 10.5 |
| Step e) 50.70 Hz ±0.10 Hz | 4721.55 | 50.70 | | 10.3 |
| Step f) 50.45 Hz ±0.05 Hz | 4963.73 | 50.45 | | 10.3 |
| Step g) 50.00 Hz ±0.01 Hz | 5011.21 | 50.00 | | N/A |

Test results are graphically shown in following pages.



Remark: Test for frequency threshold 50.4Hz with droop 10%, intentional delay is setting to 0s.



Remark: Test for frequency threshold 50.4Hz with droop 10%, intentional delay is setting to 0s.


4.5 Power output with falling frequency test

This test should be carried out in accordance with EN 50438 Annex D.3.2 active power feed-in at under-frequency.

| Test sequence | Measured Active Power Output (W) | Frequency (Hz) | Primary power source |
|---|----------------------------------|----------------|----------------------|
| Test a) 50 Hz \pm 0.01 Hz | 10013.0 | 50.0 | - |
| Test b) Point between 49.5 Hz and 49.6 Hz | 10012.6 | 49.5 | - |
| Test c) Point between 47.5 Hz and 47.6 Hz | 10010.7 | 47.5 | - |

NOTE: The operating point in Test (b) and (c) shall be maintained for at least 5 minutes

Test results are graphically shown in following pages.



4.6 Re-connection timer



Test should prove that the reconnection sequence starts after a minimum delay of 20 s for restoration of voltage and frequency to within the stage 1 settings of Table 2. These tests should be undertaken in accordance with Annex A.2.2.5.

4.6.1 Voltage Reconnection Conditions

The following table detail tests performed.

| Test at | Time delay setting(s) | Measured delay(s) | Checks on no reconnection when voltage is brought to just outside stage 1 limits of table 1. | |
|--|-----------------------|-------------------|--|------------------|
| UV | 60.0 | 63.2 | At 266.2V | At 196.1V |
| OV | 60.0 | 63.2 | | |
| Confirmation that the Micro-generator does not re-connect. | | | Not reconnection | Not reconnection |

Test results are graphically shown below.





4.6.2 Frequency Reconnection Conditions

The following table detail tests performed.

| Test at | Time delay setting(s) | Measured delay(s) | Checks on no reconnection when frequency is brought to just outside stage 1 limits of table 1. | |
|--|-----------------------|-------------------|--|------------------|
| UF | 60 | 63.2 | At 47.4Hz | At 52.1Hz |
| OF | 60 | 63.8 | | |
| Confirmation that the Micro-generator does not re-connect. | | | Not reconnection | Not reconnection |

Test results are graphically shown below.





4.7 Fault level contribution



These tests shall be carried out in accordance with EREC G98 Annex A1 A.1.3.5 (Inverter connected) and Annex A2 A.2.3.4 (Synchronous).



They have been performed different short circuit tests that are detailed in the table and pictures below.



| Short circuit current | | |
|-----------------------|----------|------------|
| L1-N | | |
| Time after fault | Volts(V) | Amps(A) |
| 20ms | 37.6 | 12.79 |
| 100ms | 0 | 9.76 |
| 250ms | 0 | 0 |
| 500ms | 0 | 0 |
| Time to trip | 0 | In seconds |



| Short circuit current | | |
|-----------------------|----------|------------|
| L2-L3 | | |
| Time after fault | Volts(V) | Amps(A) |
| 20ms | 223.8 | 13.31 |
| 100ms | 265.1 | 14.39 |
| 250ms | 0 | 0 |
| 500ms | 0 | 0 |
| Time to trip | 0 | In seconds |











4.8 SELF-MONITORING SOLID STATE SWITCHING

The evaluation of this point has been made according to EREC G98 Annex A1 A.1.3.6.

This test does not apply because in the inverter there are not solid-state switching devices.

4.9 ELECTROMAGNETIC COMPATIBILITY (EMC)

All equipment shall conform to the generic EMC standards: BS EN61000-6-3: Electromagnetic Compatibility, Generic Emission Standard; and BS EN61000-6-1: Electromagnetic Compatibility, Generic Immunity Standard.

The compliances with these requirements are stated in the following test report:

- EMC Test Report: Test Report no CE200608N033 on 2020/06/17 which issued by Shenzhen BALUN Technology Co.,. Ltd.


4.10 LOGIC INTERFACE.

Confirm that an input port is provided and can be used to shut down the module.

The evaluation of this point has been made according to Clause 9.4.3 of the standard.

Power Generating Modules connected to the DNO's Distribution Network shall be equipped with a logic interface (input port) in order to cease Active Power output within 5 s following an instruction being received at the input port.

Test results are graphically shown as below.



Ch1: AC Voltage
 Ch2 and Ch3: Output Current
 Ch4: Signal of logic interface.

5 PICTURES

Front view



Back view




Internal View 1




Internal View 2




Front side of Power board




Back side of Power board




Front side of Display board




Back side of Display board




Front side of Control board




Back side of Control board



Front side of Output board front



Back side of Output board front



Grounding




Connection interface



Serial Number and Software Version

```
Inverter Info(1)
Product SN:      SP1ES010H71002
ARM Software Version: V2.00
Main DSP Software Version: D010136
Slave DSP Software Version: D010134
```


6 ELECTRICAL SCHEMES



-----END OF REPORT-----