



**TEST REPORT
IEC 61727
Photovoltaic (PV) systems –
Characteristics of the utility interface**

Report Number..... : 2219 / 0190-1

Date of issue..... : 19/06/2019

Total number of pages 25

**Name of Testing Laboratory
preparing the Report** : SGS Tecnos, S.A. (Electrical Testing Laboratory)

Applicant's name : Shenzhen SOFAR SOLAR Co., Ltd.

Address..... : 401, Building 4, AnTongDa Industrial Park, District 68, XingDong
Community, XinAn Street, BaoAn District, Shenzhen City,
Guangdong Province, P.R. China

Test specification:

Standard : IEC 61727:2004 (Second Edition)

Test procedure : Characteristic Examination

Non-standard test method : N/A

Test Report Form No. : IEC61727A

Test Report Form(s) Originator : TÜV SÜD Product Service GmbH

Master TRF : Dated 2014-11

**Copyright © 2014 IEC System of Conformity Assessment Schemes for Electrotechnical
Equipment and Components (IECEE System). All rights reserved.**

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.


If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.







**This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory
and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.**

General disclaimer:

The test results presented in this report relate only to the object tested.



This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description	Solar Grid-tied Inverter
Trade Mark	
Manufacturer	Shenzhen SOFAR SOLAR Co., Ltd.
Model/Type reference	SOFAR 15000TL-G2
Ratings	<p> DC input: 160V-960V Max.21A /11 A AC output: 3/N/PE 230/400Va.c, 50Hz, Max.3 x 24A, 15000W Serial Number: SN1CS015K3G061 Firmware version: V0.21 </p>

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):						
<input type="checkbox"/>	CB Testing Laboratory:					
Testing location/ address.....:						
<input type="checkbox"/>	Associated CB Testing Laboratory:					
Testing location/ address.....:						
Tested by (name, function, signature).....:						
Approved by (name, function, signature)....:						
<input checked="" type="checkbox"/>	Testing procedure: TMP/CTF Stage 1:	Shenzhen SOFAR SOLAR Co., Ltd.				
Testing location/ address		401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen City, Guangdong Province, P.R. China				
Tested by (name, function, signature).....:		<table border="1"> <tr> <td>Hugo Zhang (Project Engineer)</td> <td></td> </tr> <tr> <td>Roger Hu (Project Engineer)</td> <td></td> </tr> </table>	Hugo Zhang (Project Engineer)		Roger Hu (Project Engineer)	
Hugo Zhang (Project Engineer)						
Roger Hu (Project Engineer)						
Approved by (name, function, signature)....:		Jacobo Tevar (Technical Reviewer)				
<input type="checkbox"/>	Testing procedure: WMT/CTF Stage 2:					
Testing location/ address.....:						
Tested by (name, function, signature).....:						
Witnessed by (name, function, signature) .:						
Approved by (name, function, signature)....:						
<input type="checkbox"/>	Testing procedure: SMT/CTF Stage 3 or 4:					
Testing location/ address.....:						
Tested by (name, function, signature).....:						
Witnessed by (name, function, signature) .:						
Approved by (name, function, signature)....:						
Supervised by (name, function, signature) :						

List of Attachments (including a total number of pages in each attachment):		
50 Hz		
Attachment #	Description	Pages
Attachment I	Pictures of the EUT and Electrical Schemes	12pages
Attachment II	Testing Information	5 pages
Attachment III	Graphs and Screenshots of Test Results	28 pages
Summary of testing:		
<p>Tests performed (name of test and test clause):</p> <p>The equipment has been tested according to the standard: IEC 61727:2004. Testing has been carried out at 50 Hz</p> <p>All applicable tests according to the above specified standard have been carried out.</p> <p>From the result of inspection and tests on the submitted sample, we conclude that it complies with the requirements of the standard.</p>	<p>Testing location:</p> <p>Shenzhen SOFAR SOLAR Co., Ltd. 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen City, Guangdong Province, P.R. China</p> <p>(All clauses)</p>	
Summary of compliance with National Differences:		
No National Differences are addressed to this test report		

Copy of marking plate(representative):

 Solar Grid-tied Inverter	
Model No:	SOFAR 15000TL-G2
Max.DC Input Voltage	1000V
Operating MPPT Voltage Range	160~960V
Max. Input Current	21A/11A
Max. PV Isc	30A/15A
Nominal Grid Voltage	3/N/PE,230/400Vac
Max.Output Current	3x24A
Nominal Grid Frequency	50/60Hz
Nominal Output Power	15000W
Max.Output Power	16500VA
Power Factor	>0.99(adjustable+/-0.8)
Ingress Protection	IP65
Operating Temperature Range	-25°C~ +60°C
Protective Class	Class I
Topology	Non-isolated
Made In China	
Manufacturer : Shenzhen SOFAR SOLAR Co.,Ltd. Address : 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community,XinAn Street, BaoAn District, Shenzhen, China IEC62109-1,IEC62109-2,NB-T 32004	
	

Note:

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation
3. Labels of other models are as the same with SOFAR 15000TL-G2's except the parameters of rating.

Test item particulars: Solar Grid-tied Inverter (Three Phase Inverter)	
Classification of installation and use: Fixed (permanent connection)	
Supply Connection: DC; PV	
.....: AC; Grid connection	
Possible test case verdicts:	
- test case does not apply to the test object.....: N/A	
- test object does meet the requirement.....: P (Pass)	
- test object does not meet the requirement.....: F (Fail)	
Testing: CTF Stage 1 procedure	
Date of receipt of test item: N/A	
Date (s) of performance of tests: From 07/05/2019 to 18/06/2019	
General remarks:	
<p>"(See Enclosure #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report.</p> <p>This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.</p>	
<p>Throughout this report a <input type="checkbox"/> comma / <input checked="" type="checkbox"/> point is used as the decimal separator.</p>	
Manufacturer's Declaration per sub-clause 4.2.5 of IEC 61727:	
<p>The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided</p>	<p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> Not applicable</p>
When differences exist; they shall be identified in the General product information section.	
<p>Name and address of factory (ies): Dongguan SOFAR SOLAR Co.,Ltd. 1F - 6F, Building E, No. 1 JinQi Road, Bihu Industrial Park, Wulian Village, Fenggang Town, Dongguan City, Guangdong Province, P.R. China.</p>	

General product information:

Product covered by this report is grid-connected PV inverter for indoor or outdoor installation. The connection to the DC input and AC output are through connectors.

The Solar inverter converts DC voltage into AC voltage.

The input and output are protected by varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high power switching bridge and a two relays. This assures that the opening of the output circuit can operate in case of one error.

Equipment Under Testing:

- SOFAR 15000TL-G2

Variant models:

- SOFAR 12000TL-G2
- SOFAR 10000TL-G2

Model Number	SOFAR 15000TL-G2	SOFAR 12000TL-G2	SOFAR 10000TL-G2
Max. input voltage	1000Vd.c.		
Max. input current	21A/11A		
Operating MPPT voltage range	160V-960V		
Rated voltage	600V		
Full load DC Voltage Range	500V-850V	500V-850V	350V-850V
Rated grid voltage	3/N/PE 230/400Va.c		
Rated grid frequency	50Hz		
Rated output power	15000W	12000W	10000W
Max. output current	3 x 24A	3 x 20A	3 x 16.5A
Power factor	0.8 leading to 0.8 lagging		
Ambient temperature	-25 °C ~60 °C		
Ingress protection	IP65		
Protective class	Class I		

The variants models have been included in this test report without tests because the following features don't change regarding to the tested model:

- Same connection system and hardware topology
- Same control algorithm.
- Output power within 2.5 and 2/3 of the EUT or Modular inverters.
- Same Firmware Version

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict
4	UTILITY COMPATIBILITY		P
	The quality of power provided by the PV system for the on-site AC loads and for power delivered to the utility is governed by practices and standards on voltage, flicker, frequency, harmonics and power factor.		P
	Deviation from these standards represents out-of-bounds conditions and may require the PV system to sense the deviation and properly disconnect from the utility system.		P
4.1	Voltage, current and frequency		P
	The PV system AC voltage, current and frequency are compatible with the utility system.		P
4.2	Normal voltage operating range		P
	Utility-interconnected PV systems do not normally regulate voltage, they inject current into the utility. Therefore, the voltage operating range for PV inverters is selected as a protection function that responds to abnormal utility conditions, not as a voltage regulation function.		P
4.3	Flicker		P
	The operation of the PV system is not cause voltage flicker in excess of limits stated in the relevant sections of IEC 61000-3-3 for systems less than 16 A or IEC 61000-3-5 for systems with current of 16 A and above.	(see appended table)	P
4.4	DC injection		P
	The PV system is not inject DC current greater than 1 % of the rated inverter output current, into the utility AC interface under any operating condition.	(see appended table)	P
4.5	Normal frequency operating range		P
	The PV system operates in synchronism with the utility system, and within the frequency trip limits defined in 5.2.2.		P
4.6	Harmonics and waveform distortion		P
	Total harmonic current distortion is less than 5 % at rated inverter output. Each individual harmonic is limited to the percentages listed in Table 1.	(see appended table)	P
	Even harmonics in these ranges is less than 25 % of the lower odd harmonic limits listed.		P

IEC 61727																			
Clause	Requirement + Test	Result - Remark	Verdict																
	Table 1 – Current distortion limits		P																
	<table border="1" style="width: 100%;"> <thead> <tr> <th style="width: 50%;">Odd harmonics</th> <th style="width: 50%;">Distortion limit</th> </tr> </thead> <tbody> <tr> <td>3rd through 9th</td> <td>Less than 4,0 %</td> </tr> <tr> <td>11th through 15th</td> <td>Less than 2,0 %</td> </tr> <tr> <td>17th through 21st</td> <td>Less than 1,5 %</td> </tr> <tr> <td>23rd through 33rd</td> <td>Less than 0,6 %</td> </tr> <tr> <th>Even harmonics</th> <th>Distortion limit</th> </tr> <tr> <td>2rd through 8th</td> <td>Less than 1,0 %</td> </tr> <tr> <td>10th through 32nd</td> <td>Less than 0,5 %</td> </tr> </tbody> </table>	Odd harmonics	Distortion limit	3 rd through 9 th	Less than 4,0 %	11 th through 15 th	Less than 2,0 %	17 th through 21 st	Less than 1,5 %	23 rd through 33 rd	Less than 0,6 %	Even harmonics	Distortion limit	2 rd through 8 th	Less than 1,0 %	10 th through 32 nd	Less than 0,5 %		
Odd harmonics	Distortion limit																		
3 rd through 9 th	Less than 4,0 %																		
11 th through 15 th	Less than 2,0 %																		
17 th through 21 st	Less than 1,5 %																		
23 rd through 33 rd	Less than 0,6 %																		
Even harmonics	Distortion limit																		
2 rd through 8 th	Less than 1,0 %																		
10 th through 32 nd	Less than 0,5 %																		
4.7	The PV system has a lagging power factor greater than 0,9 when the output is greater than 50 % of the rated inverter output power.	(see appended table)	P																
5	PERSONNEL SAFETY AND EQUIPMENT PROTECTION		P																
	This Clause provides information and considerations for the safe and proper operation of the utility-connected PV systems.		P																
5.1	Loss of utility voltage		P																
	To prevent islanding, a utility connected PV system ceases to energize the utility system from a de-energized distribution line irrespective of connected loads or other generators within specified time limits.		P																
	A utility distribution line can become de-energized for several reasons. For example, a substation breaker opening due to fault conditions or the distribution line switched out during maintenance.		P																
5.2	Over/under voltage and frequency		P																
	The abnormal utility conditions of concern are voltage and frequency excursions above or below the values stated in this Clause, and the complete disconnection of the utility, presenting the potential for a distributed resource island.	(see appended table)	P																
5.2.1	Over/under voltage		P																
	When the interface voltage deviates outside the conditions specified in Table 2, the photovoltaic system ceases to energize the utility distribution system. This applies to any phase of a multiphase system.	(see appended table)	P																
	<table border="1" style="width: 100%;"> <thead> <tr> <th style="width: 50%;">Voltage (at point of utility connection)</th> <th style="width: 50%;">Maximum trip time*</th> </tr> </thead> <tbody> <tr> <td>$V < 0,5 \times V_{nominal}$</td> <td>0,1 s</td> </tr> <tr> <td>$50 \% \leq V < 85 \%$</td> <td>2,0 s</td> </tr> <tr> <td>$85 \% \leq V \leq 110 \%$</td> <td>Continuous operation</td> </tr> <tr> <td>$110 \% < V < 135 \%$</td> <td>2,0 s</td> </tr> <tr> <td>$135 \% \leq V$</td> <td>0,05 s</td> </tr> </tbody> </table> <p>* Trip time refers to the time between the abnormal condition occurring and the inverter ceasing to energize the utility line. The PV system control circuits shall actually remain connected to the utility to allow sensing of utility electrical conditions for use by the "reconnect" feature.</p>	Voltage (at point of utility connection)	Maximum trip time*	$V < 0,5 \times V_{nominal}$	0,1 s	$50 \% \leq V < 85 \%$	2,0 s	$85 \% \leq V \leq 110 \%$	Continuous operation	$110 \% < V < 135 \%$	2,0 s	$135 \% \leq V$	0,05 s		P				
Voltage (at point of utility connection)	Maximum trip time*																		
$V < 0,5 \times V_{nominal}$	0,1 s																		
$50 \% \leq V < 85 \%$	2,0 s																		
$85 \% \leq V \leq 110 \%$	Continuous operation																		
$110 \% < V < 135 \%$	2,0 s																		
$135 \% \leq V$	0,05 s																		
5.2.2	Over/under frequency		P																

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict
	When the utility frequency deviates outside the specified conditions the photovoltaic system ceases to energize the utility line. The unit does not have to cease to energize if the frequency returns to the normal utility continuous operation condition within the specified trip time.	(see appended table)	P
	When the utility frequency is outside the range of ± 1 Hz, the system ceases to energize the utility line within 0,2 s. The purpose of the allowed range and time delay is to allow continued operation for short-term disturbances and to avoid excessive nuisance tripping in weak-utility system conditions.		P
5.3	Islanding protection		P
	The PV system must cease to energize the utility line within 2 s of loss of utility.	Test according IEC 62116: 2014 Refer to Test Report No: 2219 / 0190-2	P
5.4	Response to utility recovery		P
	Following an out-of-range utility condition that has caused the photovoltaic system to cease energizing, the photovoltaic system is not energize the utility line for 20 s to 5 min after the utility service voltage and frequency have recovered to within the specified ranges.	(see appended table)	P
5.5	Earthing		P
	The utility interface equipment is earthed/grounded in accordance with IEC 60364-7-712.		P
5.6	Short circuit protection		P
	The photovoltaic system has short-circuit protection in accordance with IEC 60364-7-712.		P
5.7	Isolation and switching		P
	A method of isolation and switching is provided in accordance with IEC 60364-7-712.		P

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.3	TABLE: Flicker				P
	Starting	Stopping	Running		
Limit	4%	4%	Pst = 1.0	Plt = 0.65	
Sample model	SOFAR 15000TL-G2				
33%Pn for 50Hz					
Test value (Phase A)	0.44	0.41	0.36	0.35	
Test value (Phase B)	0.33	0.30	0.23	0.22	
Test value (Phase C)	0.37	0.34	0.23	0.23	
66%Pn for 50Hz					
Test value (Phase A)	0.54	0.58	0.36	0.35	
Test value (Phase B)	0.36	0.50	0.23	0.22	
Test value (Phase C)	0.45	0.50	0.23	0.23	
100%Pn for 50Hz					
Test value (Phase A)	0.48	0.64	0.36	0.35	
Test value (Phase B)	0.34	0.64	0.23	0.22	
Test value (Phase C)	0.37	0.74	0.23	0.23	
<p>Supplementary information: The measurements of voltage fluctuations have been measured at 33 %, 66% and 100 % of the nominal power value of the inverter. As it can be seen in screenshots in Attachment III, this test has two steps and 10min for each step: 1.Starting operation 2.Stopping operation The values took of Pst and Plt are the most unfavorable of the two steps. As it can be seen in the screenshots in Attachment III. The values took of Pst and Plt are the most unfavorable of the twelve steps and 10min for each step for running operation</p>					

4.4	TABLE: Direct current injection							P	
Rated output current (A)	Ratio of rated output power (VA)	Measured DC output current between terminals (A)						Isolated transformer ? (Yes/No)	Limit (A)
		L1-L2	L1-L3	L2-L3	L1-N	L2-N	L3-N		
21.7	33%	--	--	--	0.008	0.011	0.004	No	0.217
21.7	66%	--	--	--	0.008	0.011	0.005	No	0.217
21.7	100%	--	--	--	0.005	0.007	0.006	No	0.217
<p>Supplementary information: N/A</p>									

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(a)	Table: harmonics and waveform distortion (at 33%Pn Phase A, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.040	1	03	0.162	4	
04	0.135	1	05	0.190	4	
06	0.027	1	07	0.056	4	
08	0.032	1	09	0.056	4	
10	0.015	0.5	11	0.106	2	
12	0.017	0.5	13	0.089	2	
14	0.045	0.5	15	0.021	2	
16	0.041	0.5	17	0.201	1.5	
18	0.024	0.5	19	0.154	1.5	
20	0.050	0.5	21	0.025	1.5	
22	0.031	0.5	23	0.086	0.6	
24	0.036	0.5	25	0.079	0.6	
26	0.057	0.5	27	0.039	0.6	
28	0.013	0.5	29	0.097	0.6	
30	0.036	0.5	31	0.106	0.6	
32	0.020	0.5	33	0.019	0.6	
THD	0.475	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(b)	Table: harmonics and waveform distortion (at 33%Pn Phase B, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.040	1	03	0.109	4	
04	0.074	1	05	0.313	4	
06	0.049	1	07	0.152	4	
08	0.057	1	09	0.080	4	
10	0.060	0.5	11	0.187	2	
12	0.022	0.5	13	0.165	2	
14	0.053	0.5	15	0.021	2	
16	0.041	0.5	17	0.145	1.5	
18	0.014	0.5	19	0.119	1.5	
20	0.034	0.5	21	0.034	1.5	
22	0.038	0.5	23	0.094	0.6	
24	0.023	0.5	25	0.055	0.6	
26	0.035	0.5	27	0.047	0.6	
28	0.013	0.5	29	0.046	0.6	
30	0.030	0.5	31	0.103	0.6	
32	0.061	0.5	33	0.032	0.6	
THD	0.545	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(c)	Table: harmonics and waveform distortion (at 33%Pn Phase C, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.068	1	03	0.091	4	
04	0.138	1	05	0.465	4	
06	0.046	1	07	0.176	4	
08	0.065	1	09	0.034	4	
10	0.048	0.5	11	0.204	2	
12	0.036	0.5	13	0.143	2	
14	0.037	0.5	15	0.012	2	
16	0.046	0.5	17	0.221	1.5	
18	0.012	0.5	19	0.062	1.5	
20	0.024	0.5	21	0.010	1.5	
22	0.016	0.5	23	0.084	0.6	
24	0.029	0.5	25	0.107	0.6	
26	0.032	0.5	27	0.052	0.6	
28	0.015	0.5	29	0.063	0.6	
30	0.034	0.5	31	0.058	0.6	
32	0.075	0.5	33	0.014	0.6	
THD	0.669	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(d)	Table: harmonics and waveform distortion (at 66%Pn Phase A, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.045	1	03	0.053	4	
04	0.055	1	05	0.159	4	
06	0.011	1	07	0.070	4	
08	0.025	1	09	0.066	4	
10	0.025	0.5	11	0.095	2	
12	0.003	0.5	13	0.069	2	
14	0.035	0.5	15	0.020	2	
16	0.020	0.5	17	0.084	1.5	
18	0.009	0.5	19	0.091	1.5	
20	0.008	0.5	21	0.017	1.5	
22	0.028	0.5	23	0.101	0.6	
24	0.006	0.5	25	0.065	0.6	
26	0.016	0.5	27	0.010	0.6	
28	0.007	0.5	29	0.116	0.6	
30	0.012	0.5	31	0.077	0.6	
32	0.014	0.5	33	0.004	0.6	
THD	0.333	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(e)	Table: harmonics and waveform distortion (at 66%Pn Phase B, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.059	1	03	0.075	4	
04	0.061	1	05	0.175	4	
06	0.012	1	07	0.135	4	
08	0.036	1	09	0.028	4	
10	0.033	0.5	11	0.049	2	
12	0.033	0.5	13	0.056	2	
14	0.038	0.5	15	0.013	2	
16	0.037	0.5	17	0.114	1.5	
18	0.020	0.5	19	0.097	1.5	
20	0.028	0.5	21	0.017	1.5	
22	0.037	0.5	23	0.106	0.6	
24	0.004	0.5	25	0.112	0.6	
26	0.008	0.5	27	0.021	0.6	
28	0.011	0.5	29	0.098	0.6	
30	0.013	0.5	31	0.104	0.6	
32	0.005	0.5	33	0.017	0.6	
THD	0.381	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(f)	Table: harmonics and waveform distortion (at 66%Pn Phase C, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.029	1	03	0.026	4	
04	0.052	1	05	0.275	4	
06	0.018	1	07	0.066	4	
08	0.025	1	09	0.042	4	
10	0.019	0.5	11	0.058	2	
12	0.036	0.5	13	0.049	2	
14	0.031	0.5	15	0.035	2	
16	0.034	0.5	17	0.070	1.5	
18	0.009	0.5	19	0.114	1.5	
20	0.027	0.5	21	0.017	1.5	
22	0.012	0.5	23	0.091	0.6	
24	0.006	0.5	25	0.101	0.6	
26	0.015	0.5	27	0.025	0.6	
28	0.014	0.5	29	0.090	0.6	
30	0.014	0.5	31	0.083	0.6	
32	0.011	0.5	33	0.022	0.6	
THD	0.390	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(g)	Table: harmonics and waveform distortion (at 100%Pn Phase A, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.073	1	03	0.125	4	
04	0.071	1	05	0.391	4	
06	0.031	1	07	0.386	4	
08	0.008	1	09	0.082	4	
10	0.015	0.5	11	0.162	2	
12	0.023	0.5	13	0.176	2	
14	0.026	0.5	15	0.025	2	
16	0.029	0.5	17	0.229	1.5	
18	0.005	0.5	19	0.173	1.5	
20	0.006	0.5	21	0.009	1.5	
22	0.011	0.5	23	0.128	0.6	
24	0.027	0.5	25	0.123	0.6	
26	0.008	0.5	27	0.022	0.6	
28	0.013	0.5	29	0.109	0.6	
30	0.030	0.5	31	0.071	0.6	
32	0.014	0.5	33	0.010	0.6	
THD	0.728	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(h)	Table: harmonics and waveform distortion (at 100%Pn Phase B, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.051	1	03	0.030	4	
04	0.049	1	05	0.167	4	
06	0.012	1	07	0.327	4	
08	0.039	1	09	0.075	4	
10	0.036	0.5	11	0.197	2	
12	0.019	0.5	13	0.122	2	
14	0.033	0.5	15	0.070	2	
16	0.036	0.5	17	0.175	1.5	
18	0.012	0.5	19	0.187	1.5	
20	0.012	0.5	21	0.014	1.5	
22	0.023	0.5	23	0.127	0.6	
24	0.023	0.5	25	0.133	0.6	
26	0.005	0.5	27	0.021	0.6	
28	0.023	0.5	29	0.076	0.6	
30	0.023	0.5	31	0.098	0.6	
32	0.002	0.5	33	0.014	0.6	
THD	0.574	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(i)	Table: harmonics and waveform distortion (at 100%Pn Phase C, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.032	1	03	0.122	4	
04	0.078	1	05	0.353	4	
06	0.021	1	07	0.212	4	
08	0.033	1	09	0.108	4	
10	0.050	0.5	11	0.133	2	
12	0.017	0.5	13	0.167	2	
14	0.033	0.5	15	0.065	2	
16	0.039	0.5	17	0.174	1.5	
18	0.005	0.5	19	0.204	1.5	
20	0.011	0.5	21	0.018	1.5	
22	0.033	0.5	23	0.139	0.6	
24	0.006	0.5	25	0.146	0.6	
26	0.008	0.5	27	0.024	0.6	
28	0.012	0.5	29	0.119	0.6	
30	0.007	0.5	31	0.097	0.6	
32	0.012	0.5	33	0.022	0.6	
THD	0.632	5	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.7	TABLE: Power factor							P
No	Input			Output				Rated output (V.A)
	Voltage (V d.c.)	Current (A d.c.)	Power (W)	Voltage (V a.c.)	Current (A a.c.)	Power (W)	Power factor	
1	602.6	5.1	3096	230.0	13.2	3120	0.995 (a) 0.997 (b) -- (c)	(20±5)%
2	604.4	7.7	4634	230.1	19.7	4532	0.998 (a) 0.999 (b) -- (c)	(30±5)%
3	604.0	10.2	6175	230.2	26.3	6046	0.999 (a) 0.999 (b) -- (c)	(40±5)%
4	596.2	12.9	7706	230.3	32.7	7534	0.999 (a) 0.999(b) -- (c)	(50±5)%
5	596.4	15.5	9241	230.3	39.2	9028	0.999 (a) 1.000 (b) -- (c)	(60±5)%
6	603.2	17.9	10776	230.4	45.8	10553	1.000 (a) 1.000 (b) -- (c)	(70±5)%
7	599.3	20.5	12279	230.5	52.2	12019	1.000 (a) 1.000 (b) -- (c)	(80±5)%
8	596.3	23.2	13809	230.5	58.5	13486	1.000 (a) 1.000 (b) -- (c)	(90±5)%
9	597.6	25.7	15348	230.6	65.1	15002	1.000 (a) 1.000 (b) -- (c)	(100±5)%

Supplementary information:
 Power factor with "+" indicating leading and "-" indicating lagging

Each power stage has been maintained during 60 seconds for measurements with a sampling rate of 0.2 s.

Values offered correspond with the 60s average measured with each corresponding stage.

Except for power factor measurements, where:

The value a) indicates the average of measured absolute PF values during each 60s stage of measurement.

The value b) indicates the maximum leading PF value measured during each 60s stage of measurement.

The value c) indicates the maximum lagging PF value measured during each 60s stage of measurement.

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

5.2.1 & 5.4		TABLE: Under-and over-voltage trip settings and reconnection test						P
(1) Under voltage disconnection procedure								
Rated output voltage (V)	Output power (VA)	Required min. voltage (V)	Value of PCE trip settings (V)	Ratio of decreased (V / s)	Interval time (ms)	Measured tripped voltage (V)	Measured disconnection time (ms)	
50 % Vn ≤ V < 85 % Vn Phase ABC								
230	15000	195.5	195	--	2000	195.1	1944	
230	15000	155	155	--	2000	155.6	1900	
230	15000	117	117	--	2000	117.7	1890	
V < 50%Vn Phase ABC								
230	15000	114	114	--	100	113.4	79	
(2) Under voltage reconnection procedure								
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)		Reconnection time (s)			
20.6			229.9		73.4			
(3) Over voltage disconnection procedure								
Rated output voltage (V)	Output power (VA)	Required max. voltage (V)	Value of PCE trip settings (V)	Ratio of increased (V / s)	Interval time (ms)	Measured tripped voltage (V)	Measured disconnection time (ms)	
110 % Vn < V < 135 % Vn Phase ABC								
230	15000	253	255	--	2000	252.9	1830	
230	15000	282	282	--	2000	280.5	1290	
230	15000	309	309	--	2000	309.3	4	
135 % Vn ≤ V Phase ABC								
230	15000	312	312	--	50	311.2	4	
(4) Over voltage reconnection procedure								
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)		Reconnection time (s)			
15.2			229.8		78.2			
Supplementary information:								
N/A								

IEC 61727							
Clause	Requirement + Test					Result - Remark	Verdict
5.2.2 & 5.4	TABLE: Over/under frequency trip settings and reconnection test						Pass
(1) Under frequency disconnection procedure							
Rated output frequency (Hz)	Output power (VA)	Required min. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of decreased (Hz / s)	Interval time (ms)	Measured tripped frequency (Hz)	Measured disconnection time (ms)
50	15000	49	49	--	200	49.0	185
(2) Under frequency reconnection procedure							
Ratio of voltage rapidly decreased (Hz / s)			Reconnection frequency (Hz)		Reconnection time (s)		
10			50		70.6		
(3) Over frequency disconnection procedure							
Rated output frequency (Hz)	Output power (VA)	Required max. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of increased (Hz / s)	Interval time (ms)	Measured tripped frequency (Hz)	Measured disconnection time (ms)
50	15000	51	51	--	200	51.0	129
(4) Over frequency reconnection procedure							
Ratio of voltage rapidly decreased (Hz / s)			Reconnection frequency (Hz)		Reconnection time (s)		
10			50		70.4		
Supplementary information:							
N/A							

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

5.3 Table: tested condition and run-on time									P
No.	P _{EUT} (% of EUT rating)	Reactive load (% of normal)	P _{AC}	Q _{AC}	Run-on time(ms)	P _{EUT} (W)	Actual Q _r	V _{DC} (d.c.V)	Which load is selected to be adjusted (R or L)
Test condition A									
1	100	100	0	0	390	15015	1.00	802.9	--
2	100	100	-5	-5	190	15010	0.98	802.2	R/L
3	100	100	-5	0	328	15021	0.98	803.6	R
4	100	100	-5	+5	326	15011	1.05	801.9	R/L
5	100	100	0	-5	304	15010	1.00	802.3	L
6	100	100	0	+5	324	15008	1.01	802.7	L
7	100	100	+5	-5	175	15012	1.01	803.2	R/L
8	100	100	+5	0	336	15016	0.98	802.5	R
9	100	100	+5	+5	366	15013	0.97	802.6	R/L
10	100	100	-10	+10	--	--	--	--	R/L
11	100	100	-5	+10	--	--	--	--	R/L
12	100	100	0	+10	--	--	--	--	L
13	100	100	+10	+10	--	--	--	--	R/L
14	100	100	+10	+5	--	--	--	--	R/L
15	100	100	+10	0	--	--	--	--	R
16	100	100	+10	-5	--	--	--	--	R/L
17	100	100	+10	-10	--	--	--	--	R/L
18	100	100	+5	-10	--	--	--	--	R/L
19	100	100	+5	10	--	--	--	--	R/L
20	100	100	0	-10	--	--	--	--	L
21	100	100	-5	-10	--	--	--	--	R/L
22	100	100	-10	-10	--	--	--	--	R/L
23	100	100	-10	-5	--	--	--	--	R/L
24	100	100	-10	0	--	--	--	--	R/L
25	100	100	-10	+5	--	--	--	--	R/L

IEC 61727									
Clause	Requirement + Test				Result - Remark				Verdict

Test condition B									
10	66	66	0	0	358	9915	1.00	566.7	--
11	66	66	0	-5	133	9921	1.03	563.2	L
12	66	66	0	-4	172	9923	1.03	564.2	L
13	66	66	0	-3	141	9918	1.02	565.6	L
14	66	66	0	-2	278	9917	1.02	562.8	L
15	66	66	0	-1	350	9926	1.01	563.5	L
16	66	66	0	1	194	9932	0.99	563.8	L
17	66	66	0	2	350	9924	0.99	563.5	L
18	66	66	0	3	176	9922	0.99	563.6	L
19	66	66	0	4	196	9918	0.98	562.9	L
20	66	66	0	5	100	9925	0.98	564.1	L
21	66	66	0	6	--	--	--	--	L

Test condition C									
22	33	33	0	0	418	4964	1.00	306.3	--
23	33	33	0	-5	177	4966	1.03	304.6	L
24	33	33	0	-4	374	4968	1.04	305.2	L
25	33	33	0	-3	282	4957	1.02	306.8	L
26	33	33	0	-2	328	4953	1.02	304.3	L
27	33	33	0	-1	144	4965	1.00	306.4	L
28	33	33	0	1	243	4961	1.00	305.7	L
29	33	33	0	2	185	4962	1.00	303.4	L
30	33	33	0	3	140	4959	0.99	305.6	L
31	33	33	0	4	172	4958	0.99	304.6	L
32	33	33	0	5	79	4960	0.98	304.2	L
33	33	33	0	6	--	--	--	--	L

Remark:
 For test condition A:
 If any of the recorded run-on times are longer than the one recorded for the rated balance condition, then the non-shaded parameter combinations also require testing.
 For test condition B and C:
 If run-on times are still increasing at the 95 % or 105 % points, additional 1 % increments is taken until run-on times begin decreasing.
 The compliances with these requirements are stated in the following test report:
 IEC 62116: test report n° 2219 / 0190-2

--- End of test report---